

Public Notice
Olympic Region Clean Air Agency (ORCAA)
Voluntary Limit on Emissions
Washington State Department of Enterprise Services – Washington State Capitol Campus
Synthetic Minor Order # 19SMO1416

PERMIT APPLICANT:

Washington State Department of Enterprise Services
Washington State Capitol Campus
Olympia, WA

PERMITTING AUTHORITY:

Olympic Region Clean Air Agency
2940 Limited Lane NW
Olympia, WA 98502
1-800-422-5623 or (360) 539-7610, FAX (360) 491-6308

PROJECT DESCRIPTION: The Washington State Capitol Campus relies on several boilers for heat and diesel-fired engines for emergency power at the Washington State Capitol Campus (Capitol Campus) in Olympia, Washington. Washington State Department of Enterprise Services (DES) is requesting a voluntary limit on oxides of nitrogen (NOx) emissions from these boilers and emergency engines to establish the Capitol Campus as a minor source with respect to the Washington State Operating Permit Regulation in Chapter 173-401 WAC.

ORCAA reviewed DES's request and concludes that compliance with applicable air regulations and standards will likely be maintained. On this basis, ORCAA recommends that DES's request to establish a voluntary limit on NOx emissions be conditionally approved.

PUBLIC NOTICE: Pursuant to ORCAA Rule 6.1.3(b)(2) notice is hereby given of ORCAA's Preliminary Recommendation to approve DES's Synthetic Minor Order application as described above.

DOCUMENT AVAILABILITY: Copies of ORCAA's Preliminary Recommendation is available on ORCAA's website at www.orcaa.org/news-info. If you do not have internet access or need assistance, please contact our office at 360-539-7610.

PUBLIC COMMENTS: Comments on this case may be submitted to ORCAA in writing by 4:30 p.m. on August 18, 2020. Comments may be mailed to ORCAA at the address above or emailed to lauren.whybrew@orcaa.org. Comments that may be considered by ORCAA in making a final determination are those pertaining to air quality implications of the proposed project.

Published by Franca L. McNair, ORCAA Director. (360) 539-7610 extension 100.