

## TANKS (STAGE 1) SELF-INSPECTION LOG SHEET

ORCAA • 2940-B Limited Lane NW, Olympia, WA 98502 • (360) 539-7610 • www.orcaa.org

## **INSPECT AFTER EACH FUEL DELIVERY - OR - ONCE PER DAY**

	♦ THIS IS WHAT YOU WANT TO FIND ♦													
エ	(See "defect tables" on laminated clipboard cover for more info)										TANK:			
/ONT											MONTH:		YEAR:	
DAY OF MONTH	DUST CAP		ADAPTER (Non-swivel type)		SPILL BUCKET		FILL TUBE GASKET		POPPET VALVE		<sup>1</sup> Repa	air by end of next ore fuel deliveries	business day or a for tank with defe	accept ects.
<b>♦</b> D	☑ Tight ☑ Gasket OK		☑ Tight		☑ less than1" liquid ☑ no vapor from drain valve		☑ In place ☑ in good condition (dual point & coaxial)		☑ Seated properly (dual point only)		INITIALS	TAKEN OUT OF SERVICE	DEFECT CORRECTED	INITIALS
	ОК	Needs Repair <sup>1</sup>	OK	Needs Repair <sup>1</sup>	OK	Needs Repair <sup>1</sup>	OK	Needs Repair <sup>1</sup>	ОК	Needs Repair <sup>1</sup>	S	Date & Time	Date & Time	S
_1_														
2														
3 4														
5														
6														
7														
8														
9														
10														
11														
12														
13														
14														
15														
16 17														
18		-				-	<u> </u>			-				
19														
20														
21														
22														
23														
24														
25														
26														
27														
28														
29														
30														
31														