



**Environmental Services Company, Inc.**

Corporate Office:  
13715 West Markham  
Little Rock, Arkansas 72211  
Phone: 501-221-2565  
Fax: 501-221-1341  
Email: [corporate@esclabs.com](mailto:corporate@esclabs.com)

Northwest Branch:  
1107 Century Avenue  
Springdale, Arkansas 72762  
Phone: 479-750-1170  
Fax: 479-750-1172  
Email: [nwbranch@esclabs.com](mailto:nwbranch@esclabs.com)

Web Site: [www.esclabs.com](http://www.esclabs.com)

---

**Survey of Source Emissions  
for  
Bibler Brothers Lumber Company  
Russellville, Arkansas**

**Operating Permit 1628-AOP-R8 AFIN 58-00014**

**SN-13G No. 1 Dry Kiln and Wood Burner (Formaldehyde and CO)**

**Test Date: October 26, 2010**

## Table of Contents

	<u>Section</u>
Introduction and Summary of Results	1
1.1    Scope of Work	
1.2    Process Description	
1.3    Facility, Test and Regulatory Contacts	
1.4    Acknowledgments and Certification	
1.5    Discussion of Results	
1.6    Summary of Results	
Operating Data	2
2.1    Operating Data	
Sampling and Analysis Procedure	3
3.1    Sampling Methods	
3.2    Sampling Procedure	
3.3    Source Test Nomenclature and Calculations	
3.4    Stack Schematics	
Field and Laboratory Data	4
4.1    Field Data	
4.2    Laboratory Data	
Quality Assurance	5
5.1    Probe Nozzles	
5.2    Pitot Tubes	
5.3    Metering Systems	
5.4    Temperature Gauges	
5.5    Calibration Gasses	

## Introduction and Summary of Results

### ***1.1 Scope of Work***

At the request of Mr. Matt Hagenlocker of Bibler Brothers Lumber Company, Environmental Services Company, Inc. (ESC) performed air emissions testing on October 26, 2010 at the Bibler Brothers Lumber Company facility in Russellville, Arkansas. The scope of the work consisted of testing the No. 1 Dry Kiln and Wood Burner (SN-13G) for formaldehyde (HCHO) and carbon monoxide (CO). The testing performed on this source is required by the facility's Operating Permit (Permit #1628-AOP-R8 AFIN 58-00014). The purpose of the testing was to learn whether the source in question is in compliance with the emission rates as set forth in the permit.

## ***1.2 Process Description***

Kiln #1 is 33' wide and 200' long with a 16' high opening. The two 8' wide lumber loads are pushed through the kiln on trams at a rate of about 10,000 board feet per hour. Actual throughput is dictated by the moisture content of the green wood and the target ending moisture content. The two loads move in opposing directions. There are no vents. Fume and water vapor generated by the drying wood exhausts primarily through the ends of the kiln. Lumber is dried from its initial green lumber moisture content coming from the sawmill to a target of 13-17% moisture content. Unlike typical batch dry kilns, the kiln operates continuously. Burner function and heat input vary only to maintain heat demand by the varying wood quality and moisture content.

The heat source for the kiln is a 5 grate wood burner with a sloped-grate design. It is nominally rated at 25 MMBtu/hr heat input. The sawdust is delivered from the sawmill and enters the burner at moisture contents ranging from 45-55%. The sawdust is gasified in the burner box at temperatures in the 700 °F range. The combustion gasses are blended with return air from the kiln to produce a final heat supply temperature of approximately 500 °F. The supply air is then distributed inside the kiln to maintain a controlled dry bulb temperature.

A temporary stack was installed in the kiln roof near one end of the kiln to provide a site with a consistent, laminar air flow for formaldehyde sampling. A vertical rectangular stack was constructed over an existing but non-functioning vent door. The vent door was removed and a housing built to enclose the opening and funnel exhaust gasses through the 33" tall stack extension. The temporary stack had a 10" by 15" cross section.

### ***1.3 Facility, Test and Regulatory Contacts***

#### **Facility Contact**

Mr. Matt Hagenlocker  
Bibler Brothers Lumber Company  
2401 South Arkansas Avenue  
Russellville, AR 72801  
Phone: (479)968-4986  
Fax: (479)967-9989  
email: [mhagenlocker@biblerlumber.com](mailto:mhagenlocker@biblerlumber.com)

#### **Test Contact**

Mr. Jeff Woosley  
Environmental Services Co., Inc.  
13715 West Markham  
Little Rock, AR 72211  
Phone: (501)221-2565 x 116  
Fax: (501)221-1341  
email: [jeffw@esclabs.com](mailto:jeffw@esclabs.com)

The testing team consisted of the following individuals:

Mr. Jeff Woosley  
Mr. Parker Ferebee  
Mr. Walker Dimassimo

#### **Regulatory Contact**

Mr. Brent Day  
Arkansas Department of Environmental Quality  
5301 Northshore Drive  
North Little Rock, AR 72218  
Phone: (501)682-0766  
Fax: (501)682-0059  
email: [day@adeq.state.ar.us](mailto:day@adeq.state.ar.us)

Mr. Day of ADEQ was present to observe the testing.

#### ***1.4 Acknowledgements and Certification***

The staff of Environmental Services Company, Inc. (ESC) sincerely wishes to thank all personnel involved in the success of the testing program, especially Mr. Matt Hagenlocker of Bibler Brothers Lumber Company.

Having worked on this project, reviewed all data, and prepared this report, I hereby certify that the information contained herein is accurate and true according to the methods and procedures used and take responsibility for the contents thereof. Additionally, this report shall not be reproduced, except in full, without the written approval of the testing organization.

---

Jeffrey Woosley  
Special Projects Manager

## ***1.5 Discussion of Results***

The results from this testing program are summarized in the attached table. The table provides a detail of the stack gas parameters during the testing along with a detail of the concentration, expressed in parts per million by volume dry (ppmvd), and emission rate, expressed in pounds per hour (lbs/hr) and pounds per thousand board feet (lbs/MBF – formaldehyde only). Also included is a detail of the calculated stack test values and pollutant concentration trends during the testing program. The nomenclature and calculations for each method employed are detailed in Section 3.3 of this report.

The flow rate from the temporary stack was measured for the purpose of isokinetic sampling required by USEPA Method 316. However, that measured flow rate could not be related to the total flow lost from the kiln. Rather, total kiln flow was determined by applying the predicted oxygen consumption of the burner supplying heat to the kiln and utilizing the principles described in USEPA Method 19 to calculate total kiln flow. The total kiln flow along with pollutant concentrations from the temporary stack were used to calculate total kiln emissions.

Wood fuel usage for the continuous drying process averaged 5,260 pounds per hour during the test. Analysis of sawdust samples were made to determine a source specific F-Factor of 9,364 dscf/MMBtu and a heat value of 4,138 Btu/lb (wet basis – actual). Heat input averaged 21.77 MMBtu/hr during the test. A report of the wood fuel analysis performed by Standard Laboratories is provided in the Laboratory Analysis section (Section 4.2) of this report.

1.6 Summary of Results

SUMMARY OF RESULTS					
BIBLER BROTHERS LUMBER COMPANY RUSSELLVILLE, ARKANSAS					
NO. 1 DRY KILN AND WOOD BURNER (SN-13G)					
	Run #1	Run #2	Run #3	Average	Regulatory Limit
Sample date	10/26/10	10/26/10	10/26/10		
Sample time	1139-1239	1250-1350	1358-1458		
<u>Stack Parameters</u>					
Flow, acfm	806.62	901.67	903.54	870.61	--
Flow, dscf/hr	34,181.09	40,620.28	43,613.32	39,471.56	--
O <sub>2</sub> , % dry	18.96	19.41	19.93	19.44	--
CO <sub>2</sub> , % dry	2.06	1.61	1.12	1.59	--
Moisture, %	19.34	15.67	11.47	15.49	--
Temperature, °F	145	135	123	134	--
<u>Kiln Parameters</u>					
Sawdust feed rate, lbs/hr	5,220	5,300	5,260	5,260	
Heat Input, MMBtu/hr	21.60	21.93	21.77	21.77	--
Flow, dscf/hr	2,183,096.39	2,885,148.83	4,402,977.14	3,157,074.12	--
<u>Formaldehyde (kiln total)</u>					
Concentration, ppmvd	0.26	0.16	0.10	0.17	--
Emission rate, lbs/hr	0.04	0.04	0.03	0.04	0.46
Emission rate, lbs/MBF	0.0039	0.0032	0.0030	0.0034	0.038
<u>Carbon monoxide (kiln total)</u>					
Concentration, ppmvd	50.40	38.06	25.02	37.83	--
Emission rate, lbs/hr	8.00	7.98	8.01	8.00	8.2

**SUMMARY OF TEST DATA**  
**USEPA METHODS 316 AND 19**  
**Formaldehyde**

		<b>Run #1</b>	<b>Run #2</b>	<b>Run #3</b>
Identification:		No. 1 Dry Kiln and Wood Burner (SN-13G)		
Date:		10/26/10	10/26/10	10/26/10
Time:		1139-1239	1250-1350	1358-1458
$C_p$	Pitot correction factor, dimensionless	0.840	0.840	0.840
$\sqrt{\Delta P}$	Average of the square roots of the pressure heads, in. H <sub>2</sub> O	0.2078	0.2358	0.2405
$D_n$	Probe tip diameter, inches	0.413	0.413	0.413
$D_s$	Stack diameter, ft.	0.0000	0.0000	0.0000
STK L	Stack length, ft.	1.2500	1.2500	1.2500
STK W	Stack width, ft.	0.8333	0.8333	0.8333
$T_s$	Average stack temperature, °F	145	135	123
$T_m$	Average meter temperature, °F	72	76	79
$\Delta H$	Average pressure differential across the orifice meter, in. H <sub>2</sub> O	0.9200	1.1333	1.2458
$P_{bar}$	Barometric pressure at sampling site, in Hg.	30.01	30.01	30.01
$P_g$	Stack static pressure, in. Hg	0.01	0.01	0.01
$M_{hcho}$	Total amount of formaldehyde collected in the sampling train, ug	282	196	128
Vic	Total volume of liquid collected in the impingers and silica gel, mls	155.2	134.0	101.4
$V_m$	Volume of gas sample as measured by the dry gas meter, cf	30.421	34.135	37.258
$T_{min}$	Total sampling time, minutes	60.0	60.0	60.0
%O <sub>2</sub>	Percent O <sub>2</sub> by volume, dry basis	18.96	19.41	19.93
%CO <sub>2</sub>	Percent CO <sub>2</sub> by volume, dry basis	2.06	1.61	1.12
%CO+N <sub>2</sub>	Percent CO+N <sub>2</sub> by volume, dry basis	78.98	78.98	78.95
Y	Dry gas meter calibration factor	1.004	1.004	1.004
$F_d$	Volume of combustion components per unit of heat content, dscf/MMBtu	9,364	9,364	9,364
$GCV_{sd(d)}$	Gross caloric value of sawdust, dry basis, Btu/lb	8914	8914	8914
$GCV_{sd(w)}$	Gross caloric value of sawdust, wet basis, Btu/lb	4,138	4,138	4,138
$FF_{sd}$	Feed rate of sawdust to kiln, lb/hr	5,220	5,300	5,260
PROD	Board feet per hour through the kiln, BF/hr	11,382	11,382	11,382
$MW_{hcho}$	Molecular weight of formaldehyde, g/g-mol	30.03	30.03	30.03
$M_d$	Dry molecular weight of stack gasses, lb/lb-mole	29.0875	29.0345	28.9758
$V_{w(std)}$	Volume of water vapor in the gas sample, dscf	7.3053	6.3074	4.7729
$P_s$	Absolute stack gas pressure, in. Hg	30.0200	30.0200	30.0200
$V_{m(std)}$	Volume of metered gas sample, dscf	30.4606	33.9420	36.8513

**SUMMARY OF TEST DATA**  
**USEPA METHODS 316 AND 19**  
**Formaldehyde**

		<b>Run #1</b>	<b>Run #2</b>	<b>Run #3</b>
	Identification:	No. 1 Dry Kiln and Wood Burner (SN-13G)		
	Date:	10/26/10	10/26/10	10/26/10
	Time:	1139-1239	1250-1350	1358-1458
B <sub>ws</sub>	Water vapor in the gas stream, proportion by volume	0.1934	0.1567	0.1147
M <sub>s</sub>	Wet molecular weight of stack gasses, lb/lb-mole	26.9432	27.3054	27.7169
A	Area of the stack, ft <sup>2</sup>	1.0417	1.0417	1.0417
A <sub>n</sub>	Area of the nozzle, ft <sup>2</sup>	0.000930	0.000930	0.000930
V <sub>s</sub>	Velocity in the stack, ft/sec	12.9059	14.4267	14.4566
V <sub>acfm</sub>	Velocity in the stack, ACFM	806.62	901.67	903.54
Q <sub>std</sub>	Average stack gas dry volumetric flow rate from the temporary stack, dscf/hr	34,181.09	40,620.28	43,613.32
I	Isokinetic ratio, %	99.86	93.63	94.68
HI <sub>kiln</sub>	Heat input to kiln, MMBtu/hr	21.60	21.93	21.77
Q <sub>std(kiln)</sub>	Average gas dry volumetric flow rate from the kiln, dscf/hr	2,183,096.39	2,885,148.83	4,402,977.14
C <sub>hcho</sub>	Formaldehyde concentration, ppmvd	0.26	0.16	0.10
E <sub>lbs/hr</sub>	Formaldehyde emission rate from kiln, lbs/hr	0.04	0.04	0.03
E <sub>lbs/MBF</sub>	Formaldehyde emission rate from kiln, lbs/MBF	0.004	0.003	0.003

**SUMMARY OF TEST DATA**  
**USEPA METHOD 10**  
**Carbon Monoxide (CO) Emissions**

		<b>Run #1</b>	<b>Run #2</b>	<b>Run #3</b>
	Identification:	No. 1 Dry Kiln and Wood Burner (SN-13G)		
	Date:	10/26/10	10/26/10	10/26/10
	Time:	1139-1239	1250-1350	1358-1458
C	Average carbon monoxide concentration indicated by the gas analyzer, ppmvd	50.71	38.20	25.05
C <sub>o</sub>	Average of initial and final system calibration bias check responses for the zero carbon monoxide gas, ppmvd	1.89	1.39	0.49
C <sub>m</sub>	Average of initial and final system calibration bias check responses for the upscale carbon monoxide gas, ppmvd	118.13	117.45	118.29
C <sub>ma</sub>	Actual concentration of the upscale calibration gas, ppmvd	120.00	120.00	120.00
Q <sub>std(kiln)</sub>	Average stack gas dry volumetric flow rate from the kiln, dscf/hr	2,183,096.39	2,885,148.83	4,402,977.14
C <sub>co</sub>	Carbon monoxide concentration, ppmvd	50.40	38.06	25.02
E <sub>co</sub>	Carbon monoxide emission rate from kiln, lbs/hr	8.00	7.98	8.01

**SUMMARY OF TEST DATA**  
**USEPA METHOD 3A**  
**Oxygen (O<sub>2</sub>) and Carbon Dioxide (CO<sub>2</sub>) Concentration**

		<b>Run #1</b>	<b>Run #2</b>	<b>Run #3</b>
Identification:		No. 1 Dry Kiln and Wood Burner (SN-13G)		
Date:		10/26/10	10/26/10	10/26/10
Time:		1139-1239	1250-1350	1358-1458
C	Average oxygen concentration indicated by the gas analyzer, % dry	18.85	19.29	19.75
C <sub>o</sub>	Average of initial and final system calibration bias check responses for the zero oxygen gas, %	0.08	0.09	0.09
C <sub>m</sub>	Average of initial and final system calibration bias check responses for the upscale oxygen calibration gas, %	10.04	10.04	10.01
C <sub>ma</sub>	Actual concentration of the upscale oxygen calibration gas, %	10.06	10.06	10.06
C <sub>o2</sub>	Oxygen concentration, % dry	18.96	19.41	19.93

		<b>Run #1</b>	<b>Run #2</b>	<b>Run #3</b>
Identification:		No. 1 Dry Kiln and Wood Burner (SN-13G)		
Date:		10/26/10	10/26/10	10/26/10
Time:		1139-1239	1250-1350	1358-1458
C	Average carbon dioxide concentration indicated by the gas analyzer, % dry	2.10	1.67	1.14
C <sub>o</sub>	Average of initial and final system calibration bias check responses for the zero carbon dioxide gas, %	0.06	0.07	0.03
C <sub>m</sub>	Average of initial and final system calibration bias check responses for the upscale carbon dioxide calibration gas, %	5.19	5.20	5.18
C <sub>ma</sub>	Actual concentration of the upscale carbon dioxide calibration gas, %	5.17	5.17	5.17
C <sub>co2</sub>	Carbon dioxide concentration, % dry	2.06	1.61	1.12

**SUMMARY OF TEST DATA**  
**USEPA METHOD 19**  
**"F<sub>d</sub>" Calculations**

	Identification:	No. 1 Dry Kiln and Wood Burner (SN-13G)
	Date:	10/26/10
K	Conversion factor, unitless	1.00E+06
%H <sub>sd</sub>	Concentration of hydrogen in sawdust from ultimate fuel analysis, percent by weight	6.32
%C <sub>sd</sub>	Concentration of carbon in sawdust from ultimate fuel analysis, percent by weight	51.89
%S <sub>sd</sub>	Concentration of sulfur in sawdust from ultimate fuel analysis, percent by weight	0.00
%N <sub>sd</sub>	Concentration of nitrogen in sawdust from ultimate fuel analysis, percent by weight	0.15
%O <sub>sd</sub>	Concentration of oxygen in sawdust from ultimate fuel analysis, percent by weight	41.18
K <sub>hd</sub>	Constant, (dscf/lb)/%	3.64
K <sub>c</sub>	Constant, (dscf/lb)/%	1.53
K <sub>s</sub>	Constant, (dscf/lb)/%	0.57
K <sub>n</sub>	Constant, (dscf/lb)/%	0.14
K <sub>o</sub>	Constant, (dscf/lb)/%	0.46
GCV <sub>sd(d)</sub>	Gross caloric value of sawdust from ultimate fuel analysis, dry basis, Btu/lb	8,914
GCV <sub>sd(w)</sub>	Gross caloric value of sawdust from ultimate fuel analysis, wet basis, Btu/lb	4,138
F <sub>d</sub>	Volume of combustion components per unit of heat content for sawdust, dscf/MMBtu	9,364

## Operating Data

### **2.1**    *Operating Data*

The following pages detail the production/throughput data maintained during the testing program.

**ADEQ Test Kiln 2 At Oct 26, 2010 Tuesday Morning**

	Tons Of Sawdust Per Hour		Boardfeet Per Hour	Boardfeet Per Ton
<b>Test 1</b>	<b>2.61</b>	<b>91%</b>	<b>11,382</b>	<b>4,361</b>
<b>Test 2</b>	<b>2.65</b>	<b>92%</b>	<b>11,382</b>	<b>4,295</b>
<b>Test 3</b>	<b>2.63</b>	<b>91%</b>	<b>11,382</b>	<b>4,328</b>

**Green Package size**

	2 x 12	8	10	12	14
# Full Package	136	136	136	136	136
# Layers High	17	17	17	17	17
# Pcs Wide	8	8	8	8	8
Package BD FT	2176	2720	3264	3808	4352
	5/4 x 6	8	10	12	14
# Full Package	336	336	336	336	336
# Layers High	21	21	21	21	21
# Pcs Wide	16	16	16	16	16
Package BD FT	1680	2100	2520	2940	3360

BDFt Per Foot	Feet Per 12 Min	Feet Per Hour	BDFt Per Hour
816	1.4	6.5	5,712
630	1.8	9	5,670
	<b>Total Bdfeet per Hour</b>		<b>11,382</b>

## Sampling and Analysis Procedure

### 3.1 *Sampling Methods*

The emissions testing conducted on the source in question was performed in accordance with methodology as outlined in 40 CFR Part 60, Appendix A. Specifically, the following methods are referenced in this sampling program:

- ⇒ Method 1      Sample and Velocity Traverses for Stationary Sources
- ⇒ Method 2      Determination of Stack Gas Velocity and Volumetric Flow Rate (Type S Pitot Tube)
- ⇒ Method 3A     Determination of Oxygen and Carbon Dioxide Concentrations in Emissions From Stationary Sources (Instrumental Analyzer Procedure)
- ⇒ Method 10     Determination of Carbon Monoxide Emissions From Stationary Sources
- ⇒ Method 316    Sampling and Analysis for Formaldehyde Emissions from Stationary Sources in the Mineral Wool and Wool Fiberglass Industries
- ⇒ Method 19     Determination of Sulfur Dioxide Removal Efficiency and Particulate Matter, Sulfur Dioxide and Nitrogen Oxide Emission Rates

The aforementioned methods were employed without deviation from prescribed procedures except as allowed by the Arkansas Department of Environmental Quality.

### **3.2 Sampling Procedure**

Formaldehyde sampling was conducted using an Environmental Supply Company C-5000 Source Sampler.

Oxygen and carbon dioxide concentrations were determined according to Method 3A utilizing a Servomex 1400 O<sub>2</sub>/CO<sub>2</sub> monitor. The O<sub>2</sub> monitor was calibrated on a range of 0-18.8% with a 0, 10.06 and 18.8% gas, while the CO<sub>2</sub> monitor was calibrated on a range of 0-10.2% with a 0, 5.17 and 10.2% gas.

Carbon monoxide concentrations were determined according to Method 10. A TECO Model 48C nondispersive infrared (NDIR) analyzer was utilized. The analyzer was calibrated on a range of 0-229 ppm with a 0, 120 and 229 ppm gas.

Output from the pollutant analyzers was directed to a DasyLab 6.0 Data Acquisition System and downloaded continuously to the hard drive of a personal computer (PC). Readings were taken every second, averaged and displayed every minute and averaged over the test run.

### **3.3     *Source Test Nomenclature and Calculations***

The following pages detail the source test nomenclature and calculations for each test method employed in this sampling program.

**SOURCE TEST DEFINITIONS**  
**USEPA Method 316 and 19 – Formaldehyde**

$C_p$	Pitot correction factors, dimensionless
$\sqrt{\Delta P}$	Average of the square roots of the pressure heads, in. H <sub>2</sub> O
$D_n$	Probe tip diameter, inches
$D_s$	Stack diameter or dimensions, ft
$T_s$	Average stack temperature, °F
$T_m$	Average meter temperature, °F
$\Delta H$	Average pressure differential across the orifice meter, in. H <sub>2</sub> O
$P_{bar}$	Barometric pressure at sampling site, in. Hg
$P_g$	Stack static pressure, in. Hg
$M_{hcho}$	Total amount of formaldehyde collected in the sampling train, ug
$V_{ic}$	Total volume of liquid collected in impingers and silica gel, mls
$V_m$	Volume of gas sample as measured by dry gas meter, ft <sup>3</sup>
$T_{min}$	Total sampling time, minutes
%O <sub>2</sub>	Percent O <sub>2</sub> by volume, dry basis
%CO <sub>2</sub>	Percent CO <sub>2</sub> by volume, dry basis
%CO+%N <sub>2</sub>	Percent CO+N <sub>2</sub> by volume, dry basis
Y	Dry gas meter calibration factor
$F_d$	Volume of combustion components per unit of heat content, dscf/MMBtu
$GCV_{sd(d)}$	Gross caloric value of sawdust, dry basis, Btu/lb
$GCV_{sd(w)}$	Gross caloric value of sawdust, wet basis, Btu/lb
$FF_{sd}$	Feed rate of sawdust to kiln, lbs/hr
PROD	Board feet per hour through the kiln, BF/hr
$MW_{hcho}$	Molecular weight of formaldehyde, g/g-mol

**SOURCE TEST CALCULATIONS**  
**USEPA Method 316 and 19 – Formaldehyde**

$M_d$	Dry molecular weight of stack gasses, lb/lb-mole = $0.44(\%CO_2) + 0.32(\%O_2) + 0.28(\%CO + N_2)$
$V_{w(std)}$	Volume of water vapor in the gas sample, dscf = $0.04707V_{ic}$
$P_s$	Absolute stack gas pressure, in. Hg = $P_{bar} + P_g$
$V_{m(std)}$	Volume of metered gas sample, dscf = $17.64V_m Y \frac{P_{bar} + \left(\frac{\Delta H}{13.6}\right)}{460 + T_m}$
$B_{ws}$	Water vapor in the gas stream, proportion by volume = $\frac{V_{w(std)}}{V_{m(std)} + V_{w(std)}}$
$M_s$	Wet molecular weight of stack gasses, lb/lb-mole = $M_d(1 - B_{ws}) + 18.0B_{ws}$
$A$	Area of stack, $ft^2 = \frac{D_s^2}{2} \times 3.1416$ or cross-section length x width
$A_n$	Area of nozzle, $ft^2 = \frac{D_n^2}{2} \times 3.1416$
$V_s$	Velocity in the stack, ft/sec = $85.49C_p \sqrt{\Delta P_{avg}} \sqrt{\frac{460 + T_s}{P_s M_s}}$
$V_{acfm}$	Velocity in the stack, acfm = $60 \times A \times V_s$
$Q_{std}$	Average stack gas dry volumetric flow rate from the temporary stack, dscf/hr = $3600(1 - B_{ws})V_s A \left[ \frac{528}{460 + T_s} \times \frac{P_s}{29.92} \right]$
$I$	Isokinetic ratio, % = $\frac{100(460 + T_s) \left( 0.002669V_{ic} + \frac{V_m Y}{460 + T_m} \times \left( P_{bar} + \frac{\Delta H}{13.6} \right) \right)}{60T_{min} V_s P_s A_n}$
$HI_{kiln}$	Heat input to kiln, MMBtu/hr = $\frac{FF_{sd} \times GCV_{sd(w)}}{1,000,000}$
$Q_{std(kiln)}$	Average gas dry volumetric flow rate from the kiln, dscf/hr = $\frac{HI_{kiln} \times F_d \times 20.9}{20.9 - \%O_2}$
$C_{hcho}$	Formaldehyde concentration, ppmvd = $\frac{M_{hcho} \times 0.02404}{V_{m(std)} \times 0.028317 \times MW_{hcho}}$
$E_{lbs/hr}$	Formaldehyde emission rate from kiln, lbs/hr = $\frac{C_{hcho} \times MW_{hcho} \times Q_{std(kiln)}}{385.1E06}$
$E_{lbs/MBF}$	Formaldehyde emission rate from kiln, lbs/MBF = $\frac{1000 \times E_{lbs/hr}}{PROD}$

**SOURCE TEST CALCULATIONS**  
**USEPA Method 10 – Carbon Monoxide**

**Definitions**

C	Average carbon monoxide concentration indicated by gas analyzer, ppmvd
C <sub>o</sub>	Average initial and final system calibration bias check responses for the zero carbon monoxide gas, ppmvd
C <sub>m</sub>	Average of initial and final system calibration bias check responses for the upscale carbon monoxide gas, ppmvd
C <sub>ma</sub>	Actual concentration of the upscale calibration gas, ppmvd
Q <sub>std(kiln)</sub>	Average gas dry volumetric flow rate from the kiln, dscf/hr

**Calculations**

C <sub>co</sub>	Carbon monoxide concentration, ppmvd = $(C - C_o) \left( \frac{C_{ma}}{C_m - C_o} \right)$
E <sub>co</sub>	Carbon monoxide emission rate from kiln, lbs/hr = $\frac{C_{co} \times 28 \times Q_{std(kiln)}}{385.1E06}$

**SOURCE TEST CALCULATIONS**  
**USEPA Method 3A – Oxygen and Carbon Dioxide**

**Definitions**

C	Average gas concentration indicated by gas analyzer, % dry
C <sub>0</sub>	Average initial and final system calibration bias check responses for the zero gas, %
C <sub>m</sub>	Average of initial and final system calibration bias check responses for the upscale calibration gas, %
C <sub>ma</sub>	Actual concentration of the upscale calibration gas, %

**Calculations**


C<sub>gas</sub>      Gas concentration, % dry =  $(C - C_0) \left( \frac{C_{ma}}{C_m - C_0} \right)$

**SOURCE TEST CALCULATIONS**  
**USEPA Method 19 – “F<sub>d</sub>” Calculations**


K	Conversion factor, unitless = 10 <sup>6</sup> Btu/MMBtu
%H <sub>sd</sub>	Concentration of hydrogen in sawdust from ultimate fuel analysis, percent by weight
%C <sub>sd</sub>	Concentration of carbon in sawdust from ultimate fuel analysis, percent by weight
%S <sub>sd</sub>	Concentration of sulfur in sawdust from ultimate fuel analysis, percent by weight
%N <sub>sd</sub>	Concentration of nitrogen in sawdust from an ultimate fuel analysis, percent by weight
%O <sub>sd</sub>	Concentration of oxygen in sawdust from ultimate fuel analysis, percent by weight
K <sub>hd</sub>	Constant, (dscf/lb)/% = (3.64 dscf/lb)/%
K <sub>c</sub>	Constant, (dscf/lb)/% = (1.53 dscf/lb)/%
K <sub>s</sub>	Constant, (dscf/lb)/% = (0.57 dscf/lb)/%
K <sub>n</sub>	Constant, (dscf/lb)/% = (0.14 dscf/lb)/%
K <sub>o</sub>	Constant, (dscf/lb)/% = (0.46 dscf/lb)/%
GCV <sub>sd(d)</sub>	Gross caloric value of sawdust from ultimate fuel analysis, dry basis, Btu/lb
GCV <sub>sd(w)</sub>	Gross caloric value of sawdust from ultimate fuel analysis, wet basis, Btu/lb
FF <sub>i</sub>	Fuel feed rate, units/hr
F <sub>d</sub>	Volume of combustion components per unit of heat content for sawdust, dscf/MMBtu = $\frac{K(K_{hd} \%H_{sd} + K_c \%C_{sd} + K_s \%S_{sd} + K_n \%N_{sd} - K_o \%O_{sd})}{GCV_{sd(d)}}$

### **3.4 Stack Schematics**

Traverse points were determined by Method 1 of 40 CFR Part 60, Appendix A - "Sample and Velocity Traverses for Stationary Sources." Method 1 implements the use of stack dimensions for the determination of the location of sample ports and traverse points. The diameter of the duct is taken into consideration in order to meet criteria concerning the location of test port openings. Traverse points are determined as a percentage of the stack diameter as measured from the inside wall of the stack. Method 1 provides guidelines for the calculation and location of each traverse point based on the stack diameter. Schematic drawings of the sample traverse points are detailed on the following pages.



BIBLER BROTHERS LUMBER COMPANY  
 RUSSELLVILLE, ARKANSAS  
 SN-13G No. 1 Dry Kiln and Wood Burner  
 Side View



<u>Sample Point</u>	<u>Location</u>
1, 5 and 9	3.0"
2, 6 and 10	6.0"
3, 7 and 11	9.0"
4, 8 and 12	12.0"

BIBLER BROTHERS LUMBER COMPANY  
 RUSSELLVILLE, ARKANSAS  
 SN-13G No. 1 Dry Kiln and Wood Burner  
 Sample Points

## Field and Laboratory Data

### **4.1**    *Field Data*

The following pages represent the field data for the source tested during this testing program.

# Environmental Services Company, Inc.

## STACK SAMPLING FIELD DATA

Plant Name: Baker Brothers Stack Name: SN-136  
 Operator: UPP/ JNW Run Number: 1 EPA Method: 316  
 Date: 10/26/10 Start Time: 1139 Stop Time: 1239  
 Stack Dia. (ft): 1.2500 + 0.83333 Bar. Pres. (in. Hg): 30.01 Static Pres. (in Hg): 0.01  
 Probe Tip Diameter (in): 0.388 0.41 Pitot Factor: 0.840 Meter Factor: SN 1226 → 1.004  
 Control Number: \_\_\_\_\_ K Factor: \_\_\_\_\_  
 Percent O<sub>2</sub>: \_\_\_\_\_ Percent CO<sub>2</sub>: \_\_\_\_\_ Percent CO+N<sub>2</sub>: \_\_\_\_\_  
 Pre-Leak Checks: Pitots: OK System: OK @ 17" Hg L 0.005  
 Post-Leak Checks: Pitots: OK System: OK @ 19" Hg L 0.005

Point	Sample Time	Dry Gas Meter Reading	ΔP Inches H <sub>2</sub> O	ΔH Inches H <sub>2</sub> O	Dry Gas Meter Temperature °F		L.VAC. In. Hg Gauge	Dryer Temp. °F	Probe Temp. °F	Oven Temp. °F	Stack Temp. °F
					Inlet	Outlet					
1	5/1139	863.8	0.03	0.47	69	68	3.0	60	249	248	142
2	5/1144	866.1	0.06	0.94	69	68	2.5	59	248	250	146
3	5/1149	867.9	0.03	0.47	70	69	2.5	56	246	245	143
4	5/1154	869.6	0.02	0.32	71	69	2.5	57	243	246	147
5	5/1159	871.9	0.04	0.74	72	65	3.5	52	249	246	142
6	5/1204	874.7	0.05	1.10	73	70	4.0	48	248	249	142
7	5/1209	877.3	0.04	0.90	74	70	3.5	47	246	249	142
8	5/1214	879.8	0.04	0.90	75	71	3.5	48	242	252	145
9	5/1219	882.5	0.05	1.00	76	71	3.5	48	245	250	144
10	5/1224	885.4	0.05	1.00	76	72	3.5	48	243	255	148
11	5/1229	888.6	0.04	1.00	77	72	4.0	49	241	250	148
12	5/1234	892.14	0.06	1.70	78	73	5.0	51	247	254	146
13											
14											
15											
16											
17											
18											
19											
20											
21											
22											
23											
24											
25											
		60	30.421	10.207	0.9200	78					

Environmental Services Company, Inc.

IMPINGER CATCH

Customer: Bibler Brothers

Sampling Location: 50-136 Sample Date: 10/26/10

Run Number: 1 Control Number: \_\_\_\_\_

Impinger Number	Solution Used	Amount of Solution (milliliters)	Weight (grams)
1	<u>Milli a</u>	<u>100</u>	Final <u>943.2</u> Initial <u>764.6</u> Weight gain <u>178.4</u>
2	<u>Milli a</u>	<u>100</u>	Final <u>754.5</u> Initial <u>785.5</u> Weight gain <u>(31.0)</u>
3	<u>Empty</u>	<u>0</u>	Final <u>660.1</u> Initial <u>655.2</u> Weight gain <u>4.9</u>
4	<u>Silica gel</u>	<u>200 g</u>	Final <u>915.5</u> Initial <u>915.8</u> Weight gain <u>2.7</u>

TOTAL WEIGHT GAIN OF IMPINGERS (GRAMS) 155.2

Date: 10/26/10

Signature: [Signature]

# Environmental Services Company, Inc.

## STACK SAMPLING FIELD DATA

Plant Name: Bibler Brothers Stack Name: SN-136  
 Operator: UPF/JNW Run Number: 2 EPA Method: 316  
 Date: 10/26/10 Start Time: 1250 Stop Time: 1356  
 Stack Dia. (ft): 1.2500 / 0.93333 Bar. Pres. (in. Hg): 30.01 Static Pres. (in Hg): 10.01  
 Probe Tip Diameter (in): 0.413 Pitot Factor: 0.890 Meter Factor: SN1226 → 1.004  
 Control Number: \_\_\_\_\_ K Factor: 21.3  
 Percent O<sub>2</sub>: \_\_\_\_\_ Percent CO<sub>2</sub>: \_\_\_\_\_ Percent CO+N<sub>2</sub>: \_\_\_\_\_  
 Pre-Leak Checks: Pitots: OK System: 6" @ 15" Hg @ 0.005"  
 Post-Leak Checks: Pitots: OK System: OK @ 17" Hg @ 0.005"

Point	Sample Time	Dry Gas Meter Reading	ΔP Inches H <sub>2</sub> O	ΔH Inches H <sub>2</sub> O	Dry Gas Meter Temperature °F		L.VAC In. Hg Gauge	Dryer Temp. °F	Probe Temp. °F	Oven Temp. °F	Stack Temp. °F
					Inlet	Outlet					
		892.30									
1	5/1250	895.4	0.05	1.20	75	73	3.0	48	251	253	134
2	5/1255	895.4	0.05	1.00	76	73	3.0	61	245	252	135
3	5/1300	900.7	0.05	1.00	74	74	3.0	62	277	253	134
4	5/1305	903.4	0.05	1.00	76	74	3.0	67	241	247	137
5	5/1310	906.1	0.05	1.00	77	74	3.0	62	244	258	135
6	5/1315	908.8	0.06	1.20	77	74	3.0	61	242	257	137
7	5/1320	911.7	0.07	1.40	77	74	3.0	55	246	249	137
8	5/1325	914.6	0.05	1.00	78	74	3.0	53	247	253	140
9	5/1330	917.4	0.05	1.00	78	74	3.0	53	245	253	135
10	5/1335	920.4	0.07	1.40	78	74	3.0	53	241	245	136
11	5/1340	923.4	0.06	1.20	79	75	3.0	52	245	253	133
12	5/1345	926.435	0.04	1.20	79	75	3.0	53	276	253	134
13											
14											
15											
16											
17											
18											
19											
20											
21											
22											
23											
24											
25											
	60	34.135	10.2358	1.1353		730					

Environmental Services Company, Inc.

IMPINGER CATCH

Customer: Bible Brothers

Sampling Location: SN-136 Sample Date: 10/26/10

Run Number: 2 Control Number: \_\_\_\_\_

Impinger Number	Solution Used	Amount of Solution (milliliters)	Weight (grams)
1	<u>Milli a</u>	<u>100</u>	Final <u>867.1</u> Initial <u>760.2</u> Weight gain <u>106.9</u>
2	<u>Milli a</u>	<u>100</u>	Final <u>770.5</u> Initial <u>749.9</u> Weight gain <u>20.6</u>
3	<u>Empty</u>	<u>0</u>	Final <u>658.4</u> Initial <u>653.8</u> Weight gain <u>4.6</u>
4	<u>Silica Gel</u>	<u>200g</u>	Final <u>884.9</u> Initial <u>882.5</u> Weight gain <u>2.4</u>

TOTAL WEIGHT GAIN OF IMPINGERS (GRAMS) 134.0g

Date: 10/26/10

Signature: [Signature]

# Environmental Services Company, Inc.

## STACK SAMPLING FIELD DATA

Plant Name: Biller Brothers Stack Name: 2A-136  
 Operator: WPF/JNW Run Number: 3 EPA Method: 316  
 Date: 10/26/10 Start Time: 1358 Stop Time: 1458  
 Stack Dia. (ft): 1.2500 / 0.83333 Bar. Pres. (in. Hg): 30.01 Static Pres. (in Hg): 40.01  
 Probe Tip Diameter (in): 0.413 Pitot Factor: 0.840 Meter Factor: SN1276 → 1.004  
 Control Number: \_\_\_\_\_ K Factor: \_\_\_\_\_  
 Percent O<sub>2</sub>: \_\_\_\_\_ Percent CO<sub>2</sub>: \_\_\_\_\_ Percent CO+N<sub>2</sub>: \_\_\_\_\_  
 Pre-Leak Checks: Pitots: OK System: OK @ 14" Hg @ 0.005  
 Post-Leak Checks: Pitots: OK System: OK @ 15" Hg @ 0.005

Point	Sample Time	Dry Gas Meter Reading	ΔP Inches H <sub>2</sub> O	ΔH Inches H <sub>2</sub> O	Dry Gas Meter Temperature °F		L.VAC In. Hg Gauge	Dryer Temp. °F	Probe Temp. °F	Oven Temp. °F	Stack Temp. °F
					Inlet	Outlet					
1	5/1358	930.3	0.06	1.60*	78	76	4.0	66	242	245	115
2	5/1403	934.1	0.07	1.70	78	76	2.0	62	238	245	131
3	5/1408	936.7	0.07	1.70	79	76	2.0	54	247	246	129
4	5/1413	939.4	0.05	1.20	80	76	2.0	51	245	241	123
5	5/1418	942.9	0.04	1.00	80	77	2.0	50	246	245	117
6	5/1423	946.5	0.05	1.20	81	77	2.5	47	242	255	120
7	5/1428	949.1	0.06	1.20	82	77	2.5	48	243	252	128
8	5/1433	951.5	0.08	0.80	82	78	2.5	50	242	253	124
9	5/1438	954.4	0.05	0.75	82	78	2.5	51	244	254	125
10	5/1443	957.3	0.06	1.10	82	78	2.5	50	245	253	125
11	5/1448	960.8	0.05	1.20	82	78	2.5	50	244	255	121
12	5/1453	964.058	0.06	1.60	83	79	3.0	50	244	253	117
13											
14											
15											
16											
17											
18											
19											
20											
21											
22											
23											
24											
25											
		40	37.258	10.2405	1.2458	79					

**Environmental Services Company, Inc.**

**ANALYZER CALIBRATION DATA**

Plant Name: BIOER BROTHERS Source Identification: SW-136

Reference Method: 10 Data for Sampling Runs: 1-3

Test Personnel: JW

Date: 10/20/10 Span: 225

	Cylinder Value	Analyzer Calibration Response	Absolute Difference	Difference (% of span)
Zero gas	0.00	10:35:01 0.11	0.11	0.05%)
Mid-range gas	120	10:38:09 119.3	0.70	0.31%)
High-range gas	225	10:52:41 227.4	1.40 <del>227.4</del>	0.70%)

Analyzer Calibration Error =  $\frac{\text{Analyzer Calibration Response} - \text{Cylinder Value}}{\text{Span}} \times 100 = \pm 2$  percent of span

**Environmental Services Company, Inc.**

**ANALYZER BIAS/DRIFT DATA**

Plant Name: BRYER BROTHERS Source Identification: SM-136

Reference Method: 10 Data for Sampling Runs: 1-3

Test Personnel: JW

Date: 10/26/10 Span: 225

Run #	Analyzer Calibration Response	Initial System Calibration Response	Initial System Bias (% of span)	Final System Calibration Response	Final System Bias (% of span)	Drift (% of span)
1	0.11	11:02:25 1.85	0.78%	12:41:38 1.85	0.78%	0.00%
	119.3	11:00:25 118.64	0.29%	12:45:39 117.42	0.27%	0.45%
2	0.11	12:41:38 1.85	0.78%	13:54:04 0.89	0.34%	0.44%
	119.3	12:45:39 117.42	0.73%	13:51:29 117.28	0.88%	0.15%
3	0.11	13:54:04 0.89	0.34%	15:00:46 0.09	0.01%	0.35%
	119.3	13:51:29 117.28	0.88%	15:02:12 119.3	0.00%	0.83%

$$\text{System Bias} = \frac{\text{System Cal. Response} - \text{Analyzer Cal. Response}}{\text{Span}} \times 100 = \pm 5 \text{ percent of span}$$

$$\text{Drift} = \frac{\text{Final System Cal. Response} - \text{Initial System Cal. Response}}{\text{Span}} \times 100 = \pm 3 \text{ percent of span}$$

**Environmental Services Company, Inc.**

**ANALYZER CALIBRATION DATA**

Plant Name: BIDLEN BROTHERS Source Identification: SN-136

Reference Method: 3A O<sub>2</sub> Data for Sampling Runs: 1-3

Test Personnel: JNW

Date: 10/24/12 Span: 18.8

	Cylinder Value	Analyzer Calibration Response	Absolute Difference	Difference (% of span)
Zero gas	0.2	10:38:05 0.03	0.23	0.1670
Mid-range gas	10.06	10:40:14 10.02	0.04	0.2100
High-range gas	18.8	10:35:01 18.77	0.03	0.1670

$$\text{Analyzer Calibration Error} = \frac{\text{Analyzer Calibration Response} - \text{Cylinder Value}}{\text{Span}} \times 100 = \pm 2 \text{ percent of span}$$

**Environmental Services Company, Inc.**

**ANALYZER BIAS/DRIFT DATA**

Plant Name: BIBLER BROTHERS Source Identification: SW-136

Reference Method: 3A02 Data for Sampling Runs: 1-3

Test Personnel: JW

Date: 10/26/10 Span: 15.8

Run #	Analyzer Calibration Response	Initial System Calibration Response	Initial System Bias (% of span)	Final System Calibration Response	Final System Bias (% of span)	Drift (% of span)
1	0.03	11:00:45 0.06	0.16%	12:45:39 0.09	0.32%	0.16%
		11:03:05 9.97		12:41:38 10.10		
2	0.03	12:45:39 0.09	0.32%	13:51:29 0.09	0.32%	0.00%
		12:41:38 10.10		13:54:04 9.98		
3	0.03	13:51:29 0.09	0.32%	15:02:12 0.08	0.27%	0.05%
		13:54:04 9.98		15:00:46 10.04		

$$\text{System Bias} = \frac{\text{System Cal. Response} - \text{Analyzer Cal. Response}}{\text{Span}} \times 100 = \pm 5 \text{ percent of span}$$

$$\text{Drift} = \frac{\text{Final System Cal. Response} - \text{Initial System Cal. Response}}{\text{Span}} \times 100 = \pm 3 \text{ percent of span}$$

**Environmental Services Company, Inc.**

**ANALYZER CALIBRATION DATA**

Plant Name: BIBLEA BROTHERS Source Identification: SN-136

Reference Method: 3A CO<sub>2</sub> Data for Sampling Runs: 1-3

Test Personnel: JWJ

Date: 10/24/12 Span: 10.2

	Cylinder Value	Analyzer Calibration Response	Absolute Difference	Difference (% of span)
Zero gas	0.00	10.38109 0.02	0.02	0.20%
Mid-range gas	5.17	10.4014 5.12	0.05	0.49%
High-range gas	10.2	10.3501 10.19	0.01	0.10%

Analyzer Calibration Error =  $\frac{\text{Analyzer Calibration Response} - \text{Cylinder Value}}{\text{Span}} \times 100 = \pm 2 \text{ percent of span}$

**Environmental Services Company, Inc.**

**ANALYZER BIAS/DRIFT DATA**

Plant Name: BIEBER BROTHERS Source Identification: SN-136

Reference Method: 3A CO2 Data for Sampling Runs: 1-3

Test Personnel: JW

Date: 10/26/10 Span: 50.2

Run #	Analyzer Calibration Response	Initial System Calibration Response	Initial System Bias (% of span)	Final System Calibration Response	Final System Bias (% of span)	Drift (% of span)
1	0.02	11:00:25 0.101	0.110%	12:45:35 0.11	0.88%	0.10%
	5.12	11:03:05 5.18	0.59%	12:41:38 5.20	0.78%	0.20%
2	0.02	12:45:35 0.11	0.88%	13:51:29 0.03	0.10%	0.78%
	5.12	12:41:38 5.20	0.78%	13:54:04 5.20	0.78%	0.00%
3	0.02	13:51:29 0.03	0.10%	15:03:12 0.03	0.10%	0.00%
	5.12	13:54:04 5.20	0.78%	15:00:46 5.15	0.29%	0.49%

$$\text{System Bias} = \frac{\text{System Cal. Response} - \text{Analyzer Cal. Response}}{\text{Span}} \times 100 = \pm 5 \text{ percent of span}$$

$$\text{Drift} = \frac{\text{Final System Cal. Response} - \text{Initial System Cal. Response}}{\text{Span}} \times 100 = \pm 3 \text{ percent of span}$$

Environmental Services Company, Inc.

IMPINGER CATCH

Customer: Bibler Brothers

Sampling Location: SD-136 Sample Date: 10/26/10

Run Number: 3 Control Number: \_\_\_\_\_

Impinger Number	Solution Used	Amount of Solution (milliliters)	Weight (grams)
1	<u>Milli Q</u>	<u>100</u>	Final <u>839.6</u> Initial <u>757.1</u> Weight gain <u>82.5</u>
2	<u>Milli Q</u>	<u>100</u>	Final <u>765.9</u> Initial <u>751.0</u> Weight gain <u>14.9</u>
3	<u>Empty</u>	<u>0</u>	Final <u>657.7</u> Initial <u>655.7</u> Weight gain <u>2.0</u>
4	<u>Silica Gel</u>	<u>200g</u>	Final <u>920.6</u> Initial <u>918.6</u> Weight gain <u>2.0</u>

TOTAL WEIGHT GAIN OF IMPINGERS (GRAMS) 101.4 g

Date: 10/26/10

Signature: Paul J. [Signature]

DASYLab - V 7.00.04  
 WORKSHEET : o2-co2-co  
 Recording Date : 10/26/2010, 10:35:01 AM  
 Block Length : 1  
 Delta : 1 sec.  
 Number of Channels : 3

Date	Time	CO [ppm]	O2 [ppm]	CO2 [ppm]
10/26/2010	10:35:01	0.11	18.77	10.19
10/26/2010	10:38:09	119.3	0.03	0.02
10/26/2010	10:40:14	1.9	10.02	5.12
10/26/2010	10:52:41	227.4	0	0
10/26/2010	11:00:25	118.64	0.06	0.01
10/26/2010	11:02:56	3.89	9.97	5.17
10/26/2010	11:03:05	1.89	9.97	5.18
10/26/2010	11:39:15	30.04	19.6	1.35
10/26/2010	11:40:15	42.18	19.01	1.93
10/26/2010	11:41:15	53.4	18.68	2.25
10/26/2010	11:42:15	60.09	18.37	2.51
10/26/2010	11:43:15	66.16	18.27	2.61
10/26/2010	11:44:15	67.36	18.24	2.62
10/26/2010	11:45:15	68.97	18.21	2.66
10/26/2010	11:46:15	68.76	18.14	2.72
10/26/2010	11:47:15	70.97	18.04	2.83
10/26/2010	11:48:15	74.05	17.91	2.97
10/26/2010	11:49:15	77	17.76	3.12
10/26/2010	11:50:15	79.42	17.68	3.21
10/26/2010	11:51:15	80.46	17.77	3.13
10/26/2010	11:52:15	72.61	17.99	2.89
10/26/2010	11:53:15	77.63	17.7	3.18
10/26/2010	11:54:15	79.43	17.91	2.99
10/26/2010	11:55:15	64.51	18.55	2.39
10/26/2010	11:56:15	54.61	18.8	2.15
10/26/2010	11:57:15	49.96	18.97	2
10/26/2010	11:58:15	43.92	19.14	1.83
10/26/2010	11:59:15	43.15	19.12	1.85
10/26/2010	12:00:15	45.18	18.99	1.97
10/26/2010	12:01:15	44.03	19.13	1.85
10/26/2010	12:02:15	42.41	19.17	1.8
10/26/2010	12:03:15	42.05	19.19	1.78
10/26/2010	12:04:15	43.78	19.12	1.85
10/26/2010	12:05:15	43.98	19.19	1.79
10/26/2010	12:06:15	42.51	19.19	1.79
10/26/2010	12:07:15	43.82	19.12	1.85
10/26/2010	12:08:15	44.75	19.12	1.85
10/26/2010	12:09:15	43.75	19.2	1.78
10/26/2010	12:10:15	42.12	19.13	1.83
10/26/2010	12:11:15	46.51	19.04	1.92
10/26/2010	12:12:15	47.51	18.99	1.96
10/26/2010	12:13:15	48.34	18.95	2
10/26/2010	12:14:15	47.91	18.93	2.02
10/26/2010	12:15:15	47.57	18.95	2.01
10/26/2010	12:16:15	47.51	18.92	2.04

10/26/2010	12:17:15	46.41	18.98	1.98
10/26/2010	12:18:15	46.14	19.03	1.94
10/26/2010	12:19:15	45.58	18.92	2.04
10/26/2010	12:20:15	48.71	18.9	2.06
10/26/2010	12:21:15	45.98	18.99	1.97
10/26/2010	12:22:15	44.42	19.05	1.92
10/26/2010	12:23:15	42.78	19.1	1.87
10/26/2010	12:24:15	38.95	19.33	1.65
10/26/2010	12:25:15	39.31	19.13	1.84
10/26/2010	12:26:15	40.65	19.24	1.73
10/26/2010	12:27:15	41.54	19.09	1.88
10/26/2010	12:28:15	44.35	19.06	1.9
10/26/2010	12:29:15	45.84	19.03	1.94
10/26/2010	12:30:15	43.63	19.19	1.78
10/26/2010	12:31:15	42.22	19.21	1.76
10/26/2010	12:32:15	43.67	19.12	1.85
10/26/2010	12:33:15	44.87	19.1	1.86
10/26/2010	12:34:15	44.45	19.21	1.76
10/26/2010	12:35:15	40.9	19.3	1.67
10/26/2010	12:36:15	41.65	19.16	1.79
10/26/2010	12:37:15	44.33	19.3	1.68
10/26/2010	12:38:15	38.01	19.31	1.66
10/26/2010	12:41:34	2.89	10.12	5.2
10/26/2010	12:41:38	1.89	10.1	5.2
10/26/2010	12:45:39	117.62	0.09	0.11
10/26/2010	12:49:55	39.04	19.3	1.6
10/26/2010	12:50:55	39.38	19.2	1.75
10/26/2010	12:51:55	38.88	19.29	1.68
10/26/2010	12:52:55	36.55	19.47	1.51
10/26/2010	12:53:55	32.22	19.47	1.5
10/26/2010	12:54:55	34.22	19.46	1.53
10/26/2010	12:55:55	34.04	19.46	1.52
10/26/2010	12:56:55	34.88	19.38	1.6
10/26/2010	12:57:55	31.22	19.64	1.32
10/26/2010	12:58:55	34.71	19.32	1.64
10/26/2010	12:59:55	38.54	19.24	1.73
10/26/2010	13:00:55	39.87	19.18	1.79
10/26/2010	13:01:55	40.71	19.03	1.92
10/26/2010	13:02:55	45.72	18.85	2.1
10/26/2010	13:03:55	44.38	19.03	1.94
10/26/2010	13:04:55	44.21	18.9	2.06
10/26/2010	13:05:55	44.71	18.94	2.02
10/26/2010	13:06:55	44.38	18.9	2.06
10/26/2010	13:07:55	41.87	19.03	1.94
10/26/2010	13:08:55	43.88	18.92	2.04
10/26/2010	13:09:55	44.05	18.89	2.07
10/26/2010	13:10:55	44.88	18.88	2.08
10/26/2010	13:11:55	42.88	19.02	1.95
10/26/2010	13:12:55	40.38	19.1	1.87
10/26/2010	13:13:55	41.05	19.06	1.92
10/26/2010	13:14:55	33.38	19.58	1.41
10/26/2010	13:15:55	35.65	19.25	1.73

10/26/2010	13:16:55	37.51	19.31	1.68
10/26/2010	13:17:55	34.9	19.36	1.62
10/26/2010	13:18:55	37.33	19.35	1.64
10/26/2010	13:19:55	31.33	19.58	1.4
10/26/2010	13:20:55	32.96	19.41	1.58
10/26/2010	13:21:55	32.19	19.51	1.47
10/26/2010	13:22:55	34.24	19.4	1.57
10/26/2010	13:23:55	37.82	19.17	1.8
10/26/2010	13:24:55	43.63	18.96	2
10/26/2010	13:25:55	46.82	19	1.97
10/26/2010	13:26:55	45.07	19.05	1.93
10/26/2010	13:27:55	40.84	19.24	1.74
10/26/2010	13:28:55	43.43	19.08	1.89
10/26/2010	13:29:55	40.95	19.32	1.67
10/26/2010	13:30:55	40.43	19.2	1.77
10/26/2010	13:31:55	38.77	19.37	1.62
10/26/2010	13:32:55	42.2	19.03	1.94
10/26/2010	13:33:55	40.56	19.34	1.65
10/26/2010	13:34:55	30.07	19.77	1.2
10/26/2010	13:35:55	30.68	19.49	1.5
10/26/2010	13:36:55	30.15	19.71	1.37
10/26/2010	13:37:55	30.96	19.5	1.63
10/26/2010	13:38:55	34.16	19.5	1.45
10/26/2010	13:39:55	27.74	19.86	1.07
10/26/2010	13:40:55	17.9	20.04	0.87
10/26/2010	13:41:55	36.21	19.24	1.68
10/26/2010	13:42:55	43.85	19.5	1.4
10/26/2010	13:43:55	39.41	19.35	1.51
10/26/2010	13:44:55	44.91	19.28	1.59
10/26/2010	13:45:55	44.95	19.34	1.54
10/26/2010	13:46:55	42.08	19.48	1.37
10/26/2010	13:47:55	34.34	19.74	1.1
10/26/2010	13:51:29	117.28	0.09	0.03
10/26/2010	13:54:04	0.89	9.98	5.2
10/26/2010	13:58:12	19.23	20.06	0.81
10/26/2010	13:59:12	21.39	19.86	1
10/26/2010	14:00:12	25.72	19.77	1.1
10/26/2010	14:01:12	25.89	19.78	1.08
10/26/2010	14:02:12	25.89	19.78	1.08
10/26/2010	14:03:12	25.89	19.8	1.05
10/26/2010	14:04:12	25.89	19.7	1.15
10/26/2010	14:05:12	25.89	19.8	1.05
10/26/2010	14:06:12	24.39	19.71	1.13
10/26/2010	14:07:12	27.56	19.63	1.23
10/26/2010	14:08:12	26.72	19.65	1.21
10/26/2010	14:09:12	25.71	19.71	1.15
10/26/2010	14:10:12	25.22	19.73	1.13
10/26/2010	14:11:12	22.06	19.85	0.99
10/26/2010	14:12:12	19.89	20.09	0.77
10/26/2010	14:13:12	14.57	20.14	0.71
10/26/2010	14:14:12	17.56	20.03	0.8
10/26/2010	14:15:12	18.4	20.17	0.73

10/26/2010	14:16:12	6.56	20.65	0.31
10/26/2010	14:17:12	8.22	20.38	0.51
10/26/2010	14:18:12	12.23	20.5	0.46
10/26/2010	14:19:12	6.05	20.46	0.46
10/26/2010	14:20:12	9.82	20.41	0.5
10/26/2010	14:21:12	14.55	19.99	0.88
10/26/2010	14:22:12	19.94	19.88	0.99
10/26/2010	14:23:12	23.41	19.73	1.13
10/26/2010	14:24:12	26.77	19.55	1.32
10/26/2010	14:25:12	26.64	19.69	1.18
10/26/2010	14:26:12	28.87	19.33	1.54
10/26/2010	14:27:12	33.4	19.28	1.6
10/26/2010	14:28:12	33.01	19.35	1.54
10/26/2010	14:29:12	30.89	19.42	1.46
10/26/2010	14:30:12	30.79	19.58	1.71
10/26/2010	14:31:12	28.42	19.55	1.68
10/26/2010	14:32:12	27.62	19.75	1.66
10/26/2010	14:33:12	22.03	19.66	1.71
10/26/2010	14:34:12	32.25	19.37	2.07
10/26/2010	14:35:12	34.78	19.2	1.96
10/26/2010	14:36:12	37.09	19.11	1.73
10/26/2010	14:37:12	37.53	19.42	1.43
10/26/2010	14:38:12	25.19	19.77	1.03
10/26/2010	14:39:12	27.97	19.54	1.25
10/26/2010	14:40:12	35.05	19.37	1.44
10/26/2010	14:41:12	30.12	19.65	1.16
10/26/2010	14:42:12	27.52	19.51	1.3
10/26/2010	14:43:12	31.04	19.49	1.31
10/26/2010	14:44:12	32.15	19.55	1.27
10/26/2010	14:45:12	29.94	19.52	1.28
10/26/2010	14:46:12	33.21	19.44	1.38
10/26/2010	14:47:12	26.59	19.82	0.99
10/26/2010	14:48:12	20.79	19.95	0.85
10/26/2010	14:49:12	29.48	19.62	1.2
10/26/2010	14:50:12	21.89	20	0.8
10/26/2010	14:51:12	14.79	20.44	0.43
10/26/2010	14:52:12	16.06	19.88	0.91
10/26/2010	14:53:12	33.88	19.44	1.38
10/26/2010	14:54:12	28.45	19.7	1.08
10/26/2010	14:55:12	33.91	19.38	1.44
10/26/2010	14:56:12	30.39	19.76	1.04
10/26/2010	14:57:12	26.09	19.66	1.13
10/26/2010	15:00:46	0.09	10.04	5.15
10/26/2010	15:03:12	119.3	0.08	0.03

#### **4.2    *Laboratory Data***

Attached is a copy of the laboratory report from the analysis of the samples from this testing program.

# Environmental Services Company, Inc.

13715 West Markham  
Little Rock, AR 72211

SN-13G  
Client # 1511

Analytical Report  
(1110-42)

*EPA Method 316*  
Formaldehyde



**Enthalpy Analytical, Inc.**

Phone: (919) 850 - 4392 / Fax: (919) 850 - 9012 / [www.enthalpy.com](http://www.enthalpy.com)  
2202 Ellis Road Durham, NC 27703 - 5518

I certify that to the best of my knowledge all analytical data presented in this report:

- Have been checked for completeness
- Are accurate, error-free, and legible
- Have been conducted in accordance with approved protocol, and that all deviations and analytical problems are summarized in the appropriate narrative(s)

This analytical report was prepared in Portable Document Format (.PDF) and contains ??? pages.



# Summary of Results



Company	ESC	Client #	1511
Analyst	KHB	Job #	1110-42
Parameters	EPA Method 316	PO #	Verbal
# Samples	3 Runs, 1 Blank	Report Date	11/10/10

Compound	Sample ID / Catch Weight (µg)		
	<b><i>SN-13G Run #1</i></b>	<b><i>SN-13G Run #2</i></b>	<b><i>SN-13G Run #3</i></b>
Formaldehyde	282	196	128
	<b><i>Water Blank</i></b>		
Formaldehyde	0.810 ND		

# Results



Company	ESC
Analyst	KHB
Parameters	EPA Method 316
# Samples	3 Runs, 1 Blank

Client #	1511
Job #	1110-42
PO #	Verbal
Report Date	11/10/10

MDL 0.0200 (µg/mL) Lower Curve Limit 0.271 (µg/mL)  
 LOQ 0.271 (µg/mL) Upper Curve Limit 3.25 (µg/mL)  
 Compound Formaldehyde

Sample ID	Lab ID	Absorbance	Analytical Concentration (µg/mL)	Dilution	Volume (mL)	Catch Weight (ug)	Qual
SN-13G Run #1	15	0.6251	1.3773	5	41.0	282	
SN-13G Run #2	16	0.4500	0.9916	5	39.5	196	
SN-13G Run #3	17	0.3007	0.6626	5	38.5	128	
Water Blank	19	0.0047	0.0200	1	40.5	0.810	ND
Method Blank	10	0.0020	0.0200	1	1.00	0.0200	ND
LD / SN-13G Run #1	20	0.6211	1.3687	5	41.0	281	
						% Difference	0.6%
AD / SN-13G Run #1	21	0.3132	0.6902	10	41.0	283	
						% Difference	0.2%
MS / SN-13G Run #1	20	1.2897	2.8419	1	2.50	7.10	
						spike amount (ug)	5.41
						native amount (ug)	1.69
						Spike recovery	100%
Spec34pg74 SS#1	8	0.6194	1.3648	1	1.00	1.36	
						Tag amount (ug)	1.31
						Spike recovery	104%
Spec34pg74 SS#2	9	0.6186	1.3631	1	1.00	1.36	
						Tag amount (ug)	1.31
						Spike recovery	104%

# Narrative Summary



## Enthalpy Analytical Narrative Summary

<b>Company</b>	ESC, Inc.
<b>Analyst</b>	KHB
<b>Parameters</b>	EPA Method 316
<b># Samples</b>	3 runs and 1 blank

<b>Client #</b>	1511
<b>Job #</b>	1110-42
<b>PO #</b>	Verbal
<b>Report Date</b>	November 9, 2010

<b>Custody</b>	<p>Heather Tarjeft received the samples on 11/8/10 after being relinquished by Environmental Services Company, Inc. The samples were received at 17.3°C in good condition. Prior to, during, and after analysis, the samples were kept under lock with access only to authorized personnel by Enthalpy Analytical, Inc.</p>
<b>Analysis</b>	<p>The samples were analyzed for formaldehyde using the analytical procedures in EPA Method 316, Sampling and Analysis for Formaldehyde Emissions from Stationary Sources in the Mineral Wool and Wool Fiberglass Industries (40 CFR Part 63, Appendix A).</p> <p>The sodium sulfite reagent was used within 24 hours of preparation. Formaldehyde standards were made by diluting a certified solution with DIUF-grade water. Samples and standards were analyzed following the procedures in Section 11.0. Any sample dilutions were performed on an aliquot of the original sample prior to the addition of pararosaniline reagent.</p> <p>The Hewlett Packard Model 8453A, Diode Array Spectrophotometer ("Gomez" S/N US53400446) was operated at 570 nm.</p>
<b>Calibration</b>	<p>The calibration curve is located in the Calibration Curve Spectra section of this report.</p>
<b>QC Notes</b>	<p>The following Quality Control Samples (9.0) were analyzed: field blank (9.2.1), method blank (9.2.3) and an alternate dilution (not required by the method). All samples met the method-specified quality control limits.</p> <p>All sample preparation and analytical holding times specified in the method were met.</p>
<b>Reporting Notes</b>	<p>The results presented in this report are representative of the samples as provided to the laboratory.</p> <p>Enthalpy Analytical, Inc. is accredited to perform this method for compliance purposes by the National Environmental Laboratory Accreditation Conference (NELAC) through the Louisiana Environmental Laboratory Accreditation Program (LELAP), certificate number 04010.</p>



# General Reporting Notes

The following are general reporting notes that are applicable to all Enthalpy Analytical, Inc. data reports, unless specifically noted otherwise.

- The acronym **MDL** represents the Minimum Detection Limit. Below this value the laboratory cannot determine the presence of the analyte of interest reliably.
- The acronym **LOQ** represents the Limit of Quantification. Below this value the laboratory cannot quantitate the analyte of interest within the criteria of the method.
- The acronym **ND** following a value indicates a non-detect or analytical result below the MDL.
- The letter **J** following a value indicates an analytical result between the MDL and the LOQ. A J flag indicates that the laboratory can positively identify the analyte of interest as present, but the value should be considered an estimate.
- The letter **E** following a value indicates an analytical result exceeding 100% of the highest calibration point. The associated value should be considered as an estimate.
- The acronym **DF** represents Dilution Factor. This number represents dilution of the sample during the preparation and/or analysis process. The analytical result taken from a laboratory instrument is multiplied by the DF to determine the final undiluted sample results.
- The addition of **MS** to the Sample ID represents a Matrix Spike. An aliquot of an actual sample is spiked with a known amount of analyte so that a percent recovery value can be determined. This shows what effect the sample matrix may have on the target analyte, i.e. whether or not anything in the sample matrix interferes with the analysis of the analyte(s).
- The addition of **MSD** to the Sample ID represents a Matrix Spike Duplicate. Prepared in the same manner as an MS, the use of duplicate matrix spikes allows further confirmation of laboratory quality by showing the consistency of results gained by performing the same steps multiple times.
- The addition of **LD** to the Sample ID represents a Laboratory Duplicate. The analyst prepares an additional aliquot of sample for testing and the results of the duplicate analysis are compared to the initial result. The result should have a difference value of within 10% of the initial result (if the results of the original analysis are greater than the LOQ).
- The addition of **AD** to the Sample ID represents an Alternate Dilution. The analyst prepares an additional aliquot at a different dilution factor (usually double the initial factor). This analysis helps confirm that no additional compound is present and coeluting or sharing absorbance with the analyte of interest, as they would have a different response/absorbance than the analyte of interest.
- The Sample ID **LCS** represents a Laboratory Control Sample. Clean matrix, similar to the client sample matrix, prepared and analyzed by the laboratory using the same reagents, spiking standards and procedures used for the client samples. The LCS is used to assess the control of the laboratory's analytical system. Whenever spikes are prepared for our client projects, two extra spikes are prepared. The extras (randomly chosen) are labeled with the associated project number and kept in-house at the appropriate temperature conditions. When the project samples are received for analysis, the LCSs are analyzed to confirm that the analyte could be recovered from the media, separate from the samples which were used on the project and which may have been affected by source matrix, sample collection and/or sample transport.



# General Reporting Notes

(continued)

- **Significant Figures:** Where the reported value is much greater than unity (1.00) in the units expressed, the number is rounded to a whole number of units, rather than to 3 significant figures. For example, a value of 10,456.45 ug catch is rounded to 10,456 ug. There are five significant digits displayed, but no confidence should be placed on more than two significant digits.
- **Manual Integration:** The data systems used for processing will flag manually integrated peaks with an “M”. There are several reasons a peak may be manually integrated. These reasons will be identified by the following two letter designations. The peak was *not integrated* by the software “**NI**”, the peak was *integrated incorrectly* by the software “**II**” or the *wrong peak* was integrated by the software “**WP**”. These codes will accompany the analyst’s manual integration stamp placed next to the compound name.



# Sample Custody





# Sample Spectra




\*\*\* Results Report \*\*\*

Method file (modified)  
NAIMA.M  
Number of Samples 8  
Operator KHB

Sample 1

Processed Sample Spectrum




Data Analysis Result

Analyte Name	Value	Std.Dev.	Unit
Formaldehyde	1.37730	0.01635	ug/mL

Sample 2

Processed Sample Spectrum




Data Analysis Result

Analyte Name	Value	Std.Dev.	Unit
Formaldehyde	0.99156	0.01595	ug/mL

Sample 3

Processed Sample Spectrum




Data Analysis Result

Analyte Name	Value	Std.Dev.	Unit
Formaldehyde	0.66255	0.01570	ug/mL

Sample 4

Processed Sample Spectrum




Data Analysis Result

Analyte Name	Value	Std.Dev.	Unit
Formaldehyde	0.01025	0.01550	ug/mL

Sample 5

Processed Sample Spectrum




Data Analysis Result

Analyte Name	Value	Std.Dev.	Unit
Formaldehyde	0.00440	0.01550	ug/mL

Sample 6

Processed Sample Spectrum




Data Analysis Result

Analyte Name	Value	Std.Dev.	Unit
Formaldehyde	1.36868	0.01634	ug/mL

Sample 7

Processed Sample Spectrum




Data Analysis Result

Analyte Name	Value	Std.Dev.	Unit
Formaldehyde	0.69016	0.01572	ug/mL

Sample 8

Processed Sample Spectrum



Data Analysis Result

Analyte Name	Value	Std.Dev.	Unit
Formaldehyde	2.84185	0.01887	ug/mL

\*\*\* End Results Report \*\*\*

## SCA Quantification Results

#	Sample Name	WL Result	Std.Dev.	Value(ug/mL)	Std.Dev.	95% PI
1	SN-13G Run #1*5 111	0.62505	1.0059E-4	1.37730	1.6354E-2	4.2040E-2
2	SN-13G Run #2*5 111	0.45000	7.7102E-5	0.99156	1.5948E-2	4.0997E-2
3	SN-13G Run #3*5 111	0.30068	7.7091E-5	0.66255	1.5702E-2	4.0363E-2
4	Water Blank 1110-42	4.6520E-3	6.3348E-5	1.0251E-2	1.5500E-2	3.9845E-2
5	Method Blank (#10)	1.9965E-3	5.4457E-5	4.3993E-3	1.5500E-2	3.9845E-2
6	LD/SN-13G Run #1*5	0.62114	1.2462E-4	1.36870	1.6344E-2	4.2013E-2
7	AD/SN-13G Run #1*10	0.31321	7.2346E-5	0.69016	1.5719E-2	4.0407E-2
8	MS/SN-13G Run #1 11	1.28970	6.0253E-4	2.84190	1.8870E-2	4.8506E-2

\*\*\* End Hardcopy window \*\*\*


# Calibration Curve Spectra



\*\*\* Calibration Report \*\*\*

Number of Standards 6

Standard Spectra



#	Standard	Path Length Unit	Date	Time
1	Spec34pg74 #1 (#	1.000 cm	11/8/10	17:26:29
2	Spec34pg74 #2 (#	1.000 cm	11/8/10	17:26:38
3	Spec34pg74 #3 (#	1.000 cm	11/8/10	17:26:48
4	Spec34pg74 #4 (#	1.000 cm	11/8/10	17:26:59
5	Spec34pg74 #5 (#	1.000 cm	11/8/10	17:27:13
6	Spec34pg74 #6 (#	1.000 cm	11/8/10	17:27:29

Data Analysis:

Spectral Processing:

Absorbance

Use Wavelength(s):


Single (nm): 570

Evaluation: SCA

Calibrated at: Date 11/9/2010 Time 10:41:49 AM  
 Operator: KHB

Weighting Method: Least squares  
 Calibration Curve:  $C = k_1 * A$

Analyte Name	Unit
Formaldehyde	ug/mL



Coefficients

k#	Value
1	2.20349


Used Wavelength Results (Absorbance (AU))

#	Value
1	0.00002
2	0.12313
3	0.24595
4	0.49839
5	0.96942
6	1.47885

Calibration Table of Formaldehyde (ug/mL)

#	Standard Name	Value	Fitted Val.	Error (%)
1	Spec34pg74 #1 (#	0.00000	0.00004	-100.0
2	Spec34pg74 #2 (#	0.27100	0.27132	-0.1
3	Spec34pg74 #3 (#	0.54100	0.54194	-0.2
4	Spec34pg74 #4 (#	1.08200	1.09820	-1.5
5	Spec34pg74 #5 (#	2.16400	2.13611	1.3
6	Spec34pg74 #6 (#	3.24600	3.25864	-0.4

Calibration Curve



SCA Summary

Analyte Name	Formaldehyde
Number of Standards	6
Calculation Method	LSQ
Calibration Curve	$C = k1 * A$
Coefficient k1	2.20350 ug/mL
Std.Dev. of k1	8.3440E-3 ug/mL
Std.Dev. of Calibration	1.5500E-2 ug/mL
Correl. Coeff. (R^2)	0.99993
Uncertainty	1.56 %


\*\*\* End Calibration Report \*\*\*

\*\*\* Results Report \*\*\*

Method file (modified)  
NAIMA.M  
Number of Samples 2  
Operator KHB

Sample 1

Processed Sample Spectrum




Data Analysis Result

Analyte Name	Value	Std.Dev.	Unit
Formaldehyde	1.36479	0.01634	ug/mL

Sample 2

Processed Sample Spectrum



Data Analysis Result

Analyte Name	Value	Std.Dev.	Unit
Formaldehyde	1.36309	0.01634	ug/mL

\*\*\* End Results Report \*\*\*

SCA Quantification Results

#	Sample Name	WL Result	Std.Dev.	Value(ug/mL)	Std.Dev.	95% PI
1	Spec34pg74 #SS1 (#8)	0.61938	1.6538E-4	1.36480	1.6339E-2	4.2001E-2
2	Spec34pg74 #SS2 (#9)	0.61861	1.1682E-4	1.36310	1.6337E-2	4.1996E-2


\*\*\* End Hardcopy window \*\*\*

\*\*\* Results Report \*\*\*

Method file (modified)  
NAIMA.M  
Number of Samples 2  
Operator KHB

Sample 1

Processed Sample Spectrum




Data Analysis Result

Analyte Name	Value	Std.Dev.	Unit
Formaldehyde	0.54691	0.01564	ug/mL

Sample 2

Processed Sample Spectrum



Data Analysis Result

Analyte Name	Value	Std.Dev.	Unit
Formaldehyde	0.54175	0.01564	ug/mL

\*\*\* End Results Report \*\*\*

SCA Quantification Results

#	Sample Name	WL Result	Std.Dev.	Value(ug/mL)	Std.Dev.	95% PI
1	Spec34pg74 #3A (#18)	0.24820	9.3312E-5	0.54691	1.5638E-2	4.0199E-2
2	Spec34pg74 #3B (#23)	0.24586	5.9996E-5	0.54175	1.5635E-2	4.0192E-2

\*\*\* End Hardcopy window \*\*\*

Automation Table: S:\UV2010Q4\NOV\AUTOMAT\1110-42E.A

Run Automation From Line: 1 To Line: 23

#	Srcce Sample Name	Action	Parameter
1	1 Lab Blank H2O	Measure	Blank
2	2 Spec34pg74 #1	Measure	Standard
3	3 Spec34pg74 #2	Measure	Standard
4	4 Spec34pg74 #3	Measure	Standard
5	5 Spec34pg74 #4	Measure	Standard
6	6 Spec34pg74 #5	Measure	Standard
7	7 Spec34pg74 #6	Measure	Standard
8	8 Spec34pg74 #SS1	Measure	Sample
9	9 Spec34pg74 #SS2	Measure	Sample
10	10 Method Blank	Measure	Sample
<del>11</del>	<del>11 KHB BS 1*2</del>	<del>Measure</del>	<del>Sample</del>
<del>12</del>	<del>12 KHB BS 2*2</del>	<del>Measure</del>	<del>Sample</del>
<del>13</del>	<del>13 KHB BS 3*2</del>	<del>Measure</del>	<del>Sample</del>
<del>14</del>	<del>14 KHB BS 4*2</del>	<del>Measure</del>	<del>Sample</del>
15	15 SN-13G Run #1*5	1 Measure	Sample
16	16 SN-13G Run #2*5	1 Measure	Sample
17	17 SN-13G Run #3*5	1 Measure	Sample
18	18 Spec34pg74 #3A	Measure	Sample
19	19 Water Blank 1110-	Measure	Sample
20	20 LD/SN-13G Run #1*5	Measure	Sample
21	21 AD/SN-13G Run #1*1	Measure	Sample
22	22 MS/SN-13G Run #1	Measure	Sample
23	23 Spec34pg74 #3B	Measure	Sample

\*\*\* End Automation Table \*\*\*

**This Is The Last Page  
Of This Report.**



Lab No. 2010-02790-001  
Date Rec'd. 11/01/2010  
Date Sampled 10/26/2010 to 10/26/2010  
Sampled By Client

Page: 1 of 1  
Date: 11/05/2010 10:40:05

Sample ID: 20100279001

BIBLER BROS LUMBER CO

P.O.#

PO BOX 490  
RUSSELLVILLE, AR 72811  
ATTN: MATT HAGENLOCKER

Remark: SOUTHERN YELLOW PINE SAWDUST - DRY KILNS STACK TEST

		As		Dry		Weight %	
		Received		Basis		Received	Dry
<b>PROXIMATE ANALYSIS</b>							
% Moisture	D3302	53.58	*****	*****		53.58	*****
% Ash	D3174	0.23		0.49		24.09	51.89
% Volatile	D3175	*****	*****	*****		2.93	6.32
% Fixed Carbon	D3172	*****	*****	*****		0.07	0.15
BTU	D5865	4138		8914		*****	*****
MAF-BTU	D3180		8958			< 0.01	< 0.01
% Total Sulfur	D4239B	< 0.01		< 0.01		0.23	0.49
<b>SULFUR FORMS</b>							
% Pyritic	D2492	*****	*****	*****		19.11	41.18
% Sulfate	D2492	*****	*****	*****		(Chlorine D6721 Dry Basis ug/g *****)	
% Organic	D2492	*****	*****	*****		MINERAL ANALYSIS D6349 % Ignited Basis *****	
% Total Sulfur	D4239B	< 0.01		< 0.01		Phos. Pentoxide, P2O5 *****	
<b>WATER SOLUBLE</b>							
% Na2O	ASME1974	*****	*****	*****		Silica, SiO2 *****	
% K2O	ASME1974	*****	*****	*****		Ferric Oxide, Fe2O3 *****	
% Chlorine	ASME1974	*****	*****	*****		Alumina, Al2O3 *****	
Alkalies as Na2O	ASME1974	*****	*****	*****		Titania, TiO2 *****	
<b>FUSION TEMP. OF ASH D1857</b>							
I.D.	Reducing	*****	*****	Oxidizing		Lime, CaO *****	
H=W	*****	*****	*****	*****		Magnesia, MgO *****	
H=1/2W	*****	*****	*****	*****		Sulfur Trioxide, SO3 *****	
Fluid	*****	*****	*****	*****		Potassium Oxide, K2O *****	
<b>GRINDABILITY INDEX D409</b>							
GRIND INDEX UNCONDITIONED	***** @ *****	% Moist.		*****		Sodium Oxide, Na2O *****	
FREE SWELLING INDEX D720	*****	% Moist.		*****		Barium Oxide, BaO *****	
Apparent Specific Gravity of Coal ModIC7113	*****			*****		Strontium Oxide, SrO *****	
% Equilibrium Moisture D1412	*****			*****		Manganese Dioxide, MnO2 *****	
<b>ULTIMATE ANALYSIS</b>							
% Moisture	D3302	53.58	*****	*****		Undetermined *****	
% Carbon	D5373	24.09		51.89		Type of Ash ASME1974 *****	
% Hydrogen	D5373	2.93		6.32		Silica Value ASME1974 *****	
% Nitrogen	D5373	0.07		0.15		T250 Deg B&W *****	
% Chlorine	D6721	*****	*****	*****		Base/Acid Ratio ASME1974 *****	
% Sulfur	D4239B	< 0.01		< 0.01		lb Ash/mm BTU 0.55	
% Ash	D3174	0.23		0.49		lb SO2/mm BTU < 0.01	
% Oxygen (Diff.)	D3176	19.11		41.18		Fouling Index ASME1974 *****	
<b>MINERAL ANALYSIS D6349</b>							
% Ignited Basis *****							
Phos. Pentoxide, P2O5 *****							
Silica, SiO2 *****							
Ferric Oxide, Fe2O3 *****							
Alumina, Al2O3 *****							
Titania, TiO2 *****							
Lime, CaO *****							
Magnesia, MgO *****							
Sulfur Trioxide, SO3 *****							
Potassium Oxide, K2O *****							
Sodium Oxide, Na2O *****							
Barium Oxide, BaO *****							
Strontium Oxide, SrO *****							
Manganese Dioxide, MnO2 *****							
Undetermined *****							
Type of Ash ASME1974 *****							
Silica Value ASME1974 *****							
T250 Deg B&W *****							
Base/Acid Ratio ASME1974 *****							
lb Ash/mm BTU 0.55							
lb SO2/mm BTU < 0.01							
Fouling Index ASME1974 *****							
Slagging Index ASME1974 *****							
(Mercury D6722 Dry Basis ug/g *****)							

Respectfully Submitted,



## Quality Assurance

### **5.1 Probe Nozzles**

The probe nozzles were measured with a micrometer and inspected prior to use as outlined in 40 CFR Part 60, Method 5, Section 10.1.

**Environmental Services Co., Inc.**  
**Nozzle Calibration**  
**Per 40 CFR Part 60, Appendix A, Method 5, Section 10.1**

Customer: Bibler Brothers Lumber Company  
 Project No: 1008520006  
 Source No: SN-13G

Visual Inspection

1.	Is nozzle nicked?	<u>N</u>	(Y/N)
2.	Is nozzle dented?	<u>N</u>	(Y/N)
3.	Is nozzle corroded?	<u>N</u>	(Y/N)

Measurement Calibration

1.	Measurement #1	<u>0.413</u>	in.
2.	Measurement #2	<u>0.413</u>	in.
3.	Measurement #3	<u>0.413</u>	in.
4.	Difference between low and high measurement	<u>0.000</u>	in.
5.	Average diameter	<u>0.413</u>	in.


In order to meet the specifications of Section 10.1, the nozzle must not be nicked, dented or corroded and the difference between the low and high measurements must be  $\leq 0.004$  inches.

## **5.2 Pitot Tubes**

The pitot tubes used during this test program were fabricated according to the specifications described and illustrated in 40 CFR Part 60, Appendix A, Method 2. The pitot tubes were recalibrated before field use as prescribed in Method 2, Section 6.1.1.

**Environmental Services Co., Inc.**  
**Pitot Calibration**  
**Per 40 CFR Part 60, Appendix A, Method 2, Section 6.1.1**

Customer: Bibler Brothers Lumber Company  
 Project No: 1008520006  
 Source No: SN-13G  
 Pitot ID: 3-G1



Measurements

$D_t$	<u>0.375</u>	in.
$P_A$	<u>0.500</u>	in.
$P_B$	<u>0.500</u>	in.

Calculations

$1.05D_t$	<u>0.3938</u>	in.
$1.50D_t$	<u>0.5625</u>	in.

Calibration:

In order to meet the specifications of Section 6.1.1, the following criteria must be met:

1.  $D_t$  must be between 3/16 and 3/8 inch
2.  $P_A = P_B$
3.  $1.05 D_t < P < 1.50 D_t$

Do pitots meet calibration specifications? Y (Y/N)

### **5.3     *Metering Systems***

The test meters were calibrated according to Method 5, Section 10.3. A copy of the pre-test and post-test calibration for the test meter used in this test program is attached.

Environmental Services Co., Inc.  
EPA Method 5  
ESC Meter Box Calibration  
Post-Test Orifice Method  
English Meter Box Units, English K' Factor

Model #: C-5000 Date: ----- 09/17/10  
Serial #: 1226 Barometric Pressure: -----> 30.06 in. Hg  
Theoretical Critical Vacuum: ----> 14.18 in. Hg

IMPORTANT For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above.  
IMPORTANT The Critical Orifice Coefficient, K', must be entered in English units, (ft<sup>3</sup>)(°R)<sup>0.05</sup>/((in. Hg)(min)).

----- DRY GAS METER READINGS -----										-CRIT. ORIFICE READINGS-		AMBIENT TEMPERATURE		
dH (in H2O)	Time (min)	Volume Initial (ft <sup>3</sup> )	Volume Final (ft <sup>3</sup> )	Volume Total (ft <sup>3</sup> )	Initial Temps (°F)		Final Temps. (°F)		Orifice Serial # (number)	K' Orifice Coeff. (above)	Actual Vacuum (in. Hg)	Initial (°F)	Final (°F)	Average (°F)
0.64	10.00	669.000	673.308	4.308	75.0	75.0	75.0	75.0	CT48	0.3297	23.0	74.6	73.6	74.1
1.20	10.00	673.700	679.446	5.746	75.0	75.0	76.0	75.0	CT55	0.4379	21.0	74.6	75.2	74.9
1.90	10.00	679.800	687.152	7.352	76.0	75.0	77.0	76.0	CT63	0.5613	19.5	75.6	73.6	75.4
3.60	5.25	710.900	716.196	5.296	82.0	77.0	82.0	77.0	CT73	0.7738	18.0	75.8	76.0	75.9
5.20	11.50	696.400	710.565	14.165	80.0	76.0	74.0	69.0	CT81	0.9652	16.0	76.2	70.4	73.4

----- DRY GAS METER -----			----- ORIFICE -----			DRY GAS METER		----- ORIFICE -----		
VOLUME CORRECTED	VOLUME CORRECTED	VOLUME CORRECTED	VOLUME CORRECTED	VOLUME NOMINAL	CALIBRATION FACTOR "Y"		CALIBRATION FACTOR dH@			
Vm(std) (ft <sup>3</sup> )	Vm(std) (liters)	Vcr(std) (ft <sup>3</sup> )	Vcr(std) (liters)	Vcr (ft <sup>3</sup> )	Value (number)	Variation (number)	Value (in H2O)	Value (mm H2O)	Variation (in H2O)	
4.277	121.1	4.288	121.4	4.319	1.003	-0.001	1.941	49.30	-0.024	
5.709	161.7	5.692	161.2	5.741	0.997	-0.007	2.066	52.48	0.101	
7.307	206.9	7.292	206.5	7.363	0.998	-0.006	1.991	50.57	0.026	
5.251	148.7	5.275	149.4	5.331	1.005	0.001	1.981	50.33	0.016	
14.225	402.8	14.447	409.1	14.533	1.016	0.012	1.846	46.90	-0.119	
Average Y -----					1.004					
					Average dH@ ----->		1.965	49.91		

Note: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is ±0.02.  
For Orifice Calibration Factor dH@, the orifice differential pressure in inches of H2O that equates to 0.75 cfm of air at 68°F and 29.92" Hg, acceptable tolerance of individual values from the average is ±0.2.

Environmental Services Co., Inc.  
 EPA Method 5  
 ESC Meter Box Calibration  
 Post-Test Orifice Method  
 English Meter Box Units, English K' Factor

Model #: C-5000  
 Serial #: 1226  
 Date: -----> 10/15/10  
 Barometric Pressure: -----> 30.10 in. Hg  
 Theoretical Critical Vacuum: -----> 14.20 in. Hg

IMPORTANT For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above.  
 IMPORTANT The Critical Orifice Coefficient, K', must be entered in English units,  $(\text{ft}^3 \cdot (\text{°R})^{0.05} / (\text{in. Hg} \cdot (\text{min})))$ .

----- DRY GAS METER READINGS ----- -CRIT. ORIFICE READINGS- AMBIENT TEMPERATURE

dH (in H2O)	Time (min)	Volume			Initial Temps		Final Temps.		Orifice Serial #	K' Orifice Coeff.	Actual Vacuum (in. Hg)	Ambient Temperature		
		Initial (ft <sup>3</sup> )	Volume Final (ft <sup>3</sup> )	Volume Total (ft <sup>3</sup> )	Inlet (°F)	Outlet (°F)	Inlet (°F)	Outlet (°F)				Initial (°F)	Final (°F)	Average (°F)
1.20	9.50	833.100	838.591	5.491	86.0	85.0	87.0	85.0	CT55	0.4379	20.5	79.6	79.4	79.5
2.10	8.00	839.000	844.893	5.893	87.0	85.0	88.0	85.0	CT63	0.5613	18.5	79.4	80.0	79.7
3.70	5.50	845.100	850.678	5.578	88.0	85.0	89.0	86.0	CT73	0.7738	16.5	79.8	79.4	79.6

----- DRY GAS METER ----- ORIFICE ----- DRY GAS METER ----- ORIFICE -----

VOLUME CORRECTED Vm(std) (ft <sup>3</sup> )	VOLUME CORRECTED Vm(std) (liters)	VOLUME CORRECTED Vcr(std) (ft <sup>3</sup> )	VOLUME CORRECTED Vcr(std) (liters)	VOLUME NOMINAL Ver (ft <sup>3</sup> )	CALIBRATION FACTOR "Y"		CALIBRATION FACTOR dH@		
					Value (number)	Variation (number)	Value (in H2O)	Value (mm H2O)	Variation (in H2O)
5.358	151.736	5.391	152.673	5.478	1.006	-0.003	2.043	51.89	-0.036
5.757	163.052	5.818	164.766	5.914	1.011	0.002	2.177	55.29	0.098
5.463	154.724	5.515	156.176	5.604	1.009	0.001	2.016	51.20	-0.063

Average Y -----> 1.009  
 Average dH@ -----> 2.078 52.79

Note: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is ±0.02.  
 For Orifice Calibration Factor dH@, the orifice differential pressure in inches of H2O that equates to 0.75 cfm of air at 68°F and 29.92" Hg, acceptable tolerance of individual values from the average is ±0.2.

Environmental Services Co., Inc.  
 EPA Method 5  
 ESC Meter Box Calibration  
 Post-Test Orifice Method  
 English Meter Box Units, English K' Factor

Model #: C-5000  
 Serial #: 1226

Date: ----- 10/26/10  
 Barometric Pressure: -----> 30.01 in. Hg  
 Theoretical Critical Vacuum: -----> 14.16 in. Hg

IMPORTANT For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above.  
 IMPORTANT The Critical Orifice Coefficient, K', must be entered in English units,  $(\text{ft}^3 \cdot (\text{°R})^{0.05}) / ((\text{in. Hg}) \cdot (\text{min}))$ .

----- DRY GAS METER READINGS ----- -CRIT. ORIFICE READINGS- AMBIENT TEMPERATURE

dH (in H2O)	Time (min)	Volume			Initial Temps		Final Temps.		Orifice Serial #	K' Orifice Coeff.	Actual Vacuum (in. Hg)	Ambient Temperature		
		Initial (ft <sup>3</sup> )	Volume Final (ft <sup>3</sup> )	Volume Total (ft <sup>3</sup> )	Inlet (°F)	Outlet (°F)	Inlet (°F)	Outlet (°F)				Initial (°F)	Final (°F)	Average (°F)
1.20	9.25	964.500	969.792	5.292	74.0	74.0	75.0	74.0	CT55	0.4379	20.5	72.4	72.8	72.6
2.10	7.25	970.000	975.271	5.271	75.0	74.0	75.0	75.0	CT63	0.5613	17.5	72.8	73.4	73.1
3.80	5.25	975.500	980.715	5.215	75.0	74.0	77.0	74.0	CT73	0.7738	16.5	73.2	73.8	73.5

----- DRY GAS METER ----- ORIFICE ----- DRY GAS METER ----- ORIFICE -----

VOLUME CORRECTED Vm(std) (ft <sup>3</sup> )	VOLUME CORRECTED Vm(std) (liters)	VOLUME CORRECTED Vcr(std) (ft <sup>3</sup> )	VOLUME CORRECTED Vcr(std) (liters)	VOLUME NOMINAL Ver (ft <sup>3</sup> )	CALIBRATION FACTOR "Y"		CALIBRATION FACTOR dH@		
					Value (number)	Variation (number)	Value (in H2O)	Value (mm H2O)	Variation (in H2O)
5.259	148.939	5.267	149.168	5.299	1.002	-0.006	2.064	52.44	-0.056
5.245	148.535	5.289	149.792	5.326	1.008	0.001	2.199	55.85	0.079
5.208	147.497	5.278	149.479	5.319	1.013	0.006	2.097	53.27	-0.023

Average Y -----> 1.008  
 Average dH@ -----> 2.120 53.85

Note: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is ±0.02.  
 For Orifice Calibration Factor dH@, the orifice differential pressure in inches of H2O that equates to 0.75 cfm of air at 68°F and 29.92" Hg, acceptable tolerance of individual values from the average is ±0.2.

#### **5.4    *Temperature Gauges***

All thermocouples were calibrated against a reference thermocouple that was certified against a National Bureau of Standards (NSB) traceable mercury-in-glass thermometer as outlined in Approved Alternative Method ALT-011.

**METHOD 5 THERMOCOUPLE CALIBRATION FORM**  
**APPROVED ALTERNATIVE METHOD ALT-011**  
**THERMOCOUPLE CALIBRATION FORM**

Type of Thermocouple	Standard	
Type K	Fluke-52 SN 5820128	
Identification	Job ID	
Console 1226, Probe 3-G1, #4 Adapter ESC002	1008520006	
<b>METER INLET</b>		
Standard Temperature °F	Test Thermocouple Temperature °F	Temperature Difference*
68.4	69	0.88%
<b>METER OUTLET</b>		
Standard Temperature °F	Test Thermocouple Temperature °F	Temperature Difference*
67.0	68	1.49%
<b>STACK TEMPERATURE</b>		
Standard Temperature °F	Test Thermocouple Temperature °F	Temperature Difference*
144.8	143	1.24%
<b>DRYER IMPINGER</b>		
Standard Temperature °F	Test Thermocouple Temperature °F	Temperature Difference*
58.4	59	1.03%
<b>PROBE TEMPERATURE</b>		
Standard Temperature °F	Test Thermocouple Temperature °F	Temperature Difference*
249.4	248	0.56%
<b>OVEN TEMPERATURE</b>		
Standard Temperature °F	Test Thermocouple Temperature °F	Temperature Difference*
248.2	250	0.73%

$$\text{Temperature Difference} = \frac{|\text{Standard Temperature} - \text{Test Thermocouple Temperature}|}{\text{Standard Temperature}} \times 100 = \leq 2.0\%$$

**FLUKE** ®

Everett Service Center

1420 75th St. SW  
Everett, Washington 98203  
USA**Calibration Certificate**

NQA ISO 9001:2000 (10100/2)

<b>Description:</b>	K/J THERMOMETER	<b>Certificate Number:</b>	762716-5820128:1279179569
<b>Manufacturer:</b>	FLUKE	<b>Date of Calibration:</b>	15 July 2010
<b>Model:</b>	52	<b>Date of Certificate:</b>	15 July 2010
<b>Serial Number:</b>	5820128	<b>Recommended Due Date:</b>	15 July 2011
<b>Customer Name:</b>	ENVIRONMENTAL SERVICES COMPANY INC	<b>Procedure Name:</b>	FLUKE 52: (1 YEAR) CAL VER
<b>City, State:</b>	LITTLE ROCK, AR	<b>Procedure Revision:</b>	1.4
<b>Customer Item ID:</b>	5820128	<b>Data Type:</b>	FOUND-LEFT
<b>PO Number:</b>	WOOSLEY CCS	<b>Temperature:</b>	22.30 °Celsius
<b>RMA Number:</b>	4515729	<b>Relative Humidity:</b>	37 %
<b>Result Summary:</b>	PASS		
<b>Received Date:</b>			

In the attached measurement measurement results, deviation may be expressed with units, Measured Value (MV) - Nominal Value (NV) or as a proportion of the nominal value ((MV-NV)/NV), expressed without units with a scalar multiplier such as % (0.01), or as a ratio of the units (mA/A,  $\mu$ V/V, etc.) Descriptions such as  $\mu$ A/A,  $\mu$ V/V, and others, where used to annotate results or column headings are the preferred replacements for what was historically labeled as "ppm" or parts-per-million and described the results in that column, unless otherwise noted by units symbols.

The Data type that could be found in this certificate must be interpreted as:

- As-Found - Calibration data collected before the unit is adjusted and/or repaired.
- As-Left - Calibration data collected after the unit is adjusted and/or repaired.
- Found-Left - Calibration data collected without any adjustment and/or repair performed.

Unless otherwise stated the TUR (Test Uncertainty Ratio) of this calibration is 4:1 or greater.

This Calibration conforms to ANSI/NCSL Z540.1-1994(R2002)

Results are reviewed to establish where any measurement results exceeded the manufacturer's specifications. Measured values greater than the Manufacturer's specification (Spec) are indicated by "!".

This certificate applies only to the item identified and shall not be reproduced other than in full, without the specific written approval by Fluke Corporation. The user is obliged to have the object recalibrated at appropriate intervals. Calibration certificates without signature are not valid.

**Comments:**Long Le  
Metrology TechnicianDennis Destefan  
Lead Metrologist

**Traceability Information**

For each parameter listed below the calibration was conducted using an unbroken chain of standards to:

**DC Voltage**

The Voltage Reference standard group, traceable to the Fluke Primary Standards Laboratory, which is traceable to the U.S. representation of the volt, through the internationally accepted value of the Josephson constant  $K_J=483597.9$  GHz/V and a 10 Volt Josephson Array Voltage Standard.

**Frequency and Period**

The GPS-Rubidium Disciplined oscillator frequency standard, traceable to the United States Naval Observatory (USNO), which is traceable to the National Institute of Standards and Technology.

**AC Voltage, Resistance, DC Current, AC Current, Capacitance, Inductance, Phase**

The Fluke Primary Standards Laboratory, which is traceable to the National Institute of Standards and Technology.

**AC Voltage Flatness**

The Fluke Primary Standards Laboratory, or Agilent Technologies Standards Laboratory which are traceable to the National Institute of Standards and Technology.

**Humidity**

The Vaisala Measurement Standards Laboratory Primary Salt calibration bath, with traceability based on the physical phenomena in which the equilibrium relative humidity values associated with certain saturated salt solutions are known.

**Rise Time**

The Tektronix GmbH Calibration Laboratory which is traceable to the Physikalisch-Technische Bundesanstalt.

**Radiation Temperature**

The National Institute of Standards and Technology, the Physikalisch-Technische Bundesanstalt, or Hart Scientific.

**Contact Temperature**

The Fluke Primary Standards Laboratory, Hart Scientific, which are traceable to the National Institute of Standards and Technology.

**Gas Flow**

The DHI Calibration Laboratory, which is traceable to the National Institute of Standards and Technology.

**Pressure**

The DHI Calibration Laboratory, which is traceable to the Laboratoire National D'Essais, Physikalisch-Technische Bundesanstalt and National Institute of Standards and Technology, or traceable to the Mensor or Ashcroft Calibration Laboratories, which are traceable to the National Institute of Standards and Technology.

**Standards Used**

Asset #	Instrument Model	Cal Date	Cal Due
10054	FLUKE 5500A CALIBRATOR	02 November 2009	02 November 2010

**Calibration Results**

Function/Range	Nominal Value	Measured Value	TUR	Manufacturer's Specifications	
				Lower Limit	Upper Limit

The UUT Offset Adjustment has been adjusted prior to this procedure.

**DISPLAY TEST**

Result of Operator Evaluation PASS

**MEASUREMENT TEST**

INPUT 1 (K-TYPE) PASS

Was UUT Zero reading 0.0 +/- 0.4U?

-182.0 °C	-182.00	-182.3		-182.9	-181.1
-----------	---------	--------	--	--------	--------

The preceding test uses a guardbanding technique



Certificate Number:  
762716-5820128:1279179569

Calibration Date:  
15-Jul-10

### Calibration Results

Function/Range	Nominal Value	Measured Value	TUR	Manufacturer's Specifications	
				Lower Limit	Upper Limit
to maintain the same Consumer Risk as a 4:1 TUR.					
-89.0 °C	-89.00	-89.0		-89.8	-88.2
530.0 °C	530.00	530.6		528.8	531.2
1355.0 °C	1355.00	1356.6		1352.9	1357.1
-295.6 °F	-295.60	-296.0		-297.2	-294.0

The preceding test uses a guardbanding technique to maintain the same Consumer Risk as a 4:1 TUR.

-128.2 °F	-128.20	-128.0		-129.6	-126.8
986.0 °F	986.00	987.2		983.7	988.3
2471.0 °F	2471.00	2474.0		2467.2	2474.8

**INPUT 2 (K-TYPE)**

Was UUT Zero reading 0.0 +/- 0.4U? PASS

-182.0 °C	-182.00	-182.4		-182.9	-181.1
-----------	---------	--------	--	--------	--------

The preceding test uses a guardbanding technique to maintain the same Consumer Risk as a 4:1 TUR.

-89.0 °C	-89.00	-89.1		-89.8	-88.2
530.0 °C	530.00	530.3		528.8	531.2
1355.0 °C	1355.00	1356.4		1352.9	1357.1
-295.6 °F	-295.60	-296.6		-297.2	-294.0

The preceding test uses a guardbanding technique to maintain the same Consumer Risk as a 4:1 TUR.

-128.2 °F	-128.20	-128.2		-129.6	-126.8
986.0 °F	986.00	986.8		983.7	988.3
2471.0 °F	2471.00	2473.4		2467.2	2474.8

**INPUT 1 (J-TYPE)**

Was UUT Zero reading 0.0 +/- 0.4U? PASS

-197.0 °C	-197.00	-197.4		-198.0	-196.0
258.0 °C	258.00	258.3		256.9	259.1
705.0 °C	705.00	705.5		703.5	706.5
-322.6 °F	-322.60	-323.4		-324.3	-320.9
496.4 °F	496.40	496.8		494.5	498.3
1301.0 °F	1301.00	1302.2		1298.3	1303.7

**INPUT 2 (J-TYPE)**

89

Project No. 1008520006



Certificate Number:  
762716-5820128:1279179569

Calibration Date:  
15-Jul-10


### Calibration Results

Function/Range	Nominal Value	Measured Value	TUR	Manufacturer's Specifications	
				Lower Limit	Upper Limit
Was UUT Zero reading 0.0 +/- 0.4U?		PASS			
-197.0 °C	-197.00	-197.0		-198.0	-196.0
258.0 °C	258.00	258.4		256.9	259.1
705.0 °C	705.00	705.7		703.5	706.5
-322.6 °F	-322.60	-323.2		-324.3	-320.9
496.4 °F	496.40	497.0		494.5	498.3
1301.0 °F	1301.00	1302.4		1298.3	1303.7

End of Report

### **5.5 Calibration Gasses**

All calibration standards are guaranteed and certified by the manufacturer to be prepared in accordance to regulations set forth by the United States Environmental Protection Agency concerning the production of calibration standards. A copy of the manufacturer's certificate for each cylinder used in this testing program is attached.



# LIQUID TECHNOLOGY CORPORATION

"INDUSTRY LEADER IN SPECIALTY GASES"

## Certificate of Analysis - EPA PROTOCOL GAS -

<u>Customer</u>	<u>Environmental Services Company, Inc. (Little Rock, AR)</u>
<u>Date</u>	<u>July 14, 2010</u>
<u>Delivery Receipt</u>	<u>DR-29982</u>
<u>Gas Standard</u>	<u>10.0% CO2, 19.0% Oxygen/Nitrogen</u>
<u>Final Analysis Date</u>	<u>July 08, 2010</u>
<u>Expiration Date</u>	<u>July 08, 2013</u>

**DO NOT USE BELOW 150 psig**

<u>Cylinder Data</u>			
Cylinder Serial Number:	<u>CC-166364</u>	Cylinder Outlet:	<u>CGA 590</u>
Cylinder Volume:	<u>140 Cubic Feet</u>	Cylinder Pressure:	<u>2000 psig, 70°F</u>
Expiration Date:	<u>July 08, 2013</u>		

Analytical Data  
EPA Protocol, Section No. 2.2, Procedure G-1

**Replicate Concentrations**  
**Carbon Dioxide: 10.2% +/- 0.10%**  
**Oxygen: 18.8% +/- 0.18%**  
**Nitrogen: Balance**

<u>Reference Standard(s):</u>		
GMIS/SRM:	GMIS	GMIS/GMIS
Cylinder Number:	CC-165377	CC-231332/CC-85458
Concentration:	10.05% CO2/Nitrogen	10.10% Oxygen/20.97% O2/Nitrogen
Expiration Date:	04/06/11	03/04/11 - 04/15/11

Certification Instrumentation

Component:	Carbon Dioxide	Oxygen
Make/Model:	Agilent 7890A	Servomex 244a
Serial Number:	CN10736166	1847
Principal of Measurement:	GC-TCD	Paramagnetic
Last Calibration:	June 09, 2010	June 28, 2010

Analytical uncertainty and NIST Traceability are in compliance with EPA-600/R-97/121.

Certified by:

  
Adam Strickland

# Liquid Technology Corporation

Industry Leader in Specialty Gases, Equipment and Service

## Certificate of Analysis

### - EPA PROTOCOL GAS -

Customer Environmental Services Company (Little Rock, AR)  
Date July 21, 2009  
Delivery Receipt DR-25418  
Gas Standard 5.00% CO<sub>2</sub>, 10.00% Oxygen/Nitrogen-EPA PROTOCOL  
Final Analysis Date July 20, 2009  
Expiration Date July 20, 2012

Component Carbon Dioxide, Oxygen  
Balance Gas Nitrogen

Analytical Data:  
EPA Protocol, Section No. 2.2, Procedure G-1

**DO NOT USE BELOW 150 psig**

#### Reported Concentrations

**Carbon Dioxide: 5.17% +/- 0.05%**

**Oxygen: 10.06% +/- 0.10%**

**Nitrogen: Balance**

#### Reference Standards:

SRM/GMIS:	GMIS	GMIS
Cylinder Number:	CC-159026	CC-231332
Concentration:	5.14% CO <sub>2</sub> /Nitrogen	10.1% Oxygen/Nitrogen
Expiration Date:	March 31, 2011	March 04, 2011

#### Certification Instrumentation

Component:	Carbon Dioxide	Oxygen
Make/Model:	Agilent 7890A	Servomex 244a
Serial Number:	CN10736166	1847
Principal of Measurement:	GC-TCD	Paramagnetic
Last Calibration:	July 07, 2009	July 01, 2009

#### Cylinder Data

Cylinder Serial Number:	CC-231376	Cylinder Outlet:	CGA 590
Cylinder Volume:	140 Cubic Feet	Cylinder Pressure:	2000 psig, 70°F


Analytical Uncertainty and NIST Traceability are in compliance with EPA-600/R-97/121.

Certified by:



Mike Duncan

**Unmatched Excellence**



Air Liquide America  
Specialty Gases LLC



# RATA CLASS

Dual-Analyzed Calibration Standard

1290 COMBERMERE STREET, TROY, MI 48083

Phone: 248-589-2950

Fax: 248-589-2134

## CERTIFICATE OF ACCURACY: EPA Protocol Gas

### Assay Laboratory

AIR LIQUIDE AMERICA SPECIALTY GASES LLC  
1290 COMBERMERE STREET  
TROY, MI 48083

P.O. No.: 57768-71-65000

Project No.: 05-81734-001

### Customer

CLEAN AIR ENGINEERING  
DON ALLEN  
500 W. WOOD STREET  
PALATINE IL 60067

### ANALYTICAL INFORMATION

This certification was performed according to EPA Traceability Protocol For Assay & Certification of Gaseous Calibration Standards; Procedure G-1; September, 1997.

Cylinder Number: ALM000250 Certification Date: 09Nov2009 Exp. Date: 08Nov2012  
Cylinder Pressure\*\*\*: 2015 PSIG

COMPONENT	CERTIFIED CONCENTRATION (Moles)	ANALYTICAL ACCURACY**	TRACEABILITY
CARBON MONOXIDE	120 PPM	+/- 1%	Direct NIST and VSL
NITROGEN	BALANCE		

\*\*\* Do not use when cylinder pressure is below 150 psig.

\*\* Analytical accuracy is based on the requirements of EPA Protocol Procedure G1, September 1997.

### REFERENCE STANDARD

TYPE/SRM NO.	EXPIRATION DATE	CYLINDER NUMBER	CONCENTRATION	COMPONENT
NTRM 2636	02Oct2011	KAL003802	240.8 PPM	CARBON MONOXIDE

### INSTRUMENTATION

INSTRUMENT/MODEL/SERIAL#	DATE LAST CALIBRATED	ANALYTICAL PRINCIPLE
FTIR/0928621	05Nov2009	FTIR

### ANALYZER READINGS

(Z=Zero Gas R=Reference Gas T=Test Gas r=Correlation Coefficient)

First Triad Analysis

Second Triad Analysis

Calibration Curve

#### CARBON MONOXIDE


Date: 02Nov2009	Response Unit: PPM		
Z1 = -0.02028	R1 = 101.0930	T1 = 120.7415	
R2 = 101.1020	Z2 = 0.14906	T2 = 120.8168	
Z3 = 0.24118	T3 = 120.8474	R3 = 101.3177	
Avg. Concentration:	120.6	PPM	

Date: 09Nov2009	Response Unit: PPM		
Z1 = 0.01587	R1 = 240.3707	T1 = 119.9290	
R2 = 241.0337	Z2 = 0.27852	T2 = 120.5082	
Z3 = 0.57619	T3 = 120.5388	R3 = 241.1454	
Avg. Concentration:	120.1	PPM	

Concentration = A + Bx + Cx <sup>2</sup> + Dx <sup>3</sup> + Ex <sup>4</sup>	
r = 9.99995E-1	
Constants:	A = 0.00000E+0
B = 9.86984E-1	C = 6.38000E-4
D = 1.00000E-6	E = 0.00000E+0

APPROVED BY:

JEFF CROTEAU



# LIQUID TECHNOLOGY CORPORATION

"INDUSTRY LEADER IN SPECIALTY GASES"

## Certificate of Analysis **- EPA PROTOCOL GAS -**

<u>Customer</u>	<u>Environmental Services Company (Little Rock, AR)</u>
<u>Date</u>	<u>October 28, 2010</u>
<u>Delivery Receipt</u>	<u>DR-31087</u>
<u>Gas Standard</u>	<u>45-55 ppm Nitric Oxide, 200-250 ppm Carbon Monoxide/Nitrogen</u>
<u>Final Analysis Date</u>	<u>October 25, 2010</u>
<u>Expiration Date</u>	<u>October 25, 2012</u>

**DO NOT USE BELOW 150 psig**

Analytical Data:

EPA Protocol, Section No. 2.2, Procedure G-1.

**Reported Concentrations:**

**Nitric Oxide: 48.4 ppm +/- 0.48 ppm**  
**Carbon Monoxide: 229 ppm +/- 2.2 ppm**  
**Nitrogen: Balance**  
**Total NOx: 48.8 ppm**

\*\* Total NOx for Reference Use Only \*\*

Reference Standards

SRM/GMIS	GMIS	GMIS/GMIS
Cylinder Number:	CC-159111	CC-185093/CC-251549
Concentration:	48.86 ppm NO	100.48 ppm CO/267.38 ppm CO
Expiration Date:	09/20/12	01/28/12 - 11/01/11

Certification Instrumentation

Component:	Nitric Oxide	Carbon Monoxide
Make/Model:	Horiba - CLA 510	Horiba - VIA 510
Serial Number:	43331870031	UUBKWXYZV
Principal of Measurement:	Chemiluminescence	NDIR
Last Calibration:	October 04, 2010	October 01, 2010

Cylinder Data

Cylinder Number:	EB-0027125	Cylinder Volume:	140 Cubic Feet
Cylinder Outlet:	CGA 660	Cylinder Pressure:	2000 psig, 70°F
Expiration Date:	October 25, 2012		

Analytical Uncertainty and NIST Traceability are in compliance with EPA-600/R-97/121.

Certified by:

Adam Strickland

"UNMATCHED EXCELLENCE"