

Received
RECEIVED
AUG 28 2023
ORCAA



Platypus Marine, Inc
Thomas Feik
518 Marine Dr.
Port Angeles, Wa, 98363

Aug. 23, 2023

To Whom it may concern,

Platypus Marine, Inc (PMI) would like to modify permit 19ADM1360. PMI installed a dry filter open face booth dust collector. During the inspection it was brought up that the dust collector needs to be permitted. PMI received the notice of violation # 4460.

Attached to the Notice of Construction:

1. 3-stage filtration aerospace rev 02282019
2. Platypus BTH AMU 4-12-23
3. Stamped calculations
4. Stamped drawings
5. Design drawings
6. MSDS Green Diamond abrasive
7. Fiberglass spreadsheet
8. Paint Spreadsheet
9. Welding spreadsheet

If Olympic Regional Clean Air Agency needs any other information, concerns or questions please respond to Thomas Feik's phone number or email.

Sincerely,

Thomas Feik
Safety Manager
360-417-0709
tomf@platypusmarine.com



About Platypus Marine, Inc.

Government, Military, & Commercial Projects

Platypus Marine is one of the Pacific Northwest's largest indoor/outdoor, full-service shipyards specializing in marine refit, repair, and new construction. With a long-standing proven record of excellence, we have provided services to numerous vessels for the U.S. Navy, U.S. Coast Guard, U.S. Army, and U.S. Army Corps. We also provide service to commercial and charter vessels, tugboats, and passenger vessels.

Conveniently located off the Strait of Juan de Fuca, our ten-acre facility in Port Angeles, Washington offers 25-foot deep-water, heavy lift haul-out capability.

With over 70,000 square feet of enclosed space, our facility is comprised of multiple buildings that include dedicated spaces for our paint shop, metal fabrication shop, fiberglass shop, mechanic shop, carpentry shop, and electrical shop.

Platypus Marine's professional, multi-talented tradespeople excel in working with all types of vessels. In addition to our own tradespeople, Platypus Marine utilizes approved contractors that are skilled in specialty trades.

Experienced with fiberglass, steel, aluminum and wood, Platypus Marine provides skilled service and repair of propulsion, mechanical, electrical and auxiliary systems. Our experienced and dedicated management team maintains project timelines while ensuring quality and controlling project costs.

Painting & Blasting

- SSPC Certifications
 - NAVSEA Basic Paint Inspector (NBPI)
 - SSPC C12 (paint) and C7 (blasting)
- NACE Level 2 Certified Coating Inspectors
- NACE Level 3 available upon request
- 30 Years Yacht Painting in Awlgrip & Alexseal

Welding

- Follows NAVSEA Welding Standard
 - S9074-AQ-GIB-010-248
- ASME, Code 9 Certified
- Welding Systems & Operations Certified:
 - GMAW, GTAW, & FCAW
- AWS Certified
- Follows ABS Welding Procedures

Travelift Capacities

- 330-ton, 34' beam
- 500-ton, 34' beam
- 26-ton boom truck

Commander Building

- 200'L x 120'W x 62.5' height clearance
 - Concrete floor with radiant heat
- Space for multiple concurrent projects

North Building

- 160'L x 60'W
- Heated metal fabrication shop
- Multi-use work areas

RUBB Building

- 150'L x 75' W
- Enclosed space with concrete floor
- Multi-use work areas

OLYMPIC REGION CLEAN AIR AGENCY

2940 Limited Lane NW - Olympia, Washington 98502 - 360-539-7610 – Fax 360-491-6308

FORM 1- NOTICE OF CONSTRUCTION TO CONSTRUCT - INSTALL - ESTABLISH OR MODIFY AN AIR CONTAMINANT SOURCE

Form 1 Instructions:

1. Please complete all the fields below. **This NOC application is considered incomplete until signed.**
2. If the application contains any confidential business information, please complete a Request of Confidentiality of Records (www.orcaa.org).
3. Duty to Correction Application: An applicant has the duty to supplement or correct an application. Any applicant who fails to submit any relevant facts or who has submitted incorrect information in a permit application must, upon becoming aware of such failure or incorrect submittal, promptly submit supplementary factors or corrected information.

Business Name: Platypus Marine Inc.	For ORCAA use only
Mailing Address: 518 Marine Drive Port Angeles, WA 98363	File No: 791 County No: 9 Source No: 63 Application No: 23NOC1612
Physical Address of Project or New Source: 102 Cedar St., Port Angeles, WA 98363	Date Received: <div style="text-align: center; color: red; font-weight: bold; font-size: 1.2em;"> Received AUG 28 2023 ORCAA </div>
Billing Address: 518 Marine Drive Port Angeles, WA 98363	
Project or Equipment to be installed/established: 3-stage filtration, Global Finishing Solutions, tech data sheet attached.	
Anticipated startup date: ___ / ___ / ___ Is facility currently registered with ORCAA? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>	
This project must meet the requirements of the State Environmental Policy Act (SEPA) before ORCAA can issue final approval. Indicate the SEPA compliance option: <input type="checkbox"/> SEPA was satisfied by _____ (government agency) on ___ / ___ / ___ (date) - Include a copy of the SEPA determination <input type="checkbox"/> SEPA threshold determination by _____ (government agency) is pending - Include a copy of the environmental checklist <input checked="" type="checkbox"/> ORCAA is the only government agency requiring a permit - Include ORCAA Environmental Checklist <input type="checkbox"/> This project is exempt from SEPA per _____ (WAC citation).	
Name of Owner of Business: Judson Linnabary	Agency Use Only
Title: Owner	
Email: Judson@platypusmarine.com	Phone: (206)979-1646
Authorized Representative for Application (if different than owner): Christopher Feffer	
Title: President	
Email: Chris@platypusmarine.com	Phone: (860)227-8721
I hereby certify that the information contained in this application is, to the best of my knowledge, complete and correct.	
Signature of Owner or Authorized Representative: (sign in Blue Ink)	
	Date: 8-24-23
IMPORTANT: Do not send via email or other electronic means. ORCAA must receive Original, hardcopy, signed application and payment prior to processing application.	

OLYMPIC REGION CLEAN AIR AGENCY

2940 Limited Lane NW - Olympia, Washington 98502 - 360-539-7610 – Fax 360-491-6308

FORM 1D- Contact Information

Business Name Platypus Marine, Inc	FOR ORCAA USE
Physical Site Address (Street address, city, state, zip) 518 Marine Dr. Port Angeles, Wa., 98363	FILE # 791
	CTY # 9
	SRC # 63
Previous Business Name (if applicable) N/A	Date Received 8/28/2023

Contact Information

Inspection Contact	
Name Jacob Tweter	Title Facilities Project Manager
Phone 360-417-0709	Email jacob@platypusmarine.com
Billing Contact	
Name Tara Parrish	Title Purchasing Manager
Phone 360-417-0709	Email purchasing@platypusmarine.com
Emission Inventory Contact	
Name Thomas G. Feik	Title Yard and Safety Manager
Phone 360-417-0709	Email tomf@platypusmarine.com
Complaint Contact	
Name Thomas G. Feik	Title Yard and Safety Manager
Phone 360-417-0709	Email tomf@platypusmarine.com
Permit Contact	
Name Jacob Tweter	Title Facilities Project Manager
Phone 360-417-0709	Email jacob@platypusmarine.com

The **inspection contact** is the on-site person responsible for the everyday operation of the site and is available for inspections.

The **billing contact** is the person invoices are sent.

The **emission inventory contact** is the person requests for emissions information and material use information are sent.

The **complaint contact** is the person who receives and responds to complaints received on-site and who is contacted regarding complaints ORCAA receives.

The **permit contact** is the person responsible for filling out permit applications and receiving approval from ORCAA.



OLYMPIC REGION CLEAN AIR AGENCY

2940 Limited Lane NW - Olympia, Washington 98502

Telephone: (360)-539-7610 – Fax: (360)-491-6308

www.orcaa.org

FORM 8

Fill out all the applicable equipment information requested below and submit the appropriate fees.

SPRAY COATING (Autobody) SURFACE COATING (Aviation, Wood, Boat, Other)

Shop Information

Business Name: Platypus Marine, Inc 518 Marine Dr. Port Angeles, Wa, 98363	Contact Person: Tom Feik
	Phone Number: 360-417-0709
	Email: tomf@platypusmarine.com
Operating Schedule: 14 hrs/day, 6 days/wk, 52 wks/yr	Indicate days when operating: <input type="checkbox"/> M <input checked="" type="checkbox"/> T <input checked="" type="checkbox"/> W <input checked="" type="checkbox"/> Thu <input checked="" type="checkbox"/> F <input checked="" type="checkbox"/> Sat <input type="checkbox"/> Sun

Process Information

Flow:	<input checked="" type="checkbox"/> Cross front flow <input type="checkbox"/> Full downdraft <input type="checkbox"/> Side downdraft <input type="checkbox"/> Combination <input checked="" type="checkbox"/> Cross reverse flow <input type="checkbox"/> Semi-downdraft <input type="checkbox"/> Updraft <input type="checkbox"/> Other (explain in attachment)		
Exhaust:	<input type="checkbox"/> Side Wall <input type="checkbox"/> Pit/Trench Design <input checked="" type="checkbox"/> Ceiling <input type="checkbox"/> Rear Wall <input type="checkbox"/> Front/Doors		
Intake Type:	<input checked="" type="checkbox"/> Natural <input type="checkbox"/> Forced (air make-up unit)		
Enclosure Type:	<input type="checkbox"/> Fully enclosed <input type="checkbox"/> Compact/modular <input type="checkbox"/> Open table/bench <input checked="" type="checkbox"/> Closed top open front (CTOF) <input checked="" type="checkbox"/> Curtain/tent/drape <input type="checkbox"/> Other (explain in attachment) <input type="checkbox"/> Tunnel		
Width (feet):	31'2"	Length (feet):	16'2"
Height (feet):	16'2"		
Manufacturer:	Finishing Consultants		
Model Number:	DFOCG-300812-NSB-SP-F3		
Serial Number:	UNK		
Pressure Gauge:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	Filter Plenum:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Intended Applicator Usage (see next section):	<input checked="" type="checkbox"/> Applicator #1 <input checked="" type="checkbox"/> Applicator #3 <input type="checkbox"/> Applicator #5 <input checked="" type="checkbox"/> Applicator #2 <input checked="" type="checkbox"/> Applicator #4		
Air Pollution Control Methods:	<input type="checkbox"/> Water Wash <input checked="" type="checkbox"/> Low VOC coatings <input type="checkbox"/> Cartridge unit (Form 12) <input type="checkbox"/> Scrubber <input type="checkbox"/> Cyclone (Form 13) <input type="checkbox"/> Enclosed spray gun cleaner <input type="checkbox"/> Oxidizer (Form 35) <input type="checkbox"/> Baghouse (Form 12)		
Heater/Curing Information (if applicable)			
Heater Placement:	<input checked="" type="checkbox"/> Part of spray booth unit <input type="checkbox"/> Separate curing enclosure (Form 11)		
Curing/Heating Type :	<input checked="" type="checkbox"/> Hot air dryer <input type="checkbox"/> Infrared dryer <input type="checkbox"/> Other (explain in attachment) <input type="checkbox"/> Ultraviolet <input type="checkbox"/> Boiler		
Fuel/Heat Type :	<input type="checkbox"/> Natural gas <input type="checkbox"/> Electric <input checked="" type="checkbox"/> Other (explain in attachment) <input type="checkbox"/> Propane (LP) Gas <input checked="" type="checkbox"/> Diesel		
Maximum Heating Rate (MMBtu/hr):	95040		
Maximum Air Flow Rate (acfm):	2376000		

RETURN TO ORCAA

Coating Operation Information

Type:	<input checked="" type="checkbox"/> Existing Stationary Source	<input type="checkbox"/> Temporary Source	<input type="checkbox"/> New Stationary Source
NAICS Code(s):	336611		

Coating Equipment Information

	Applicator #1	Applicator #2	Applicator #3	Applicator #4	Applicator #5	
Coating Type**:	<input checked="" type="checkbox"/> Brush/Roller <input type="checkbox"/> Web <input type="checkbox"/> Wet spray <input type="checkbox"/> Deposition <input type="checkbox"/> Powder <input type="checkbox"/> Plating	<input type="checkbox"/> Brush/Roller <input type="checkbox"/> Web <input checked="" type="checkbox"/> Wet spray <input type="checkbox"/> Deposition <input type="checkbox"/> Powder <input type="checkbox"/> Plating	<input type="checkbox"/> Brush/Roller <input type="checkbox"/> Web <input checked="" type="checkbox"/> Wet spray <input type="checkbox"/> Deposition <input type="checkbox"/> Powder <input type="checkbox"/> Plating	<input type="checkbox"/> Brush/Roller <input type="checkbox"/> Web <input checked="" type="checkbox"/> Wet spray <input type="checkbox"/> Deposition <input type="checkbox"/> Powder <input type="checkbox"/> Plating	<input type="checkbox"/> Brush/Roller <input type="checkbox"/> Web <input checked="" type="checkbox"/> Wet spray <input type="checkbox"/> Deposition <input type="checkbox"/> Powder <input type="checkbox"/> Plating	<input type="checkbox"/> Brush/Roller <input type="checkbox"/> Web <input type="checkbox"/> Wet spray <input type="checkbox"/> Deposition <input type="checkbox"/> Powder <input type="checkbox"/> Plating
Manufacturer:	various	various	various	various		
Model:	various	various	various	various		
Quantity:	various	various	various	various		
Technology Type:	<input type="checkbox"/> HVLP <input type="checkbox"/> Electrostatic <input type="checkbox"/> Air-assisted airless <input type="checkbox"/> Airless <input type="checkbox"/> Air spray <input type="checkbox"/> Rotary cup <input type="checkbox"/> Airbrush <input type="checkbox"/> Other (explain in attachment)	<input type="checkbox"/> HVLP <input type="checkbox"/> Electrostatic <input type="checkbox"/> Air-assisted airless <input checked="" type="checkbox"/> Airless <input type="checkbox"/> Air spray <input type="checkbox"/> Rotary cup <input type="checkbox"/> Airbrush <input type="checkbox"/> Other (explain in attachment)	<input type="checkbox"/> HVLP <input type="checkbox"/> Electrostatic <input type="checkbox"/> Air-assisted airless <input type="checkbox"/> Airless <input checked="" type="checkbox"/> Air spray <input type="checkbox"/> Rotary cup <input type="checkbox"/> Airbrush <input type="checkbox"/> Other (explain in attachment)	<input checked="" type="checkbox"/> HVLP <input type="checkbox"/> Electrostatic <input type="checkbox"/> Air-assisted airless <input type="checkbox"/> Airless <input type="checkbox"/> Air spray <input type="checkbox"/> Rotary cup <input type="checkbox"/> Airbrush <input type="checkbox"/> Other (explain in attachment)	<input type="checkbox"/> HVLP <input type="checkbox"/> Electrostatic <input type="checkbox"/> Air-assisted airless <input type="checkbox"/> Airless <input type="checkbox"/> Air spray <input type="checkbox"/> Rotary cup <input type="checkbox"/> Airbrush <input type="checkbox"/> Other (explain in attachment)	
Automation/Control:	<input checked="" type="checkbox"/> Manual <input type="checkbox"/> Automatic	<input type="checkbox"/> Manual <input checked="" type="checkbox"/> Automatic	<input type="checkbox"/> Manual <input checked="" type="checkbox"/> Automatic	<input type="checkbox"/> Manual <input checked="" type="checkbox"/> Automatic	<input type="checkbox"/> Manual <input type="checkbox"/> Automatic	
Air Supply Pressure (psi):	0		45	45		
Fluid Output Pressure (psi):	0	Variable	Variable	Variable		
Mounting:	<input checked="" type="checkbox"/> Handheld Gun <input type="checkbox"/> Machine/Reciprocator	<input checked="" type="checkbox"/> Handheld Gun <input type="checkbox"/> Machine/Reciprocator	<input checked="" type="checkbox"/> Handheld Gun <input type="checkbox"/> Machine/Reciprocator	<input checked="" type="checkbox"/> Handheld Gun <input type="checkbox"/> Machine/Reciprocator	<input type="checkbox"/> Handheld Gun <input type="checkbox"/> Machine/Reciprocator	

**Only provide further information for applicators that are not roller/brush

Dry Filter Information

	Pre-Filter	Exhaust Filter
Manufacturer:	Standard 3 stage wave media, poly panel, 2-pocket bag	
Model:		
Media Type:	Roll media	
Overall Arrest Efficiency (%):		
Filtered Area (squared feet):		

RETURN TO ORCAA

Heavy Metal Information

Application of coatings containing compounds of chromium (Cr), lead (Pb), manganese (Mn), nickel (Ni), or cadmium (Cd):	<input type="checkbox"/> Yes** <input checked="" type="checkbox"/> No
---	---

**Please provide SDS/ MSDS information and estimated annual usage for each product

Other Process Information

Abrasive Blasting:	<input type="checkbox"/> Yes (Form 17) <input checked="" type="checkbox"/> No
Welding:	<input type="checkbox"/> Yes (Form 19) <input checked="" type="checkbox"/> No
Metal Cutting:	<input type="checkbox"/> Yes (Form 31) <input checked="" type="checkbox"/> No
Fluidized Bed Coating:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No

Cleaning/Etching/Degreasing Information

Methylene Chloride Stripping:	<input type="checkbox"/> Yes** <input checked="" type="checkbox"/> No
Phosphate or Chromate Conversion Coating:	<input type="checkbox"/> Yes** <input checked="" type="checkbox"/> No
Chemical/Acid Rinsing or Bathing:	<input type="checkbox"/> Yes** <input checked="" type="checkbox"/> No

**Please provide SDS/ MSDS information and estimated annual usage for each product

Exhaust/Stack/Building Information

Motor Power (hp):	7.5 hp	
Exhaust Air Flow Rate at 0.65" w.g. (acfm):	24000 Design CRM 8000 CFM Per fan	
Fan Diameter (feet):	30"	
Stack Type:	<input checked="" type="checkbox"/> Vertical (Ceiling Outlet)	<input type="checkbox"/> Horizontal (Wall Outlet)
Stack Height (feet from ground):	8	
Stack Inside Diameter (inches):	30	
Stack weatherproof damper or exhaust apparatus:	<input checked="" type="checkbox"/> None <input type="checkbox"/> Hexagonal <input type="checkbox"/> Stack within stack	<input type="checkbox"/> Butterfly <input type="checkbox"/> Inverted cone <input type="checkbox"/> Other (explain in attachment)
Bldg. Peak Height (feet):	60'	
Bldg. Width (feet):		
Bldg. Length (feet)		

Air Quality Modeling Site Information

Distance from the centroid of the stack to the shop's property line (feet):	
Distance from the centroid of the stack to the nearest point on the property line of a permanent residence (feet):	

Filing Fee:

See <https://www.orcaa.org/services/fee-schedules/> for an up-to-date list of fees

Material Usage Information

Provide the following information and attach copies of Material Safety Data Sheets (MSDS) used in all coating operations, including but not limited to pre-treatment wash, chemical strippers, paint, primer, topcoat, clearcoat, gelcoat, lacquer, stain, catalyst, activator, hardener, resin, filler, sealer, adhesive, solvent and thinner/reducer and any other materials used which contain volatile organic compounds (VOC). Use additional pages if necessary. For similar materials such as multiple color variations of a stain or paint, enter as single item with a usage rate representing the total gallons of all variations used, and provide the MSDS for the constituent which is most used.

NAME OF MATERIAL (as on SDS/ MSDS):	ESTIMATED ANNUAL USAGE (in gallons):	Applicator # (as defined in the "Coating Equipment Information" section):
Attachment 1 Paint spread sheet	3646.5	HVLP, airless, air

OLYMPIC REGION CLEAN AIR AGENCY

2940 Limited Lane NW - Olympia, Washington 98502 - 360-539-7610 – Fax 360-491-6308

NOC FORM 9 FIBERGLASS REINFORCED PLASTICS INDUSTRIES


GENERAL FACILITY INFORMATION			
Facility Name: Platypus Marine, Inc	Environmental Contact: Thomas G. Feik Phone Number: 360-912-3797 Email: tomf@platypusmarine.com		
General Operating Schedule: 8 hrs/day, 6 days/wk, 52 wks/yr Check the days when the facility operates: M <input checked="" type="checkbox"/> T <input type="checkbox"/> W <input type="checkbox"/> Th <input type="checkbox"/> Fri <input type="checkbox"/> Sat <input type="checkbox"/> Sun	Lamination Schedule: Account for times when lamination will be occurring. N/A hrs/day, N/A days/wk, N/A wks/yr Check days when lamination occurs: M T W Th F Sat Sun		
EQUIPMENT INFORMATION			
Methods of Coating: (check all that are proposed) <input type="checkbox"/> Dipping or Flow Coater <input checked="" type="checkbox"/> Brush or Roler <input checked="" type="checkbox"/> HVLP Spray Guns (High Volume Low Pressure) <input type="checkbox"/> Electrostatic <input type="checkbox"/> Air Assisted Airless, < 10 psi <input type="checkbox"/> Airless <input type="checkbox"/> Air Atomized (conventional or air spray) <input checked="" type="checkbox"/> Other (explain in attachment)		Air Pollution Control Methods(check all proposed) <input type="checkbox"/> Dry Filter Spray Booth <input type="checkbox"/> Water Wash Spray Booth <input type="checkbox"/> Incinerator (need Form 29) <input type="checkbox"/> Adsorption Scrubber (need Form 30) <input checked="" type="checkbox"/> Low VOC resins <input checked="" type="checkbox"/> Dust Collection System <input type="checkbox"/> Enclosed Spray Gun Cleaners <input type="checkbox"/> Other (explain in attachment)	
Spray Booth Data: Fan Motor H.P. Fan Size (in.) No. of Blades ACFM Exhaust Temperature Stack Height (from ground) Stack Inside Diameter Building Height, Width, Length Spray Booth Dimensions Spray Booth Filter Area Type of Filters	Line 1	Line 2	Line 3
Other Equipment: (attach written description or standard forms as indicated) <input type="checkbox"/> Hot Air Dryer (need Form 27) <input type="checkbox"/> Curing Oven (need Form 27) <input type="checkbox"/> Infrared Dryer <input type="checkbox"/> Abrasive Blaster (need Form 28) <input type="checkbox"/> Cyclone (need Form 13) <input type="checkbox"/> Baghouse (need Form 12)			
MATERIAL USAGE INFORMATION			
Provide the following information and attach copies of material Safety Data Sheets (MSDS) for all resins, gelcoats, catalysts, solvents, paints and any other materials used which contain volatile organic compounds. Use additional pages if necessary.			
NAME OF MATERIAL (as on MSDS): Attachment 2 Fiberglass PTE		ESTIMATED ANNUAL USAGE (in gallons): 871	

Note: See back of form for information on ORCAA-approved equipment and operations.

REQUIREMENTS FOR NEW FACILITIES PRODUCING FIBERGLASS REINFORCED PLASTICS ORCAA, 12/28/95

1. **Spray Booth:** A spray booth or enclosure is required for new Fiberglass Reinforced Plastics (FRP) industries within ORCAA's jurisdiction. The spray booth shall be capable of capturing overspray and emissions from spray coating and lamination operations. All spray coating and lamination shall be conducted inside the controlled spray booth area and only when the spray booth fan is operating properly.
2. **Spray Exhaust Stacks:** Spray booth exhaust shall exit through a vertical stack with a vertical discharge to the atmosphere at no less than one and one third the height of the building or 6 feet from the peak of the building roof line, whichever is the greater height. There shall be no flow obstructions at the point of discharge from the stack (i.e. cap). However, a butterfly damper or other weatherproof damper which does not obstruct the exhaust as it exits the stack is acceptable (see diagram below).
3. **Spray Booth Filters:** Spray booth filters shall be suitable for capture of overspray and shall be changed on a regular schedule according to the filter manufacturer recommendations. Filters shall be properly seated and shall cover all openings.
4. **Spray Booth Exhaust Ducts:** Spray booth exhaust ducts shall be visibly clean and free of buildup.
5. **Control of Volatile Organic Emissions:** Emissions of volatile organic compounds (VOCs) shall be controlled or minimized by use of either a control device such as an incinerator or adsorption scrubber, or through appropriate pollution prevention measures such as use of vapor suppressed or low styrene content resins.
6. **Minimizing Volatile Organic Emissions:** All reasonable measures and precautions shall be taken for minimizing volatile organic compound (VOC) emissions including:
 - a. Keeping VOC-containing materials in closed, air-tight containers when not being used.
 - b. Minimizing and promptly cleaning up all spills and leaks.
 - c. Recycle cleaning solvents by using an enclosed spray gun cleaner or flushing cleaning solvent back into the solvent bath or tank. **NOTE:** Cleaning spray guns and lines by spraying solvent into the air, filter banks, or on any surface where the solvent is not reclaimed and evaporates is **not acceptable**.
 - d. Standard procedures and schedule for checking and maintaining the spray booth system including inspection of the filters, fan and ducting, and checking for overspray outside of the shop.
7. **Complaint Investigation and Resolution Plan:** The owner or operator shall work cooperatively with complainants and ORCAA to resolve any nuisance related complaints including complaints due to odors, fallout, or fugitive dust.
8. **Record Keeping:** The following records are required:
 - a. Record of the monthly usage in gallons of all VOC containing materials.
 - b. MSDS for all VOC containing materials.
 - c. A copy of the final Approval Order issued by ORCAA.

FIGURE 1: Acceptable weatherproof exhaust systems:





OLYMPIC REGION CLEAN AIR AGENCY
 2940 B Limited Lane NW - Olympia, Washington 98502
 Telephone: (360)-539-7610 – Fax: (360)-491-6308
www.orcaa.org

FORM 17

Fill out all the applicable equipment information requested below and submit the appropriate fees.

Abrasive Blasting

Shop Information

Business Name: Northwest Sandblasting (subcontractor)	Contact Person: Devon Raleigh
	Phone Number: 360-259-5641
	Email: devonraleigh@comcast.com
Operating Schedule: 10 hrs/day, 5 days/wk, 52 wks/yr	Indicate days when operating: ✓ M ✓ T ✓ W ✓ Thu ✓ F ✓ Sat Sun

Blasting Operation Information

Type:	<input type="checkbox"/> Existing Stationary Source	<input checked="" type="checkbox"/> Temporary Source	<input type="checkbox"/> New Stationary Source
NAICS Code(s):	336611		

Blasting Information

Type:	<input type="checkbox"/> Hydro-blasting	<input type="checkbox"/> Wet-abrasive	<input type="checkbox"/> Other (explain in attachment)
	<input checked="" type="checkbox"/> Vacuum-blasting	<input type="checkbox"/> Bead/Micro-abrasive	
	<input checked="" type="checkbox"/> Centrifugal-blasting	<input type="checkbox"/> Bristle/Brush	
Equipment Type:	<input checked="" type="checkbox"/> Portable System (gravity fed or pressurized)	<input type="checkbox"/> Tumble Blaster	<input type="checkbox"/> Cabinet Blaster
		<input type="checkbox"/> Vacuum Blaster	<input type="checkbox"/> Other (explain in attachment)
Dust Control Methods:	<input checked="" type="checkbox"/> Enclosure (i.e. Tent, Room, Booth or Cabinet)	<input type="checkbox"/> Water Curtains	<input type="checkbox"/> Other (explain in attachment)
		<input type="checkbox"/> Drapes	
Exhausts to Outdoors:	<input type="checkbox"/> Yes, fill out exhaust information <input checked="" type="checkbox"/> No		

Enclosure Information

Type:	<input checked="" type="checkbox"/> Fully enclosed		<input type="checkbox"/> Closed top open front (CTOF)				
	<input type="checkbox"/> Open table/bench		<input checked="" type="checkbox"/> Other (explain in attachment)				
Exhaust:	<input type="checkbox"/> Side Wall	<input type="checkbox"/> Pit/Trench Design	<input type="checkbox"/> Ceiling	<input type="checkbox"/> Rear Wall	<input type="checkbox"/> Front/Doors	<input type="checkbox"/> Ducting	
Width (feet):	N/A		Length (feet):			Height (feet):	
Manufacturer:							
Model Number:							
Serial Number:							
Pressure Gauge:	<input type="checkbox"/> Yes <input type="checkbox"/> No		Filter Plenum:	<input type="checkbox"/> Yes <input type="checkbox"/> No			
Air Pollution Control Methods:	<input type="checkbox"/> Water Wash	<input type="checkbox"/> Cyclone (Form 13)	<input type="checkbox"/> Portable Dust Collector				
	<input type="checkbox"/> Cartridge Unit (Form 12)	<input type="checkbox"/> Baghouse (Form 12)	<input checked="" type="checkbox"/> Other (explain in attachment)				

Blasting Media Information

Type:	<input type="checkbox"/> Glass Beads <input type="checkbox"/> Cut Plastic <input type="checkbox"/> Aluminum Oxide <input type="checkbox"/> Crushed Nutshells <input type="checkbox"/> Cast Iron	<input type="checkbox"/> Garnet <input type="checkbox"/> Silica Sand <input type="checkbox"/> Crushed Glass <input type="checkbox"/> Steel Shot/Grit <input type="checkbox"/> Nickel Slag	<input type="checkbox"/> Copper Slag <input type="checkbox"/> Coal Slag <input type="checkbox"/> Staurolite <input checked="" type="checkbox"/> Other (explain in attachment)
Heavy Metal and Silica Composition (if applicable):	Trace Elements		Total Concentration (%)
	<input type="checkbox"/> Antimony (Sb)		N/A
	<input type="checkbox"/> Arsenic (As)		N/A
	<input type="checkbox"/> Barium (Ba)		N/A
	<input type="checkbox"/> Beryllium (Be)		N/A
	<input type="checkbox"/> Cadmium (Cd)		N/A
	<input type="checkbox"/> Chromium (Cr)		N/A
	<input type="checkbox"/> Copper (Cu)		N/A
	<input type="checkbox"/> Lead (Pb)		N/A
	<input type="checkbox"/> Mercury (Hg)		N/A
	<input type="checkbox"/> Nickel (Ni)		N/A
	<input type="checkbox"/> Selenium (Se)		N/A
	<input type="checkbox"/> Silver (Ag)		N/A
	<input type="checkbox"/> Thallium (Ti)		N/A
	<input type="checkbox"/> Zinc (Zn)		N/A
<input type="checkbox"/> Respirable Silica (CAS# 7631-86-9)		N/A	
Media Storage:	<input checked="" type="checkbox"/> Bags/Sacks	<input type="checkbox"/> Enclosed Building	<input type="checkbox"/> Hopper/Silo
Waste Handling Methods:	Subcontractor disposes of material		

Base Material Information

Type:	<input checked="" type="checkbox"/> Galvanized Steel <input checked="" type="checkbox"/> Stainless Steel <input checked="" type="checkbox"/> Aluminum	<input type="checkbox"/> Copper Alloys <input type="checkbox"/> Nickel Alloys <input type="checkbox"/> Glass	<input type="checkbox"/> Other (explain in attachment)
Surface Coatings:	<input type="checkbox"/> Anticorrosive <input checked="" type="checkbox"/> Shop primers	<input checked="" type="checkbox"/> Antifouling <input checked="" type="checkbox"/> Metal-based	<input type="checkbox"/> Other (explain in attachment)
SAE Steel Grade(s):			
Heavy Metal Composition (if applicable):	Trace Elements		Total Concentration (%)
	<input type="checkbox"/> Antimony (Sb)		N/A
	<input type="checkbox"/> Arsenic (As)		N/A
	<input type="checkbox"/> Barium (Ba)		N/A
	<input type="checkbox"/> Beryllium (Be)		N/A
	<input type="checkbox"/> Cadmium (Cd)		N/A
	<input type="checkbox"/> Chromium (Cr)		N/A
	<input type="checkbox"/> Copper (Cu)		N/A
	<input type="checkbox"/> Lead (Pb)		N/A
	<input type="checkbox"/> Mercury (Hg)		N/A
	<input type="checkbox"/> Nickel (Ni)		N/A
	<input type="checkbox"/> Selenium (Se)		N/A
	<input type="checkbox"/> Silver (Ag)		N/A
<input type="checkbox"/> Thallium (Ti)		N/A	
<input type="checkbox"/> Zinc (Zn)		N/A	

Dry Filter Information

	Pre-Filter	Exhaust Filter
Manufacturer:		
Model:		
Media Type:		
Overall Arrest Efficiency (%):		
Filtered Area (squared feet):		

Exhaust/Stack/Building Information

Motor Power (hp):		
Exhaust Air Flow Rate at 0.65" w.g. (acfm):		
Fan Diameter (feet):		
Stack Height (feet from ground):		
Stack Inside Diameter (inches):		
Stack weatherproof damper or exhaust apparatus**:	<input type="checkbox"/> None <input type="checkbox"/> Hexagonal <input type="checkbox"/> Stack within stack	<input type="checkbox"/> Butterfly <input type="checkbox"/> Inverted cone <input type="checkbox"/> Other (explain in attachment)
Bldg. Peak Height (feet):		
Bldg. Width (feet):		
Bldg. Length (feet)		

**See back of form for information on ORCAA-approved stack equipment

Portable System Information

Non-electric Air Heater:	<input type="checkbox"/> Yes (Form 11) <input type="checkbox"/> No
Non-electric Air Compressor:	<input type="checkbox"/> Yes (Form 11) <input type="checkbox"/> No

Air Quality Modeling Site Information

Distance from the centroid of the stack to the shop's property line (feet):	
Distance from the centroid of the stack to the nearest point on the property line of a permanent residence (feet):	

Material Usage Information

Provide the following information and attach copies of Material Safety Data Sheets (MSDS) for any material used including, but not limited to blasting media, base material and surface coatings, which contain toxic air pollutants. Use additional pages if necessary.	
NAME OF MATERIAL (as on MSDS):	ESTIMATED ANNUAL USAGE (in gallons or lbs):
Attachment 6 MSDS Green Diamond <input type="checkbox"/>	642,960 lbs <input type="checkbox"/>

RETURN TO ORCAA

OLYMPIC REGION CLEAN AIR AGENCY

2940 Limited Lane NW - Olympia, Washington 98502 - 360-539-7610 – Fax 360-491-6308


FORM 31 Thermal Metal Cutting

GENERAL INFORMATION						
Source Name/Address: Platypus Marine, Inc 518 Marine Dr. Port Angeles, Wa, 98363			Contact Person: Thomas Feik Phone Number: 360-417-0709 Email: tomf@platypusmarine.com			
EQUIPMENT INFORMATION 1. Provide as much information as is readily available 2. Use additional pages if necessary. 3. Call ORCAA if you need assistance - (360) 586-1044						
CUTTING PROCESS EQUIPMENT						
Equipment Type	Number of units		Specifications:			
	Portable	Stationary	Manufacturer/Model #	Fuel type	Plasma Gas	Capacity/Rating (amps)
Oxy-acetylene	3	N/A	Victor	oxy-acetylene	N/A	N/A
Plasma Arc	3	N/A	Hypertherm	Electric	N/A	N/A
Laser	N/A	N/A	N/A	N/A	N/A	N/A
Other (describe below)	N/A	N/A	N/A	N/A	N/A	N/A
AIR POLLUTION CONTROL METHOD						
<u>Equipment Type</u> <input type="checkbox"/> Downdraft Table <input type="checkbox"/> Water Table ___ Submerged cutting ___ Semi-dry <input type="checkbox"/> Cartridge filter <input type="checkbox"/> Baghouse <input type="checkbox"/> Electrostatic Precipitator (ESP) <input checked="" type="checkbox"/> Other (describe below) <input type="checkbox"/> None		<u>Stack Data:</u> No stack <u>No</u> Stack Height (from ground): _____ Stack Inside Diameter: _____ Bldg. Peak Height: _____ Bldg. Width: _____ Bldg. Length: _____		<u>Specifications:</u> Manufacturer/Model # _____ Control Efficiency (%) _____ ACFM _____ For water table: Maximum height of work above water level _____		
OTHER EQUIPMENT						
<u>Equipment Type</u> Finishing Consultants Closed top Open Front DFOCG-300812-NSB-SP-F3			<u>Specifications:</u> Pressure Gauge Yes 3 stage filter 31'W x 16'L x 16' H			
I hereby certify that the above information is, to the best of my knowledge, complete and correct.						
Signature _____					Date _____	



3-STAGE FILTRATION

Specifications — Products, Connections & Data Results



This overspray collection system is specifically designed for the collection of chromate coating overspray and diminishing the amount of dangerous chromium emissions up the exhaust stack.

This 3-stage system can be easily adapted to older 2-stage paint finishing lines.

Exceeds E.P.A Method 319 Emission Standard for Aerospace Manufacturing and Rework Facilities

1ST STAGE - Roll Media	2ND STAGE - MEPT Panel Filter	3RD STAGE - Bag Filters
<p>Roll Media contains multi-layered polyester media. The air-entry side is constructed of a mixture of lofted denier fiber. The air-leaving side is comprised of a mixture of heavily needled media to densify. The air leaving side is jet-ink printed for identification and proper installation. Media weighs 1.2 oz per square foot.</p> <p>GFS Part Numbers:</p> <ul style="list-style-type: none"> • 216-502, 36" X 50' • 216-503, 45" X 50' 	<p>The MEPT panel is constructed of two different layers of tackified polyester media, sealed together so the tackified layers of each media touch in the center. A galvanized nine-gauge wire frame will be inserted into the center of the MEPT panel, so the wire is touching the tackified sides of both media. The MEPT panel has an initial pressure drop of 0.06 water gauge (w.g.) at 150 feet per minute.</p> <p>The air-entry layer is constructed of multi-layered, multi-density polyester with a heavy, non-migrating tackifier on the air-leaving side. The air-leaving media is a heavily needled polyester, densified to 1/4" thick, tackified on the air-entry side with a weight of 0.42 oz per square foot. The air leaving side is jet-ink printed for identification and proper installation.</p> <p>GFS Part Numbers:</p> <ul style="list-style-type: none"> • 216-501, 20" X 20" X 1" • 216-517, 24" X 24" X 1" 	<p>The 6-pocket bag filter is constructed of a composite of pre-filter, melt blown and spun bound polyester fibers. The pockets are sewn together on the perimeter with two heat seals, forming three air channels in each bag pocket.</p> <p>The bag pockets on the metal support is inserted into a galvanized metal header. The galvanized header contains an acceptable sealing agent inside of each header to eliminate the possibility of paint bypass within the filter.</p> <p>GFS Part Numbers:</p> <ul style="list-style-type: none"> • 216-505, 20" X 20" X 12" • 216-516, 24" X 24" X 12"




FILTER MONITORING SYSTEM

A self-contained unit that monitors air filter pressure drop on a stage-by-stage basis. GFS' filter monitoring frame is designed to fit within an existing exhaust filter bank framework. Housing each filter within this unit allows multiple access tubes to be permanently mounted between each of these stages to monitor individual pressure drops.


Manual or electronic magnahelic gauges are connected for data collection. Pressure is taken at each of the three stages. Magnahelic gages located near the booth display the filter pressure. This allows filters to be changed consistently at appropriate pressure drops, ensuring emission standards compliance, quality paint finishes and filter longevity. Optional transmitter is available for data logging applications.

GFS Part Numbers:

- 600-200, 20" x 20" filter rack
- 600-201, 24" x 24" filter rack



3-Stage Monitor Connection



TEST DATA RESULTS

Method 319 Challenge Agents

Independent testing clearly demonstrates Aerospace Paint Overspray Collection System meets and far exceeds Method 319 Emission Standards for Aerospace Manufacturing and Rework Facilities in both liquid and solid phase.

	Efficiency Requirements Micron Size	Efficiency of 3 rd Stage Filter
Liquid Challenge	> 0.42 (>65%)	92.3%
	> 1.00 (>80%)	98.9%
	> 2.00 (>95%)	99.7%
Solid Challenge	> 0.70 (>75%)	96.6%
	> 1.70 (>85%)	98.4%
	> 2.50 (>95%)	99.6%

Conditions Pertinent to Filter Changing		
1 st Stage	2 nd Stage	3 rd Stage
+0.5" w.c.	+1.0" w.c.	+1.0" w.c.

Above Clean Operating Point

3-Stage Filter Build-Up Data	
Initial Pressure Drop	0.25" w.c.
Final Pressure Drop	3.0" w.c.



Efficient Equipment Solutions®



www.finishingconsultants.com
425-743-9999

NON-DISCLOSURE: FINISHING CONSULTANTS is providing this bid on finishing related equipment, designs and/or processes, which may include certain intellectual property, equipment manufacturers design concepts and/or drawings, confidential or proprietary documents, information, or trade secrets. Such information may include but is not limited to design and engineering drawings, manufacturers' specifications, necessary parts and component details, methodology and pricing, and may include any amendments or subsequent revisions thereof. Upon receipt of this proposal, recipient agrees to treat the proprietary/confidential information contained herein with care and shall not disclose or communicate contained information to any third-party including competitors of FINISHING CONSULTANTS and shall employ best efforts to prevent the inadvertent disclosure of FINISHING CONSULTANTS proprietary or confidential information contained herein.

PLATYPUS MARINE PRELIMINARY PROPOSAL SPRAY/SAND BOOTH, AMU

Chris Feffer
PLATYPUS MARINE INC.
April 13, 2023

For over 31 years, Finishing Consultants has been providing high-quality, Efficient Equipment Solutions® to manufacturers throughout the Western U.S. Whether powder or paint application, two-component metering, electrostatic spraying, abrasive blasting, dust and weld-smoke collection, or solvent recycling, Finishing Consultants has the technical expertise, products, and customer service to make your capital investment a successful one.

SCOPE OF WORK

Finishing Consultants is pleased to provide the following technical and current pricing information on our supply of a 30' wide spray/sand booth and air make up system, including all functional ducting, less mechanical erection services. Pricing does not include taxes, shipping or permitting of any kind.

ITEM A – SPRAY/SAND BOOTH

Equipment Type:	Dry Filter Open Face Booth
GFS Model Number:	DFOCG-300812-NSB-SP-F3
Internal Clear Working Dimensions:	30' 0" W x 8' 0" H x 12' 0" L
Overall Dimensions (Approximate):	31' 4" W x 8' 8" H x 16' 2" L
<i>Note: Approximate Overall Dimensions DO NOT Account for External Components (Fans, Remote Modules, AMUs, Ductwork, etc.)</i>	

Equipment Base Design

Equipment Panel Construction Type:	Single Skin
Equipment Panel Construction Finish:	G90 Galvanized Steel
Equipment Panel Construction Material:	18 Gauge Thickness
Support Structure Construction Type:	I-Beam Structural Steel
Airflow Design:	Cross draft
Target Average Air Velocity (FPM):	100 FPM
Light Quantity:	10 Lights
Light Type:	LED T8 Inside Access 4-Tube Lights

Exhaust Design

Total Design Exhaust CFM:	24000 Design CFM (8000 CFM per Fan)
Exhaust Method Design:	Industrial Exhaust Chamber
Exhaust Fan Framework:	(3) 30" Mixed Flow Fan with 7.5 HP TEFC Motor at 3" SP Aerovent
Exhaust Filter Selection:	Standard 3 Stage (Wave Media, Poly Panel, 2-Pocket Bag)

Exhaust Ductwork Inclusions *(Designed to Have Proper Termination Point from Building)*

Exhaust Duct Building Penetration:	Roof
Exhaust Duct Construction Design:	1 Lot of Spiral Exhaust Ductwork (30" Diameter)
Includes: (3) Inspection Door(s); (1 lot) Connection Rings; (3) ARV(s); (3) Roof Flange(s); (6) 45° Elbow(s); (3) Guy Wire Kit(s)	
<i>Note: Duct Supports not Provided in this Quotation (Roof Flanges & Additional Items not Included Unless Listed)</i>	

Equipment Access Design

Solid Back or Passthrough Equipment Flow:	Solid Back
Front Opening/Product Door Access:	Open Face
Front Opening/Product Door Size:	30' 0" W x 8' 0" H

Electrical Controls Design

Equipment Electrical Controls Operation:	Basic Non-Pressurized Control (CP-BNP)
Equipment Pressure Control System:	Manual VFD Balance (Mounted Inside Control Panel)
Safety Solenoid Valve Inclusion:	3/4" Industrial Style
Filter Monitoring Framework:	Manometer

Additional Inclusions

Include Equipment ETL Listing:	Included
Include Structurally Engineering Stamped Drawings:	Included

Cost F.O.B. Osseo, Wisconsin \$159,142.00 USD

(Cost does not include tax, installation, start-up services, and freight)
Standard freight terms = ship best way / pre-paid and added to the invoice

This quotation will remain valid for 30 days but is subject to revision for materials price increase following sales order acknowledgement of mutual acceptance of order.

Site Specifications (Required at Time of Order)

Roof Height and Site Exhaust Termination:	60' 0" Above Ground with 6' Termination Above Roof
Building Roof Pitch:	0/12 (Nearest Whole Number; 0 Equivalent to Flat)
Distance from Equipment to Wall:	Not Applicable to Design
Distance from AMU to Wall (Outdoor):	Not Applicable to Design
System Voltage on Site:	480V 3 PH 3 Wire
Gas Type and Pressure:	Not Applicable to Design
Installation Site Location:	98363 Zip Code (Red Zone - Review Required)

Construction

Booth panels are pre-punched, and companion flanged for easy assembly.

Booth support structure consists of structural steel with trouble-free bolt together assembly.

Note: This equipment is designed expressly for the removal of particulate matter only. Reduction of "volatile organic compounds" requires either coating reformulation or optional, additional equipment.

Mixed-Flow Fan

Mixed-flow fans are designed for maximum performance at higher static pressures and higher air volumes. A mixed-flow wheel offers quiet operation with high efficiencies in low-to-medium pressure-ducted systems. The housing is constructed of continuously welded, heavy-gauge steel to ensure no air leakage, with inlet and outlet collars for slip fit duct connections. Welded steel vanes straighten the flow of air from the fan discharge and support bearings and drives. Turned, precision-ground and polished steel shafts are sized so that the first critical speed is at least 25 percent more than the maximum operating speed for each pressure class. Close tolerances are maintained where the shaft makes contact with the bearing. Mixed-flow fans are also equipped with extended lube lines with grease fittings, allowing for lubrication without disassembling the fan. Belt guards provide protection from rotating drive components, per OSHA requirements. All sound levels are calculated in accordance with AMCA 210 standards.

T8 LED Light Fixtures

Glass-free, ETL listed T8 LED lamps emit virtually no ultraviolet or infrared light, and they don't contain mercury, allowing for non-hazardous waste disposal. They turn on instantly at full luminosity, with no flicker or buzz. T8 LED lamps offer up to 40 percent energy savings when compared to traditional fluorescent 32-watt T8 systems. They also last longer than traditional fluorescent bulbs, providing up to a 50,000-hour life span.

Three-Stage Filtration System

The three-stage filtration system is designed to fit into a 20-by-20-inch filter cell. The first stage features a roll media-type filter, the second stage is a panel-type filter, and the third stage is a bag-type filter.

Filter Monitoring System for Three-Stage Filtration

The filter monitoring system is designed to fit into a 20-by-20-inch filter cell. It is a self-contained unit that monitors air filter pressure drops on a stage-by-stage basis, without touching a single filter. Three magnehelic gauges are included.

Basic Non-Pressurized (BNP) Control Panel

- UL 508A listed, independent electromechanical control panel with a single-point connection for easy wiring to the main disconnecting device
- Type 1 rated enclosure provides protection from electrical shock
- Simple on/off controls for operating non-pressurized paint booths
- Standard control panel
- Included components:
 - Non-fused disconnect with a door-mounted disconnect handle provides basic safety lockout/tagout
 - Magnetic motor starter

- Motor fuse protection
- Lighting contactor
- Lighting circuit protection
- Terminal strips for field wiring
- System operating lights
- 22 mm pushbuttons
- Sequence of Operation
 - Use the system start and stop pushbuttons and the booth lighting selector switch to operate the booth's exhaust ventilation and lights.
- SCCR Rating 5ka standard at operating voltage (Please Note: higher ratings available for quotation if required).

Consta-Flow System

The Consta-Flow System is designed to automatically adjust the exhaust fan to the changing conditions of the exhaust filters. The system monitors static pressure and adjusts the exhaust fan's RPMs to meet the need of the volume of exhaust air based on how loaded the filters are. Booths with constant airflow as the filters load experience increased filter life.

Exhaust Ductwork *Designed to have proper termination height above the roof line*

Ductwork is constructed from 20-gauge galvanized spiral sections with connection rings for easy, bolt together assembly.

NOTE: Duct supports not provided in this quotation.

Manometer

The manometer measures differential pressure, indicating when paint arrestors or air intake filters are sufficiently loaded and need replacement. Manometers are included with all GFS paint booths and exhaust chambers.

Solenoid Valve

To prevent the working area of the equipment from reaching combustible levels, the three-way air safety valve interlocks the compressed air supplying the application equipment with the ventilation system and prevents spraying operations when exhaust fans are off. This safety feature is in accordance with NFPA 33 requirements. Additionally, any listed light fixtures included with this equipment provide a light lens switch that will shut down operation when the lens is not in the closed position. This is required to help prevent the possibility of the electrical componentry of the light from being exposed to a combustible level of overspray. Compressed air between the valve and the spray equipment is vented out when the valve is closed to assist in preventing damage to the equipment when the safety valve is triggered.

Assembly Hardware

Necessary assembly hardware provided, including all required bolts, nuts and caulking for a complete mechanical assembly. Anchor bolts are not provided, unless specified. For easy assembly, exploded-view installation drawings are also included.

ITEM B – AIR MAKE UP SYSTEM

TITAN AIR 24,000 CFM, VARIABLE OUTPUT, PROPANE-FIRED, VERTICAL DESIGN, 480 VOLT. OPTIONAL COST FOR ELECTRIC FIRED LISTED.

Airhandling Specifications

Model: TA-127 NG VRH DA
CFM: 24000
ESP ("w.c.): 0
Function: 100% OA | Variable Air Volume | Demand Air
Systems: Demand Air | Building Pressure Control
Location: Outdoor
Configuration: VRH
Elevation (ft): 0
TSP ("w.c.): 1.34
Fan Type: FC DWDI
Fan Size: Lau A27-27H
Fan RPM: 445
Fan BHP 11.5

Heating Control Summary

Controls: Discharge Control w/ Room Override (DDC)
BMS Comm.:
Enclosure: NEMA-1
Remote Panel: Shipped Loose

Voltage and Supply Motor Specifications

Power Supply: 480V, 3PH
Motor HP: 15 HP
Motor Type: 1750 rpm ODP Premium E
NEC Motor FLA: 21
Unit FLA: 22
SCCR: 5 kA

Unit Construction

Exterior: Epoxy w/ Enamel - Gray Casing Type: Double Wall Insulated Insulation: 1" 1.5#
Liner: Heresite Ins./Liner Loc.: Entire Airstream

Gas Heat Source

Heating Type: Direct-Fired Gas Type: NG Gas Pressure: 1# - 5#
Agency: STD-ANSI Temp Rise: 90 BTU/HR Min: 95040
BTU/HR Max: 2376000

Optional Equipment Included:

- Standard Stand
- Discharge Damper & Actuator*
 - Type: Standard
 - Damper Blades: Vertical
 - Finish: Match Unit
- Discharge Diffuser*
 - Type: 3-Way
 - Finish: Match Unit
- Outside Air Filter Section
 - Filters: 2" Cleanable
 - Config: V-Bank

Optional Controls Included:

- No NRTL (ETL/UL) Listing
- Door Interlocked Non-Fused Disconnect
- Low Fire Start
- High Gas Pressure Switch
- Low Temp Safety via DDC
- Warm OA Heat Shut Down via DDC
- 7 Day Occupancy Schedule via DDC
- Audible Alarm
 - DDC Fault
- Factory Mounted VFD w/ Vent Package
 - VFD Fuses / Circuit Breakers (By Others)

Cost F.O.B. Osseo, Wisconsin \$45,990.00 USD

Option-Electric-fired, please add \$74,002.00

(Cost does not include tax, installation, start-up services, and freight)

Standard freight terms = ship best way / pre-paid and added to the invoice

Delivery and Submittal Schedule

Phase of Process	Requirements to Move Forward	Equipment Timeframe
Receipt of Order	Acceptance of Order	Order Acceptance Confirmation
Submittal Drawings	Approved Submittal Drawings	15-20 Working Days
Production and Shipment	Completed Shipping Release	16-18 Weeks

Shipments that are delayed by the customer may incur storage and additional handling fees. If shipments incur additional charges that are outside of the control and responsibility of FC, the customer may need to assume those additional fees. Shipment dates are estimated and dependent on production capacity at the time approved submittal drawings received. A committed shipment date will be provided after submittal drawings have been approved.

Site Work Responsibilities as Performed By:	PLATYPUS	FC
Mechanical Installation of described equipment	X	
All lift equipment and crane service	X	
Verify Adequate Power	X	
Air Quality Permits	X	
Mechanical & Building Department Permits or Fees	X	
Unload Equipment	X	
Supply Equipment Staging Area	X	
Roof, Floor or Wall Penetrations/Duct Supports	X	
Concrete work	X	
Air Piping	X	
Any offsets for discharge ducting	X	
Main Power Termination to Equipment	X	
Electrical Component Field Wiring	X	
Compressed Air Piping to Equipment	X	
Fire Suppression System	X	
Third-Party Inspections	X	
Building or Fire Department Inspections	X	
Fire Alarm Connections	X	
Start Up & Training	X	
Waste Disposal	X	
Freight and Local Sales Tax	X	

EXCEPTIONS AND EXCLUSIONS: Mechanical Permits, third-party inspections or certifications, fire suppression systems, air regulators, electrical wiring or electrical connection to power source, any permits or permit costs, membrane-roof work or services to comply with roof warranty, roof penetration, Air Quality permits or costs, any other required permits or costs not described above, gas meter upgrades are the responsibility of the Gas Service Provider account holder, building alarm or fire system wiring or interlocks, site engineering, fluid or air piping, building or roof modifications to meet permit and building department requirements, any additional offsets in ducting if required, concrete work, sales tax, freight charges, off-loading of equipment and storage, or any items not specifically listed in our quotation.

TERMS

FOB FACTORY WITH FREIGHT CHARGES TO BE ADDED TO PRICING

EQUIPMENT:

50% down with signed order, 50% due 5 days prior to shipment of equipment

SHIPPING- ESTIMATED 16-18 WEEKS AFTER SIGNED APPROVAL DRAWING AND DEPOSIT

SALES TAX ADDED UNLESS TAX EXEMPT PER CUSTOMER

ALL PRICING VALID UNTIL 4/30/23, AND SUBJECT TO REVISION AFTER

Chris, thank you for your continued interest in our company, products, and technical services!



Jeff LaSorella
President

jeff@finishingconsultants.com

Office 425-743-9999 • **Cell** 206-618-4295
finishingconsultants.com

Efficient Equipment Solutions • Spray Systems, Pumps, Booths, Ovens & Dust Collection



GLOBAL
FINISHING
SOLUTIONS

12731 Norway Road | Osseo, Wisconsin 54758

800-848-8738 | globalfinishing.com


STRUCTURAL CALCULATIONS

GFS Project: U137521SD

3/14/2022

**Shipped To:
Platypus Marine, Inc.
518 Marine Drive
Port Angeles, WA 98363**

**Sold To:
Finnishing Consultants
720 132nd Street SW
Everett, WA 98204**



03/15/2022



Digitally signed by
DANIEL M GEORGE
Date: 2022.03.15
13:07:18 -05'00'

Sheet Index:

Equipment A	Page
Design Loads	1-2
Shear Wall Analysis	3-10

LOADING CRITERIA

ROOF DEAD LOAD

Panel	18 gauge	2.4 psf
Lights	Yes	
Number of Lights	4	0.5 psf
Fire Suppression	No	0.0 psf
Misc.	Yes (Stiffeners, Etc.)	0.3 psf
RDL		3.2 psf

WALL DEAD LOAD


Panel	18 gauge	2.4 psf
Lights	No	
	0	
WDL		2.4 psf

MECHANICAL EQUIPMENT

Make-up Air Unit	0 lbs
Exhaust Fan	662 lbs
Recirculation Fan	0 lbs
Duct	1248 lbs


BOOTH CONSTRUCTION

Booth Width, W (N-S)	14.0 ft
Booth Length, D (E-W)	16.0 ft
Mean Roof Height	8.0 ft
Roof Area	224 ft ²
Total Wall Length	46 ft



PLAN VIEW

(TOTAL WALL LENGTHS)



BOOTH FRONT ELEVATION

(BOOTH WIDTH & ROOF HEIGHT)



ASCE 7-16 EARTHQUAKE LOADS (Ch. 12)

	Code	ASCE 7-16	
	Soil Site Class	D	Table 20.3-1
	Risk Category	II, Standard	Table 1.5-1
Mapped Accelerations	S_s	1.587	From Hazard Tool
	S_1	0.615	
Site Coefficients	F_a	1.200	Table 11.4-1
	F_v	1.700	Table 11.4-2
MCE _R Spectral Accelerations	$S_{ms} = F_a * S_s$	1.904	Eq. 11.4-1
	$S_{m1} = F_v * S_1$	1.046	Eq. 11.4-2
Design Spectral Accelerations	$S_{DS} = 2/3(S_{ms})$	1.269	Eq. 11.4-3
	$S_{D1} = 2/3(S_{m1})$	0.697	Eq. 11.4-4
	Seismic Design Category (0.2 sec.)	D	Table 11.6-1
	Seismic Design Category (1.0 sec.)	D	Table 11.6-2
	Seismic Design Category	D	

Seismic Force Resisting System: Light-framed walls with shear panels of all other materials Table 12.2-1

Detailing Requirements		§ 14.1 & 14.5	
Average Building Height	h (ft)	8	
Building Height Limit		35	Table 12.2-1
Long-Period Transition Period	T_L	16	Figures 22-14 - 22-17
Coefficient for Upper Limit on Period	C_u	1.40	Table 12.8-1
Approximate Period Parameters	C_t	0.02	} Table 12.8-2
	x	0.75	
Approximate Fundamental Period	T_a	0.10	Eq. 12.8-7
Response Modification Coefficient	R	2.00	} Table 12.2-1
System Overstrength Factor	Ω_o	2.50	
Deflection Amplification Factor	C_d	2.00	
Importance Factor	I_E	1.00	Table 11.5-2

Seismic Response Coefficient

C_s	0.635	Eq. 12.8-2
C_{s_max}	3.663	Eq. 12.8-3
C_{s_min}	0.056	Eq. 12.8-5
C_{s_min}	0.246	Eq. 12.8-6

C_s 0.635



SEISMIC DESIGN

SEISMIC WEIGHT

Booth Weight (Trib to Roof) 1158 lbs

Mechanical Equipment

Make-up Air Unit 0 lbs
 Exhaust Fan 662 lbs
 Recirculation Fan 0 lbs
 Duct 1248 lbs

Total Weight, W_T 3068 lbs

BASE SHEAR (ASCE 7-10 12.8.1)

$C_s * W_T, V$ 1947 lbs (Ult.)

DIAPHRAGM DESIGN

$$F_p = \frac{\sum_{i=x}^n F_i}{\sum_{i=x}^n W_i} W_{px}$$

$F_p =$ 8334 lbs (ASCE 7-16 12.10-1)

Shall not be less than

$F_{p \min} =$ 779 lbs (ASCE 7-16 12.10-2)

Need not exceed

$F_{p \max} =$ 1558 lbs (ASCE 7-16 12.10-3)

$F_p =$ 1558 lbs

East-West Direction

$V_{EW} =$ 49 plf

$V_{allow} =$ 190 plf

Actual < Allowable therefore OK

North-South Direction

$V_{NS} =$ 111 plf

$V_{allow} =$ 190 plf

Actual < Allowable therefore OK

USE 18 GA ROOF PANELS



SHEAR WALL DESIGN

GRID LINE A

Entire Wall Length 16.0 ft
 Pier Length 16.0 ft
 Number of Piers 1
 Panel Height 8.0 ft

SEISMIC LOADING

Total Area 224 ft²
 Tributary Area 112 ft²
 Shear to Gridline 973 lbs (Ult.)
 Shear to Pier 973 lbs (Ult.)

SHEAR WALL DESIGN

GRID LINE B

Entire Wall Length 16.0 ft
 Pier Length 16.0 ft
 Number of Piers 1
 Panel Height 8.0 ft


SEISMIC LOADING

Total Area 224 ft²
 Tributary Area 112 ft²
 Shear to Gridline 973 lbs (Ult.)
 Shear to Pier 973 lbs (Ult.)



SHEAR WALL DESIGN

GRID LINE A



1/4"Ø DeWalt Screw-Bolt+ Embedded 2" Minimum

Reference Report: ESR-3889

Effective Embed. Depth, h_{ef}	1.94 in
Min. Anchor Spacing, s_{min}	1.5 in
Min. Slab Thickness, h_{min}	4 in
Critical Edge Distance, c_{ac}	6.1 in

Shear Wall Dimensions

Pier Length	16.0 ft
Number of Piers	1
Panel Height	8.0 ft

Shear at Wall/Pier

Shear to Gridline	973 lbs
Shear to Pier	973 lbs
Uniform Shear to Pier	61 plf

Check 18 GA wall panel

Panel Thickness	0.048 in
Allowable Wall Shear	190 plf

DESIGN CONTROLLED BY NORTH-SOUTH LOADING

Check Overturning

Overturning Moment	7788 lb-ft
Resisting Moment	2867 lb-ft
Uplift	325 lbs
Capacity of Anchor (Tension)	920 lbs
Number of holdown anchors required	1

DESIGN CONTROLLED BY NORTH-SOUTH LOADING

Check Shear Anchors

Capacity of Anchor (Shear)	1205 lbs
Number of bolts required	1
Yield Strength of Sheet Steel	30 ksi
Ω	2.5
Steel Bearing Capacity	129 lbs
Number of bolts required	8
Anchors at 18" o.c.	10
Anchors at 12" o.c.	15
Anchors at 6" o.c.	30

10 anchors provided

DESIGN CONTROLLED BY NORTH-SOUTH LOADING


ANCHORAGE VALUES ARE BASED ON AN EDGE DISTANCE GREATER THAN THE CRITICAL EDGE DISTANCE REPORTED IN

This spreadsheet assumes concrete is NOT reinforced per ACI 318-14 and therefore uses all *Condition B* values on the ICC-ES report for the chosen anchor.



SHEAR WALL DESIGN

GRID LINE B



1/4" Ø DeWalt Screw-Bolt+ Embedded 2" Minimum

Reference Report: ESR-3889

Effective Embed. Depth, h_{ef}	1.94 in
Min. Anchor Spacing, s_{min}	1.5 in
Min. Slab Thickness, h_{min}	4 in
Critical Edge Distance, c_{ac}	6.1 in

Shear Wall Dimensions

Pier Length	16.0 ft
Number of Piers	1
Panel Height	8.0 ft

Shear at Wall/Pier

Shear to Gridline	973 lbs
Shear to Pier	973 lbs
Uniform Shear to Pier	61 plf

Check 18 GA wall panel

Panel Thickness	0.048 in
Allowable Wall Shear	190 plf

DESIGN CONTROLLED BY NORTH-SOUTH LOADING

Check Overturning

Overturning Moment	7788 lb-ft
Resisting Moment	2867 lb-ft
Uplift	325 lbs
Capacity of Anchor (Tension)	920 lbs
Number of holdown anchors required	1

DESIGN CONTROLLED BY NORTH-SOUTH LOADING

Check Shear Anchors

Capacity of Anchor (Shear)	1205 lbs
Number of bolts required	1
Yield Strength of Sheet Steel	30 ksi
Ω	2.5
Steel Bearing Capacity	129 lbs
Number of bolts required	8
Anchors at 18" o.c.	10
Anchors at 12" o.c.	15
Anchors at 6" o.c.	30

10 anchors provided

DESIGN CONTROLLED BY NORTH-SOUTH LOADING

ANCHORAGE VALUES ARE BASED ON AN EDGE DISTANCE GREATER THAN THE CRITICAL EDGE DISTANCE REPORTED IN

This spreadsheet assumes concrete is NOT reinforced per ACI 318-14 and therefore uses all *Condition B* values on the ICC-ES report for the chosen anchor.



SHEAR WALL DESIGN

GRID LINE 1

Entire Wall Length 14.0 ft
 Pier Length 14.0 ft
 Number of Piers 1
 Panel Height 8.0 ft

SEISMIC LOADING

Total Area 224 ft²
 Tributary Area 224 ft²
 Shear to Gridline 1947 lbs (Ult.)
 Shear to Pier 1947 lbs (Ult.)

SHEAR WALL DESIGN

GRID LINE A

Entire Wall Length 16.0 ft
 Pier Length 16.0 ft
 Number of Piers 1
 Panel Height 8.0 ft

SEISMIC LOADING

Shear to Gridline 1113 lbs (Ult.)
 Shear to Pier 1113 lbs (Ult.)

North-South lateral loads control design of
 Gridline A shear wall

GRID LINE B

Entire Wall Length 16.0 ft
 Pier Length 16.0 ft
 Number of Piers 1
 Panel Height 8.0 ft

SEISMIC LOADING


Shear to Gridline 1113 lbs (Ult.)
 Shear to Pier 1113 lbs (Ult.)

North-South lateral loads control design of
 Gridline B shear wall



SHEAR WALL DESIGN

GRID LINE 1



1/4" Ø DeWalt Screw-Bolt+ Embedded 2" Minimum

Reference Report: ESR-3889

Effective Embed. Depth, h_{ef}	1.94 in
Min. Anchor Spacing, s_{min}	1.5 in
Min. Slab Thickness, h_{min}	4 in
Critical Edge Distance, c_{ac}	6.1 in

Shear Wall Dimensions

Pier Length	14.0 ft
Number of Piers	1
Panel Height	8.0 ft

Shear at Wall/Pier

Shear to Gridline	1947 lbs
Shear to Pier	1947 lbs
Uniform Shear to Pier	139 plf

Check 18 GA wall panel

Panel Thickness	0.048 in
Allowable Wall Shear	190 plf

18 GA WALL PANELS OK

Check Overturning

Overturning Moment	15575 lb-ft
Resisting Moment	2195 lb-ft
Uplift	971 lbs
Capacity of Anchor (Tension)	920 lbs
Number of holdown anchors required	2

LOCATE FIRST HOLDOWN ANCHOR 3 IN. FROM END OF THE PIER AND REMAINING (1) HOLDOWN ANCHOR AT 6 IN. O.C. FROM FIRST HOLDOWN ANCHOR

Check Shear Anchors

Capacity of Anchor (Shear)	1205 lbs
Number of bolts required	2
Yield Strength of Sheet Steel	30 ksi
Ω	2.5
Steel Bearing Capacity	129 lbs
Number of bolts required	16
Anchors at 18" o.c.	8
Anchors at 12" o.c.	12
Anchors at 6" o.c.	24

24 anchors provided

SPACE ANCHORS AT 6 IN. O.C. BETWEEN HOLDOWN ANCHORS


ANCHORAGE VALUES ARE BASED ON AN EDGE DISTANCE GREATER THAN THE CRITICAL EDGE DISTANCE REPORTED IN

This spreadsheet assumes concrete is NOT reinforced per ACI 318-14 and therefore uses all *Condition B* values on the ICC-ES report for the chosen anchor.



SHEAR WALL DESIGN

GRID LINE A



1/4"Ø DeWalt Screw-Bolt+ Embedded 2" Minimum

Reference Report: ESR-3889

Effective Embed. Depth, h_{ef}	1.94 in
Min. Anchor Spacing, s_{min}	1.5 in
Min. Slab Thickness, h_{min}	4 in
Critical Edge Distance, c_{ac}	6.1 in

Shear Wall Dimensions

Pier Length	16.0 ft
Number of Piers	1
Panel Height	8.0 ft

Shear at Wall/Pier

Shear to Gridline	1113 lbs
Shear to Pier	1113 lbs
Uniform Shear to Pier	70 plf

Check 18 GA wall panel

Panel Thickness	0.048 in
Allowable Wall Shear	190 plf

18 GA WALL PANELS OK

Check Overturning

Overturning Moment	8900 lb-ft
Resisting Moment	2867 lb-ft
Uplift	395 lbs
Capacity of Anchor (Tension)	920 lbs
Number of holddown anchors required	1

LOCATE HOLDOWN ANCHOR 3 IN. FROM EACH END OF THE PIER

Check Shear Anchors

Capacity of Anchor (Shear)	1205 lbs
Number of bolts required	1
Yield Strength of Sheet Steel	30 ksi
Ω	2.5
Steel Bearing Capacity	129 lbs
Number of bolts required	9
Anchors at 18" o.c.	10
Anchors at 12" o.c.	15
Anchors at 6" o.c.	30

10 anchors provided

SPACE ANCHORS AT 18 IN. O.C. BETWEEN HOLDOWN ANCHORS


ANCHORAGE VALUES ARE BASED ON AN EDGE DISTANCE GREATER THAN THE CRITICAL EDGE DISTANCE REPORTED IN

This spreadsheet assumes concrete is NOT reinforced per ACI 318-14 and therefore uses all *Condition B* values on the ICC-ES report for the chosen anchor.



SHEAR WALL DESIGN

GRID LINE B



1/4" Ø DeWalt Screw-Bolt+ Embedded 2" Minimum

Reference Report: ESR-3889

Effective Embed. Depth, h_{ef}	1.94 in
Min. Anchor Spacing, s_{min}	1.5 in
Min. Slab Thickness, h_{min}	4 in
Critical Edge Distance, c_{ac}	6.1 in

Shear Wall Dimensions

Pier Length	16.0 ft
Number of Piers	1
Panel Height	8.0 ft

Shear at Wall/Pier

Shear to Gridline	1113 lbs
Shear to Pier	1113 lbs
Uniform Shear to Pier	70 plf

Check 18 GA wall panel

Panel Thickness	0.048 in
Allowable Wall Shear	190 plf

18 GA WALL PANELS OK

Check Overturning

Overturning Moment	8900 lb-ft
Resisting Moment	2867 lb-ft
Uplift	395 lbs
Capacity of Anchor (Tension)	920 lbs
Number of holddown anchors required	1

LOCATE HOLDOWN ANCHOR 3 IN. FROM EACH END OF THE PIER

Check Shear Anchors

Capacity of Anchor (Shear)	1205 lbs
Number of bolts required	1
Yield Strength of Sheet Steel	30 ksi
Ω	2.5
Steel Bearing Capacity	129 lbs
Number of bolts required	9
Anchors at 18" o.c.	10
Anchors at 12" o.c.	15
Anchors at 6" o.c.	30

10 anchors provided

SPACE ANCHORS AT 18 IN. O.C. BETWEEN HOLDOWN ANCHORS

ANCHORAGE VALUES ARE BASED ON AN EDGE DISTANCE GREATER THAN THE CRITICAL EDGE DISTANCE REPORTED IN

This spreadsheet assumes concrete is NOT reinforced per ACI 318-14 and therefore uses all *Condition B* values on the ICC-ES report for the chosen anchor.



GENERAL STRUCTURAL NOTES

APPLY UNLESS NOTED ON DRAWINGS. IN CASE OF CONFLICT BETWEEN GSN, DETAILS AND PLANS, THE GREATER REQUIREMENTS GOVERN.

DESIGN INFORMATION:

BOOTH AND EQUIPMENT HAS BEEN DESIGNED BASED ON THE CURRENT EDITION OF THE INTERNATIONAL BUILDING CODE

RISK CATEGORY: II
SEISMIC IMPORTANCE FACTOR: IE=1
MAPPED SPECTRAL RESPONSE ACCELERATION:
S_s = 1.587
S₁ = 0.615

SITE CLASS: D (ASSUMED)
SPECTRAL RESPONSE COEFFICIENT:
S_{DS} = 1.269
S_{DI} = 0.697

SEISMIC DESIGN CATEGORY: D
SEISMIC-FORCE-RESISTING SYSTEMS:
LIGHT-FRAMED WALLS WITH SHEAR PANELS OF ALL OTHER MATERIALS

RESPONSE MODIFICATION FACTOR: R=2
SEISMIC RESPONSE COEFFICIENT: C_s=0.635

ANALYSIS PROCEDURE USED:
EQUIVALENT LATERAL FORCE PROCEDURE

BASIC WIND SPEED: 97 MPH
(PORTIONS OF EQUIPMENT THAT ARE OUTDOOR ONLY - IE STACKS AND STANDS)

BUILDING CATEGORY: INDOOR

EXPOSURE: C

LATERAL LIVE LOAD: 5 PSF

DEAD LOADS: SELF-WEIGHT OF STRUCTURAL STEEL

- 6 PSF (ROOF)

- 4 PSF (WALLS)

BOOTH ROOF LIVE LOADS: N/A PSF

FDN INFORMATION:

CAPACITY OF THE FDN/SLAB TO SUPPORT GFS BOOTHS AND EQUIPMENT IS NOT THE RESPONSIBILITY OF GFS.

ANCHORS INDICATED ARE BASED ON ASSUMPTIONS OF EXIST CONDITIONS (LISTED BELOW). THESE ASSUMPTIONS ARE MADE IN ORDER FOR GFS TO PROVIDE ANCHOR BOLT HOLES IN THE BASE PLATES AND PANELS. EXIST CONDITIONS SHOULD BE VERIFIED BY THE OWNER AND ANY DEVIATIONS SHOULD BE CONVEYED TO GFS PRIOR TO FABRICATION.

1/4"Ø SCREW ANCHOR - 1/4"Ø POWERS (DEWALT) SCREW-BOLT+ SCREW ANCHORS EMBEDDED 1 15/16" PER ICC ESR-3889 TO SECURE PANELS TO CONC. IN LIEU OF THE POWERS (DEWALT) ANCHOR, 1/4"Ø HILTI KWIK HUS-EZ SCREW ANCHORS EMBEDDED 1 15/16" PER ICC ESR-3027 MAY BE USED. EACH WALL/BAY IS REQUIRED TO HAVE ANCHORS AT 18" O.C. MAX, U.N.O. EACH WALL SHALL HAVE (1) ANCHOR 6" MAX FROM END OR CORNER AND A MIN OF (2) ANCHOR PER WALL/BAY. INSTALL ANCHORS PER MFR'S RECOMMENDATION. SEE DETAILS FOR ADDITIONAL INFORMATION. A PREAPPROVED ANCHOR WITH A CAPACITY EQUAL TO OR GREATER THAN THE SPECIFIED ANCHOR AND WITH A CURRENT ICC REPORT MAY BE USED IN LIEU OF THE ANCHOR SPECIFIED. ALL OTHER RESTRICTIONS (INCLUDING BUT NOT LIMITED TO EDGE DISTANCE AND EMBEDMENT) SHALL BE CONSIDERED.

ANCHOR SPECIFICATION IS BASED ON THE FOLLOWING ASSUMPTIONS OF EXIST CONDITIONS:
-- MIN CONC COMPRESSIVE STRENGTH IS 2500 PSI.
-- MIN SLAB DEPTH IS 4".

COLD-FORMED STEEL:

ALL COLD-FORMED STEEL MEETS THE REQUIREMENTS OF THE LATEST EDITION OF THE AISI SPECIFICATION FOR THE DESIGN OF COLD-FORMED STEEL STRUCTURAL MEMBERS. ALL COLD-FORMED STEEL IS COMMERCIAL GRADE WITH A YIELD STRENGTH OF 24 KSI AND AN ULTIMATE STRENGTH OF 40 KSI.

STRUCTURAL STEEL:

ALL STRUCTURAL STEEL FABRICATION AND CONSTRUCTION COMPLY WITH THE LATEST AISC HANDBOOKS AND CODES. ALL STEEL IS ASTM A36, EXCEPT AS FOLLOWS:
-- WIDE FLANGE SECTIONS - ASTM A992,
-- PIPE SECTIONS - ASTM A53 GRADE B,
-- HSS SECTIONS - ASTM A500 GRADE B
-- BOLTS ARE A325-N AND SHALL BE SNUG-TIGHTENED.

WELDING:

WELDERS HOLD CURRENT VALID CERTIFICATES AND HAVE CURRENT EXPERIENCE IN TYPE OF WELD CALLED FOR. STRUCTURAL STEEL WELDING WITH LOW HYDROGEN TYPE, E70 AND E60 FOR LIGHT GAUGE STEEL. STRUCTURAL STEEL WELDING CONFORMS TO THE "STRUCTURAL WELDING CODES-STEEL" AWS D1.1, CURRENT EDITION.

ROOF ACCESS RESTRICTIONS:

THE ROOFS OF GFS EQUIPMENT ARE NOT DESIGNED OR INTENDED TO BE WALKED UPON OR TO SUPPORT WEIGHT OF ANY KIND. AS DESIGNED AND MANUFACTURED, THE EQUIPMENT ROOFS DO NOT MEET THE MINIMUM REQUIREMENTS OF A SAFE WALKING AND/OR WORKING SURFACE UNDER OSHA 1910.22. UNDER NO CIRCUMSTANCES SHOULD THE ROOF BE USED BY MAINTENANCE PERSONNEL OR OTHERS FOR WALKING, STANDING, OR STORAGE OF ANY KIND.

WHEN NECESSARY, ROOF ACCESS SHOULD BE SECURED THROUGH THE USE OF A PROPERLY SUPPORTED PLATFORM THAT SATISFIES THE MINIMUM LOAD REQUIREMENTS SPECIFIED BY ASCE 7 (MINIMUM DESIGN LOADS AND ASSOCIATED CRITERIA FOR BUILDINGS AND OTHER STRUCTURES) AND ASCE 37 (DESIGN LOADS ON STRUCTURES DURING CONSTRUCTION).

ADDITIONALLY, PERSONNEL SHOULD ALWAYS UTILIZE APPROPRIATE FALL SAFETY PROTOCOLS WHEN USING AN ELEVATED PLATFORM. USE OF THE ROOF IN A CONTRARY MANNER MAY RESULT IN INJURY AND/OR DEATH.

SPECIAL INSPECTION INFORMATION:

SPECIAL INSPECTION SHALL BE REQUIRED FOR THE FOLLOWING TYPES OF WORK AND SHALL BE IN COMPLIANCE WITH IBC SECTION 1705:

1. POST-INSTALLED ANCHORS INTO HARDENED CONCRETE.
2. HIGH STRENGTH BOLTING.
3. FIELD WELDING.
4. STRUCTURAL STEEL IN THE SEISMIC FORCE-RESISTING SYSTEMS

STATEMENT OF SPECIAL INSPECTION:

- A THIS STATEMENT OF SPECIAL INSPECTIONS SHALL BE SUBMITTED IN ACCORDANCE WITH SECTION 1704.3 OF THE IBC.
- B THIS STATEMENT SHALL INCLUDE A SCHEDULE OF SPECIAL INSPECTION SERVICES APPLICABLE TO THIS PROJECT.

THE SPECIAL INSPECTOR(S) SHALL KEEP RECORDS OF ALL INSPECTIONS AND SHALL FURNISH INTERIM INSPECTION REPORTS TO THE BUILDING OFFICIAL AND TO THE REGISTERED DESIGN PROFESSIONAL IN RESPONSIBLE CHARGE ON A BI-WEEKLY BASIS. DISCREPANCIES SHALL BE BROUGHT TO THE IMMEDIATE ATTENTION OF THE CONTRACTOR FOR CORRECTION. IF THE DISCREPANCIES ARE NOT CORRECTED, THE DISCREPANCIES SHALL BE BROUGHT TO THE ATTENTION OF THE BUILDING OFFICIAL AND THE REGISTERED DESIGN PROFESSIONAL IN RESPONSIBLE CHARGE PRIOR TO COMPLETION OF THAT PHASE OF WORK. A FINAL REPORT OF SPECIAL INSPECTIONS DOCUMENTING REQUIRED SPECIAL INSPECTIONS AND CORRECTIONS OF ANY DISCREPANCIES NOTED IN THE INSPECTIONS SHALL BE SUBMITTED TO THE BUILDING OFFICIAL AND REGISTERED DESIGN PROFESSIONAL IN RESPONSIBLE CHARGE AT THE CONCLUSION OF THE PROJECT.

THE SPECIAL INSPECTION PROGRAM DOES NOT RELIEVE THE CONTRACTOR OF THE RESPONSIBILITY TO COMPLY WITH THE CONTRACT DOCUMENTS. JOBSITE SAFETY AND MEANS AND METHOD OF CONSTRUCTION ARE SOLELY THE RESPONSIBILITY OF THE CONTRACTOR.

ABBREVIATIONS:

AMU	-	AIR MAKE-UP UNIT
BLDG	-	BUILDING
CONC	-	CONCRETE
ESOW	-	EACH SIDE OF WEB
EXIST	-	EXISTING
FDN	-	FOUNDATION
GA	-	GAUGE
GR5	-	GRADE 5
IBC	-	INTERNATIONAL BUILDING CODE
LBS	-	POUNDS
MAX	-	MAXIMUM
MFR	-	MANUFACTURER
MIN	-	MINIMUM
NS/FS	-	NEAR SIDE AND FAR SIDE
O.C.	-	ON CENTER
OSHA	-	OCCUPATIONAL SAFETY AND HEALTH ADMINISTRATION
PLF	-	POUNDS PER LINEAR FOOT
PSF	-	POUNDS PER SQUARE FOOT
T/B	-	TOP AND BOTTOM
TYP	-	TYPICAL
U.N.O. OR UNO	-	UNLESS NOTED OTHERWISE
WF	-	WIDE FLANGE

GLOBAL FINISHING SOLUTIONS
12731 NORWAY ROAD
OSSEO, WI 54758 USA
800-848-8738
globalfinishing.com



GFS Digitally signed by DANIEL M GEISLER
Date: 2022.03.13:06:43 -05'0

SCALE	NTS	DRAWN BY	BDK	DATE	1/5/2022	REVIEW BY	BDK	REVIEW DATE
-------	-----	----------	-----	------	----------	-----------	-----	-------------

SHIP TO
FINISHING CONSULTANTS
132ND STREET SW / SUITE 201 | 518 MARINE DRIVE
PLATYPUS MARINE, INC.


IMPORTANT NOTE: This print and all information contained therein is the sole property of Global Finishing Solutions, LLC ("GFS"). It is not to be used or reproduced in any manner or submitted to other parties for examination without the express written approval of GFS pursuant to a fully-executed contract or purchase order for GFS-manufactured equipment. Customer may make and retain copies of this document for their own use, but this document and its contents shall remain the property of GFS. No part of this document is to be reproduced or transmitted in any form or by any means, electronic or mechanical, including photocopying, recording, or by any information storage and retrieval system, without the prior written permission of GFS.

1

2


3

4




DF2A ROOF BEAM
SS###

1. SINGLE SKIN BOOTH ROOF PANEL.
2. 12GA "J" BEAM x 10" DEEP.
3. 18GA BRACE - LOCATE BETWEEN PANELS NEAREST TO MID-SPAN.
4. 5/16"φ A307 BOLT - FIELD DRILL.
5. 10GA SPLICE CHANNEL x 5 1/2" DEEP x 30" LONG.
6. MID-SPAN.
7. (4) 1/2"φ A325 BOLTS EACH SIDE OF SPLICE.




DF2B ROOF BEAM
SS###

1. SINGLE SKIN BOOTH ROOF PANEL.
2. 12GA "J" BEAM x 10" DEEP.
3. 18GA BRACE - LOCATE BETWEEN PANELS NEAREST TO MID-SPAN.
4. 5/16"φ A307 BOLT - FIELD DRILL.
5. 10GA SPLICE CHANNEL x 5 1/2" DEEP x 30" LONG.
6. MID-SPAN.
7. (4) 1/2"φ A325 BOLTS EACH SIDE OF SPLICE.
8. BENT SHEET LEDGER ANGLE - 2x2x14GA.
9. 5/16"φ BOLTS AT 6" O.C.




DF4A FILTER RACK TO WALL STRUT
SS###

1. SINGLE SKIN WALL PANEL.
2. FILTER RACK FRAMING.
3. 18GA STRUT.
4. (2) 5/16"φ A307 BOLTS.
5. (1) 5/16"φ A307 BOLT.




DF3C WALL/ROOF TIE
SS###

1. SINGLE SKIN WALL PANEL.
2. SINGLE SKIN BOOTH ROOF PANEL.
3. TIE ANGLE - 2x2x14GA.
4. 5/16"φ BOLTS AT 6" O.C. TYP WHERE SHOWN.



DF4B FILTER RACK
SS###

1. FILTER RACK FRAMING.
2. 5/16"φ A307 BOLTS AT 6" O.C.




DF1 PANEL TO PANEL CONNECTION
SS###

1. FILTER RACK.
2. FLOOR CHANNEL, FIELD DRILL AS NECESSARY FOR ANCHOR INSTALLATION
3. SEE 1/4"φ SCREW ANCHOR NOTE ON GSN.
4. EXIST SLAB ON GRADE, 4" MIN CONC THICKNESS. VERIFICATION OF SLAB NOT BY GFS.

1. SINGLE SKIN PANEL.
2. 5/16"φ A307 BOLTS AT 6" O.C. TYP.

1. MAY NEED TO REMOVE BOLT AND NUT FOR INSTALLATION OF ANCHOR.
2. SEE 1/4"φ SCREW ANCHOR NOTES ON GSN.
3. EXIST SLAB ON GRADE, 4" MIN CONC THICKNESS. VERIFICATION OF SLAB NOT BY GFS.
4. SINGLE SKIN PANEL.
5. BASE TIE ANGLE

GLOBAL FINISHING SOLUTIONS
12731 NORWAY ROAD
OSSEO, WI 54758 USA
800-848-8738
globalfinishing.com



SCALE	NTS	DRAWN BY	BDK	DATE	1/5/2022	REVIEW BY	BDK	REVIEW DATE
-------	-----	----------	-----	------	----------	-----------	-----	-------------

SHIP TO
PLATYPUS MARINE, INC.
1518 MARINE DRIVE
SUITE 201
OSSEO, WI 54758

DEL INFO
STANDARD DETAILS

IMPORTANT NOTE: This print and all information contained therein is the sole property of Global Finishing Solutions, LLC ("GFS"). It is not to be used or reproduced in any manner or submitted to other parties for examination without the express written approval of GFS pursuant to a fully-executed contract or purchase order for GFS-manufactured equipment. Customer may make and retain copies of this print for their own use, but they are not to be distributed, copied, or otherwise used for any purpose not intended or represented to be suitable for re-use by Customer or others on extensions of the order.

- NOTE:
- BOOTH IS FABRICATED FROM 18 GAGE GALVANIZED SHEET STEEL; PRE-PUNCHED AND COMPANION FLANGED FOR BOLT TOGETHER ASSEMBLY.
 - SOLENOID VALVE REQUIRED FOR INTERLOCKING SPRAY AIR WITH LIGHT LIMIT SWITCH AND EXHAUST. (VALVE CAN BE ORDERED AS AN OPTION FROM GFS)
 - WALL SHUTTER, IF APPLICABLE, DOES NOT MEET NFPA CODE. DISCHARGE POINT MUST BE 6' FROM EXTERIOR WALL OR ROOF.
 - INCLUDED BUT NOT SHOWN:
 - (1) MANOMETER
 - (1) 1/2" SOLENOID VALVE
 - (1) CONTROL PANEL w/ MANUAL VFD

BOOTH IS DESIGNED TO SUPPORT THE VERTICAL MAXIMUM STACK DEPICTED UP TO 1,910 LBS. STACK WEIGHT INCLUDES EXHAUST FAN, DUCT AND ARV. ANY OFFSET, ADDITIONAL RUN OF DUCT OR ADDITIONAL WEIGHT ABOVE THE MAXIMUM STACK WEIGHT STATED WILL REQUIRE ADDITIONAL SUPPORT AND THAT SUPPORT IS NOT DESIGNED OR SUPPLIED BY GFS.

EXHAUST DUCT SHALL BE INSTALLED IN ACCORDANCE WITH ALL LOCAL CODES.


NATIONAL FIRE PREVENTION ASSOCIATION

- AIR EXHAUSTED TO THE ATMOSPHERE FROM LIQUID SPRAY OPERATIONS SHALL BE CONDUCTED BY DUCTS DIRECTLY TO THE OUTSIDE OF THE BUILDING.
- EXHAUST DUCTS SHALL FOLLOW THE MOST DIRECT ROUTE TO THE POINT OF DISCHARGE BUT SHALL NOT PENETRATE A FIRE WALL.
- THE EXHAUST DISCHARGE SHALL BE DIRECTED AWAY FROM ANY FRESH AIR INTAKES.
- THE EXHAUST DUCT SHALL BE AT LEAST 6 FT. (1830 MM) FROM ANY EXTERIOR WALL OR ROOF.
- THE EXHAUST DUCT SHALL NOT DISCHARGE IN THE DIRECTION OF ANY COMBUSTIBLE CONSTRUCTION THAT IS WITHIN 25 FT. (7625 MM) OF THE EXHAUST DUCT DISCHARGE POINT NOR SHALL IT DISCHARGE IN THE DIRECTION OF ANY UNPROTECTED OPENING IN ANY NONCOMBUSTIBLE OR LIMITED-COMBUSTIBLE CONSTRUCTION THAT IS WITHIN 25 FT. (7625 MM) OF THE EXHAUST DUCT DISCHARGE POINT.




INTERNATIONAL FIRE CODE

- THE TERMINATION POINT FOR EXHAUST DUCTS DISCHARGING TO THE ATMOSPHERE SHALL NOT BE LESS THAN THE FOLLOWING DISTANCES:
- DUCTS CONVEYING EXPLOSIVE OR FLAMMABLE VAPORS, FUMES OR DUSTS: 30 FT. (9144 MM) FROM THE PROPERTY LINE; 10 FT. (3048 MM) FROM OPENINGS INTO THE BUILDING; 6 FT. (1830 MM) FROM EXTERIOR WALLS OR ROOFS; 30 FT. (9144 MM) FROM COMBUSTIBLE WALLS OR OPENINGS INTO THE BUILDING WHICH ARE IN THE DIRECTION OF THE EXHAUST DISCHARGE; 10 FT. (3048 MM) ABOVE THE ADJOINING GRADE.

DUCTWORK SHOWN IS FOR REPRESENTATION ONLY. DUCTWORK CAN BE PURCHASED AS ADDITIONAL EQUIPMENT FROM GFS.



LATERAL DUCT SUPPORT REQUIRED WHICH IS NOT DESIGNED OR SUPPLIED BY GFS.



BOOTH EQUIPMENT SPECIFICATIONS EXHAUST FAN

PART #	AMX-245
DIAMETER	34
CFM	11,200
STATIC PRESSURE	3
HORSEPOWER	10
VOLTAGE	208/230/460
PHASE	3
ENCLOSURE	TEFC
QUANTITY	1

LIGHTS

PART #	LABW12-6-LED
SIZE	48
TUBES - INCLUDED	6
TYPE	FLUORESCENT
VOLTAGE	120/277
RATING	CLASS 1 DIV. 2
ACCESS	INSIDE
QUANTITY	4

3 STAGE FILTRATION


1ST STAGE	
TYPE	WAVE ROLL MEDIA
QTY	1
2ND STAGE	
TYPE	20"x20" PANEL FILTER
QTY	32
3RD STAGE	
TYPE	20"x20"x12" 2 POCKET
QTY	32

ELECTRICAL INFO

OPERATING VOLTAGE	
208 VOLT 3PH 4W 60HZ	
FULL LOAD AMPS	35
LARGEST MOTOR HP	10
TOTAL HP	10
LIGHTING VOLTAGE	120 4W
44 AMP MIN SERVICE REQ	

GLOBAL FINISHING SOLUTIONS
 12731 NORWAY ROAD
 OSSEO, WI 54758 USA
 800-848-8738
 globalfinishing.com

IMPORTANT NOTE: This print and all information contained herein is the sole property of Global Finishing Solutions, LLC (GFS). It is not to be used or reproduced in any manner or submitted to other parties for examination without the express written approval of GFS pursuant to a fully-executed contract or purchase order for GFS-manufactured equipment. Customer may make and retain copies of the print for information and reference in connection with an equipment order; however, this print is not intended or represented to be suitable for re-use by Customer or others on extensions of the order or



SCALE	1/4" = 1'-0"
DRAWN BY	BDK
DATE	1/5/2022
REVIEW BY	NM
SHIP TO	

MODEL INFO
 FOCG-140812-NSB-SP-F3
 FRY FILTER OPEN FACE BOOTH 14'W X 8'T X 12'D
 SHIP TO
 FINISHING CONSULTANTS
 201 132ND STREET SW / SUITE 201 518 MARINE DRIVE
 PLATYPUS MARINE, INC.


DESIGN DRAWINGS

DRY FILTER OPEN FACE BOOTH

DFOCG-140812-NSB-SP-F3

SOLD TO
FINISHING CONSULTANTS
FOR
PLATYPUS MARINE, INC.

TABLE OF CONTENTS			
DRAWING	REV	TITLE	DESCRIPTION
01	0	GSN-NOTES	GENERAL STRUCTURAL NOTES
02	0	GSN-DETAILS	STANDARD DETAILS
03	0	DFOCG-140812-NSB-SP-F3	DRY FILTER OPEN FACE BOOTH 14'W X 8'T X 12'D
04	0	DFOCG-140812-NSB-SP-F3	OPEN FACE BOOTH, 14'W X 8'H X 12'D
05	0	CA-IDGE3-1408-34	EXHAUST CHAMBER, 3-STAGE, 14' W X 8' H
06	0	CA-UBG-140806-2L	UNIVERSAL BAY



SOLD TO
FINISHING CONSULTANTS
720 132ND STREET SW / SUITE 201

SHIP TO
PLATYPUS MARINE, INC.
518 MARINE DRIVE

GLOBAL FINISHING SOLUTIONS
12731 NORWAY ROAD
OSSEO, WI 54758 USA
800-840-8730
globalfinishing.com

IMPORTANT NOTE: This print and all information contained herein is the sole property of Global Finishing Solutions, LLC ("GFS"). It is not to be used or reproduced in any manner or submitted to other parties for examination without the express written approval of GFS pursuant to a fully-executed contract or purchase order for GFS-manufactured equipment. Customer may make and retain copies of the print for information and reference in connection with an equipment order; this permission is not to be construed as an endorsement or approval of any other product. Any use without written verification is at the user's risk.

GENERAL STRUCTURAL NOTES

APPLY UNLESS NOTED ON DRAWINGS. IN CASE OF CONFLICT BETWEEN GSN, DETAILS AND PLANS, THE GREATER REQUIREMENTS GOVERN.

DESIGN INFORMATION:

BOOTH AND EQUIPMENT HAS BEEN DESIGNED BASED ON THE CURRENT EDITION OF THE INTERNATIONAL BUILDING CODE

RISK CATEGORY: II
SEISMIC IMPORTANCE FACTOR: IE=1
MAPPED SPECTRAL RESPONSE ACCELERATION:

$S_s = 1.587$
 $S_1 = 0.615$

SITE CLASS: D (ASSUMED)

SPECTRAL RESPONSE COEFFICIENT:

$S_{DS} = 1.269$
 $S_{D1} = 0.697$

SEISMIC DESIGN CATEGORY: D

SEISMIC-FORCE-RESISTING SYSTEMS:

LIGHT-FRAMED WALLS WITH SHEAR PANELS OF ALL OTHER MATERIALS

RESPONSE MODIFICATION FACTOR: R=2
SEISMIC RESPONSE COEFFICIENT: $C_s = 0.635$

ANALYSIS PROCEDURE USED:

EQUIVALENT LATERAL FORCE PROCEDURE

BASIC WIND SPEED: 97 MPH

(PORTIONS OF EQUIPMENT THAT ARE OUTDOOR ONLY - IE STACKS AND STANDS)

BUILDING CATEGORY: INDOOR

EXPOSURE: C

LATERAL LIVE LOAD: 5 PSF

DEAD LOADS: SELF-WEIGHT OF STRUCTURAL STEEL

- 6 PSF (ROOF)
- 4 PSF (WALLS)

BOOTH ROOF LIVE LOADS: N/A PSF

FDN INFORMATION:

CAPACITY OF THE FDN/SLAB TO SUPPORT GFS BOOTHS AND EQUIPMENT IS NOT THE RESPONSIBILITY OF GFS.

ANCHORS INDICATED ARE BASED ON ASSUMPTIONS OF EXIST CONDITIONS (LISTED BELOW). THESE ASSUMPTIONS ARE MADE IN ORDER FOR GFS TO PROVIDE ANCHOR BOLT HOLES IN THE BASE PLATES AND PANELS. EXIST CONDITIONS SHOULD BE VERIFIED BY THE OWNER AND ANY DEVIATIONS SHOULD BE CONVEYED TO GFS PRIOR TO FABRICATION.

1/4"φ SCREW ANCHOR - 1/4"φ POWERS (DEWALT) SCREW-BOLT+ SCREW ANCHORS EMBEDDED 1 15/16" PER ICC ESR-3889 TO SECURE PANELS TO CONC. IN LIEU OF THE POWERS (DEWALT) ANCHOR, 1/4"φ HILTI KWIK HUS-EZ SCREW ANCHORS EMBEDDED 1 15/16" PER ICC ESR-3027 MAY BE USED. EACH WALL/BAY IS REQUIRED TO HAVE ANCHORS AT 18" O.C. MAX, U.N.O. EACH WALL SHALL HAVE (1) ANCHOR 6" MAX FROM END OR CORNER AND A MIN OF (2) ANCHOR PER WALL/BAY. INSTALL ANCHORS PER MFR'S RECOMMENDATION. SEE DETAILS FOR ADDITIONAL INFORMATION. A PREAPPROVED ANCHOR WITH A CAPACITY EQUAL TO OR GREATER THAN THE SPECIFIED ANCHOR AND WITH A CURRENT ICC REPORT MAY BE USED IN LIEU OF THE ANCHOR SPECIFIED. ALL OTHER RESTRICTIONS (INCLUDING BUT NOT LIMITED TO EDGE DISTANCE AND EMBEDMENT) SHALL BE CONSIDERED.

ANCHOR SPECIFICATION IS BASED ON THE FOLLOWING ASSUMPTIONS OF EXIST CONDITIONS:
-- MIN CONC COMPRESSIVE STRENGTH IS 2500 PSI.
-- MIN SLAB DEPTH IS 4".

COLD-FORMED STEEL:

ALL COLD-FORMED STEEL MEETS THE REQUIREMENTS OF THE LATEST EDITION OF THE AISI SPECIFICATION FOR THE DESIGN OF COLD-FORMED STEEL STRUCTURAL MEMBERS. ALL COLD-FORMED STEEL IS COMMERCIAL GRADE WITH A YIELD STRENGTH OF 24 KSI AND AN ULTIMATE STRENGTH OF 40 KSI.

STRUCTURAL STEEL:

ALL STRUCTURAL STEEL FABRICATION AND CONSTRUCTION COMPLY WITH THE LATEST AISC HANDBOOKS AND CODES. ALL STEEL IS ASTM A36, EXCEPT AS FOLLOWS:
-- WIDE FLANGE SECTIONS - ASTM A992,
-- PIPE SECTIONS - ASTM A53 GRADE B,
-- HSS SECTIONS - ASTM A500 GRADE B
-- BOLTS ARE A325-N AND SHALL BE SNUG-TIGHTENED.

WELDING:

WELDERS HOLD CURRENT VALID CERTIFICATES AND HAVE CURRENT EXPERIENCE IN TYPE OF WELD CALLED FOR. STRUCTURAL STEEL WELDING WITH LOW HYDROGEN TYPE, E70 AND E60 FOR LIGHT GAUGE STEEL. STRUCTURAL STEEL WELDING CONFORMS TO THE "STRUCTURAL WELDING CODES-STEEL" AWS D1.1, CURRENT EDITION.

ROOF ACCESS RESTRICTIONS:

THE ROOFS OF GFS EQUIPMENT ARE NOT DESIGNED OR INTENDED TO BE WALKED UPON OR TO SUPPORT WEIGHT OF ANY KIND. AS DESIGNED AND MANUFACTURED, THE EQUIPMENT ROOFS DO NOT MEET THE MINIMUM REQUIREMENTS OF A SAFE WALKING AND/OR WORKING SURFACE UNDER OSHA 1910.22. UNDER NO CIRCUMSTANCES SHOULD THE ROOF BE USED BY MAINTENANCE PERSONNEL OR OTHERS FOR WALKING, STANDING, OR STORAGE OF ANY KIND.

WHEN NECESSARY, ROOF ACCESS SHOULD BE SECURED THROUGH THE USE OF A PROPERLY SUPPORTED PLATFORM THAT SATISFIES THE MINIMUM LOAD REQUIREMENTS SPECIFIED BY ASCE 7 (MINIMUM DESIGN LOADS AND ASSOCIATED CRITERIA FOR BUILDINGS AND OTHER STRUCTURES) AND ASCE 37 (DESIGN LOADS ON STRUCTURES DURING CONSTRUCTION).

ADDITIONALLY, PERSONNEL SHOULD ALWAYS UTILIZE APPROPRIATE FALL SAFETY PROTOCOLS WHEN USING AN ELEVATED PLATFORM. USE OF THE ROOF IN A CONTRARY MANNER MAY RESULT IN INJURY AND/OR DEATH.

SPECIAL INSPECTION INFORMATION:

SPECIAL INSPECTION SHALL BE REQUIRED FOR THE FOLLOWING TYPES OF WORK AND SHALL BE IN COMPLIANCE WITH IBC SECTION 1705:

1. POST-INSTALLED ANCHORS INTO HARDENED CONCRETE.
2. HIGH STRENGTH BOLTING.
3. FIELD WELDING.
4. STRUCTURAL STEEL IN THE SEISMIC FORCE-RESISTING SYSTEMS

STATEMENT OF SPECIAL INSPECTION:

- A THIS STATEMENT OF SPECIAL INSPECTIONS SHALL BE SUBMITTED IN ACCORDANCE WITH SECTION 1704.3 OF THE IBC.
- B THIS STATEMENT SHALL INCLUDE A SCHEDULE OF SPECIAL INSPECTION SERVICES APPLICABLE TO THIS PROJECT.

THE SPECIAL INSPECTOR(S) SHALL KEEP RECORDS OF ALL INSPECTIONS AND SHALL FURNISH INTERIM INSPECTION REPORTS TO THE BUILDING OFFICIAL AND TO THE REGISTERED DESIGN PROFESSIONAL IN RESPONSIBLE CHARGE ON A BI-WEEKLY BASIS. DISCREPANCIES SHALL BE BROUGHT TO THE IMMEDIATE ATTENTION OF THE CONTRACTOR FOR CORRECTION. IF THE DISCREPANCIES ARE NOT CORRECTED, THE DISCREPANCIES SHALL BE BROUGHT TO THE ATTENTION OF THE BUILDING OFFICIAL AND THE REGISTERED DESIGN PROFESSIONAL IN RESPONSIBLE CHARGE PRIOR TO COMPLETION OF THAT PHASE OF WORK. A FINAL REPORT OF SPECIAL INSPECTIONS DOCUMENTING REQUIRED SPECIAL INSPECTIONS AND CORRECTIONS OF ANY DISCREPANCIES NOTED IN THE INSPECTIONS SHALL BE SUBMITTED TO THE BUILDING OFFICIAL AND REGISTERED DESIGN PROFESSIONAL IN RESPONSIBLE CHARGE AT THE CONCLUSION OF THE PROJECT.

THE SPECIAL INSPECTION PROGRAM DOES NOT RELIEVE THE CONTRACTOR OF THE RESPONSIBILITY TO COMPLY WITH THE CONTRACT DOCUMENTS, JOBSITE SAFETY AND MEANS AND METHOD OF CONSTRUCTION ARE SOLELY THE RESPONSIBILITY OF THE CONTRACTOR.

ABBREVIATIONS:

AMU	-	AIR MAKE-UP UNIT
BLDG	-	BUILDING
CONC	-	CONCRETE
ESOW	-	EACH SIDE OF WEB
EXIST	-	EXISTING
FDN	-	FOUNDATION
GA	-	GAUGE
GR5	-	GRADE 5
IBC	-	INTERNATIONAL BUILDING CODE
LBS	-	POUNDS
MAX	-	MAXIMUM
MFR	-	MANUFACTURER
MIN	-	MINIMUM
NS/FS	-	NEAR SIDE AND FAR SIDE
O.C.	-	ON CENTER
OSHA	-	OCCUPATIONAL SAFETY AND HEALTH ADMINISTRATION
PLF	-	POUNDS PER LINEAR FOOT
PSF	-	POUNDS PER SQUARE FOOT
T/B	-	TOP AND BOTTOM
TYP	-	TYPICAL
U.N.O. OR UNO	-	UNLESS NOTED OTHERWISE
WF	-	WIDE FLANGE

GLOBAL FINISHING SOLUTIONS
12731 NORWAY ROAD
OSSEO, WI 54758 USA
800-848-8738
globalfinishing.com

IMPORTANT NOTE: This print and all information contained therein is the sole property of Global Finishing Solutions, Inc. It is to be used only for the project and location specified on the title block. It is not to be reproduced, stored in a retrieval system, or transmitted in any form or by any means, electronic, mechanical, photocopying, recording, or by any information storage and retrieval system, without the express written approval of GFS pursuant to a fully-executed contract or purchase order for GFS-manufactured equipment. Customer may make and retain copies of the print for information and reference in connection with an equipment order; however, this print is not intended or represented to be suitable for re-use by Customer or others on extensions of the order.

SCALE	NTS
DRAWN BY	JO
DATE	3/1/2022
REVIEW BY	BDK
REVIEW DATE	

GENERAL STRUCTURAL NOTES

SHIP TO
PLATYPUS MARINE, INC.
FINISHING CONSULTANTS
10132ND STREET SW / SUITE 201 518 MARINE DRIVE


A

B

C


D

E




DF2A ROOF BEAM
SS###

1. SINGLE SKIN BOOTH ROOF PANEL.
2. 12GA "J" BEAM x 10" DEEP.
3. 18GA BRACE - LOCATE BETWEEN PANELS NEAREST TO MID-SPAN.
4. 5/16"φ A307 BOLT - FIELD DRILL.
5. 10GA SPLICE CHANNEL x 5 1/2" DEEP x 30" LONG.
6. MID-SPAN.
7. (4) 1/2"φ A325 BOLTS EACH SIDE OF SPLICE.




DF2B ROOF BEAM
SS###

1. SINGLE SKIN BOOTH ROOF PANEL.
2. 12GA "J" BEAM x 10" DEEP.
3. 18GA BRACE - LOCATE BETWEEN PANELS NEAREST TO MID-SPAN.
4. 5/16"φ A307 BOLT - FIELD DRILL.
5. 10GA SPLICE CHANNEL x 5 1/2" DEEP x 30" LONG.
6. MID-SPAN.
7. (4) 1/2"φ A325 BOLTS EACH SIDE OF SPLICE.
8. BENT SHEET LEDGER ANGLE - 2x2x14GA.
9. 5/16"φ BOLTS AT 6" O.C.




DF4A FILTER RACK TO WALL STRUT
SS###

1. SINGLE SKIN WALL PANEL.
2. FILTER RACK FRAMING.
3. 18GA STRUT.
4. (2) 5/16"φ A307 BOLTS.
5. (1) 5/16"φ A307 BOLT.




DF3C WALL/ROOF TIE
SS###

1. SINGLE SKIN WALL PANEL.
2. SINGLE SKIN BOOTH ROOF PANEL.
3. TIE ANGLE - 2x2x14GA.
4. 5/16"φ BOLTS AT 6" O.C. TYP WHERE SHOWN.



DF4B FILTER RACK
SS###


1. FILTER RACK FRAMING.
2. 5/16"φ A307 BOLTS AT 6" O.C.



SCALE
3" = 1'-0"

DF1 PANEL TO PANEL CONNECTION
SS###

1. FILTER RACK.
2. FLOOR CHANNEL. FIELD DRILL AS NECESSARY FOR ANCHOR INSTALLATION
3. SEE 1/4"φ SCREW ANCHOR NOTE ON GSN.
4. EXIST SLAB ON GRADE. 4" MIN CONC THICKNESS. VERIFICATION OF SLAB NOT BY GFS.



1. MAY NEED TO REMOVE BOLT AND NUT FOR INSTALLATION OF ANCHOR.
2. SEE 1/4"φ SCREW ANCHOR NOTES ON GSN.
3. EXIST SLAB ON GRADE. 4" MIN CONC THICKNESS. VERIFICATION OF SLAB NOT BY GFS.
4. SINGLE SKIN PANEL.
5. BASE TIE ANGLE

GLOBAL FINISHING SOLUTIONS
12731 NORWAY ROAD
OSSEO, WI 54758 USA
800-848-8738
globalfinishing.com

IMPORTANT NOTE: This print and all information contained herein is the sole property of Global Finishing Solutions, LLC ("GFS"). It is not to be used or reproduced in any manner or submitted to other parties for examination without the express written approval of GFS pursuant to a fully-executed contract or purchase order for GFS-manufactured equipment. Customer may make and retain copies of the print for information and reference in connection with an equipment order; however, this print is not intended or represented to be suitable for re-use by Customer or others on projects of the order. Intentional or unintentional re-use by Customer or others on projects of the order or for any other purpose is prohibited.

SCALE	NTS	DRAWN BY	DATE	REVIEW BY	REVIEW DATE
		JO	3/1/2022	BDK	



DEL INFO
SN-DETAILS
STANDARD DETAILS

SHIP TO
FINISHING CONSULTANTS
132ND STREET SW / SUITE 201
PLATYPUS MARINE, INC.
1518 MARINE DRIVE

2

3

4



INSPECTED AND INVENTORIED BY: _____
 PACKED BY: _____
 QUANTITY PER BOOTH: 1
 BOOTHS REQUIRED: 1
 TOTAL QUANTITY: 1

SKID	ITEM	QTY	PART NUMBER	NEW PART NUMBER	DESCRIPTION	MATERIAL
	1	1	CA-IDGE3-1408-34		EXHAUST CHAMBER, 3-STAGE, 14' W x 8' H	
	2	1	1056847	1056847	AMX-245 AEROVENT MIXED FLOW FAN	
	3	2	CA-UBG-140806-2L		UNIVERSAL BAY	

GLOBAL FINISHING SOLUTIONS
 12731 NORWAY ROAD
 OSSEO, WI 54758 USA
 800-848-8738
globalfinishing.com

IMPORTANT NOTE: This print and all information contained herein is the sole property of Global Finishing Solutions, LLC ("GFS"). It is not to be used or reproduced in any manner or submitted to other parties for examination without the express written approval of GFS pursuant to a fully-executed contract or purchase order for GFS-manufactured equipment. Customer may make and retain copies of the print for information and reference in connection with an equipment order; however, this print is not intended or represented to be suitable for re-use by Customer or others on extensions of the order or on any other project. Any use without written

SCALE	0.06 : 1
DRAWN BY	JO
DATE	3/1/2022
REVIEW BY	
REVISED DATE	

DEL INFO
 FOCG-140812-NSB-SP-F3
 OPEN FACE BOOTH, 14'W x 8'H x 12'D
 OVERALL ASSEMBLY

SHIP TO
 PLATYPUS MARINE, INC.
 518 MARINE DRIVE

FINISHING CONSULTANTS
 100 132ND STREET SW / SUITE 201

1
2
3
4



- NOTE:
 1. USE $\emptyset 5/16"$ x $3/4"$ BOLTS & NUTS FOR ALL PANEL TO PANEL, AND PANEL TO BEAM CONNECTIONS.
 2. USE ONE $\emptyset 5/16"$ x $3/8"$ BOLT & NUT EVERY 6 INCHES FOR FILTER RACK CONNECTIONS.
 3. USE $\emptyset 1/4"$ x $1 1/4"$ NAIL DRIVE ANCHORS TO SECURE PANELS TO FLOOR. (BY OTHERS)

INSPECTED AND INVENTORIED BY: _____
 PACKED BY: _____
 QUANTITY PER BOOTH: 1
 BOOTHS REQUIRED: 1
 TOTAL QUANTITY: 1

SKID	ITEM	QTY	PART NUMBER	NEW PART NUMBER	DESCRIPTION	MATERIAL
	4	1	600-200	1010588	FILTER MONITORING CELL	-
	5	1	FHG8-0240	1008063	MEDIA HANGER, 24	18 GA
	6	3	FHG8-0480	1008064	MEDIA HANGER, 48	18 GA
	7	1	FLC8-4-0720	1008109	FLOOR CHANNEL, 4.313 x 72.000	18 GA
	8	1	FLC8-4-0960	1008110	FLOOR CHANNEL, 4.313 x 96.000	18 GA
	9	1	FRAG8-E4-20038	1014514	FILTER RACK, 3-STAGE, 20 x 37.813 x 4	
	10	1	FRAG8-E4-20040	1007964	FILTER RACK, EXHAUST, 20 x 40 x 4	
	11	7	FRAG8-E4-20098	1007972	FILTER RACK, 3-STAGE, 20 x 97.813 x 4	
	12	2	FRB8-48-4	1007894	FILTER RACK BRACE, 48	18 GA
	13	1	JSG8-0240	1007170	J-STRIP, 24	18 GA
	14	3	JSG8-0480	1007171	J-STRIP, 48	18 GA
	15	1	CP-D01		PANEL FAN, 48.000 x 48.000	10 GA
	16	4	PG8HS-4-24062	1057194	PANEL, 24.000 x 61.625	18 GA
	17	11	PG8HS-4-24096	1005526	PANEL, 24.000 x 95.625	18 GA
	18	1	PG8LS-4-06098-LN13	1024707	PANEL, 5.813 x 97.813	18 GA
	19	6	TG4-0480	1000594	TIE ANGLE, 2 x 2 x 48	14 GA
	20	6	TG4-0840	1000607	TIE ANGLE, 2 x 2 x 84	14 GA
	21	2	TG4-0960	1000610	TIE ANGLE, 2 x 2 x 96	14 GA
	22	2	SG12-FSA-08	1001400	FAN SUPPORT ANGLE, 2.000 x 2.000 x 8.000	12 GA
	23	2	SG14-FSC-096	1001447	FAN SUPPORT CHANNEL, 4.000 x 95.750	14 GA
	24	2	SG12-FSA-42	1001401	FAN SUPPORT ANGLE, 2.000 x 2.000 x 42.000	12 GA
	25	1	PG8LS-4-06098-RN13	1024708	PANEL, 5.813 x 97.813	18 GA


GLOBAL FINISHING SOLUTIONS
 12731 NORWAY ROAD
 OSSEO, WI 54758 USA
 800-848-8738 globalfinishing.com

IMPORTANT NOTE: This print and all information contained therein is the sole property of Global Finishing Solutions, LLC ("GFS"). It is not to be used or reproduced in any manner or submitted to other parties for examination without the express written approval of GFS pursuant to a fully-executed contract or purchase order for GFS-manufactured equipment. Customer may make and retain copies of this print for reference only. No liability shall be assumed for reference in connection with an equipment purchase order or any other project. Any use without written reference to GFS is prohibited. For more information, please contact GFS at 800-848-8738 or globalfinishing.com. Any use without written reference to GFS is prohibited.




3 STAGE FILTRATION INSTALLATION

- NOTE:
 1. USE $\emptyset 5/16"$ x $3/8"$ BOLTS TO ASSEMBLE CENTER VERTICAL SEAM OF EXHAUST RACKS.
 2. USE $\emptyset 5/16"$ x $3/4"$ BOLTS TO ASSEMBLE TOP OF EXHAUST RACKS TO BOTTOM OF PANEL.
 3. INSTALL "PIGTAIL" CLIPS TO FOUR CORNERS OF EACH FILTER CELL BY SLIDING OVER BACK BREAK OF CELL. (CLIP SHOULD BE IN OPEN POSITION UNTIL INSTALLING FILTER PADS.)
 4. INSTALL BAG FILTER BY PUSHING BAG THROUGH CELL UNTIL WIRE FRAME



ROLL MEDIA INSTALLATION


1. INSTALL J-STRIP & HANGER TO PANEL ABOVE FILTER RACKS USING HOLES IN J-STRIP AS PILOT HOLES. (BOTTOM OF HANGER SHOULD BE AT LEAST 1" ABOVE TOP OF FILTER RACK).
 2. TUCK ROLL MEDIA INTO J-STRIP AND PULL DOWN ON TO HANGER.
 3. OVERLAP EDGES OF ROLL MEDIA TO ENSURE ENTIRE FILTER WALL IS COVERED.



SCALE 1 / 18
 DRAWN BY JO
 DATE 3/1/2022
 REVIEW BY
 R/VIEW DATE

MODEL INFO
 A-IDGE3-1408-34
 EXHAUST CHAMBER, 3-STAGE, 14' W x 8' H
 SHIP TO
 PLATYPUS MARINE, INC.
 518 MARINE DRIVE
 FINISHING CONSULTANTS
 20 132ND STREET SW / SUITE 201


- NOTE:
1. WORK DEPTH IS FABRICATED FROM 18 GAGE GALVANIZED SHEET STEEL; STRUCTURAL COMPONENTS ARE FABRICATED FROM 10 AND 12 GAGE GALVANIZED SHEET STEEL; ALL ARE PRE-PUNCHED AND COMPANION FLANGED FOR BOLT TOGETHER ASSEMBLY.
 2. USE $\frac{1}{2}$ "x1" BOLTS & NUTS FOR PLATE TO FRAME MEMBER CONNECTIONS.
 3. USE $\frac{5}{16}$ "x $\frac{3}{4}$ " BOLTS & NUTS FOR TIE ANGLE TO PANEL AND TIE ANGLE TO FRAME MEMBER CONNECTIONS
 4. FRAME BRACE MUST BE LOCATED WITHIN THREE FEET OF THE CENTER OF BOOTH, BETWEEN PANEL FLANGES. FIELD DRILL (1) $\frac{3}{8}$ " HOLE THRU TOP STRUCTURAL MEMBERS AND USE $\frac{5}{16}$ "x1" BOLT & NUT TO SECURE FRAME BRACE TO STRUCTURE.
 5. SEE GSN DRAWING FOR PANEL ANCHORING DETAILS.
 6. FIRE CURTAINS TO BE PLACED ON MOST OUTER FACE OF BAY (FRONT BOOTH) FIRE CURTAIN NOT NEEDED IF PRODUCT DOORS ADDED.




FRAME BRACE DETAIL
FRAME BRACE MUST BE PLACED BETWEEN PANEL FLANGES WITHIN THREE FEET OF BAY CENTER.

INSPECTED AND INVENTORIED BY:	
PACKED BY:	
QUANTITY PER BOOTH:	2
BOOTHS REQUIRED:	1
TOTAL QUANTITY:	2




SKID	ITEM	QTY	PART NUMBER	NEW PART NUMBER	DESCRIPTION	MATERIAL
	20	2	TG4-0840	1000607	TIE ANGLE, 2 x 2 x 84	14 GA
	26	4	PG8HS-36096	1005494	PANEL, 36.000 x 95.625	18 GA
	27	2	FCJG8-0840	1008134	FIRE CURTAIN, 7.000 X 84.000	18 GA
	28	2	PG8HL-36072	1005827	PANEL, 36.000 x 71.625	18 GA
	29	1	PG8HS-24072	1005630	PANEL, 24.000 x 71.625	18 GA
	30	2	PG8HS-36072	1005607	PANEL, 36.000 x 71.625	18 GA
	31	1	SG10-SP-06030	1001493	SPLICE PLATE 5.500 x 30.000	10 GA
	32	4	SG12-CB-1010	1001495	CORNER BRACE, 9.625 x 9.625	12 GA
	33	1	SG12-FMU-10086L	1001518	FRAME MEMBER, 10.000 x 86.000	12 GA
	34	1	SG12-FMU-10086R-LAW	1042204	STRUCTURAL MEMBER W/ LABEL, 10.000 x 86.000	
	35	1	SG18-FBU-15	1001456	FRAME BRACE	18 GA
	36	4	TG4-0720	1000602	TIE ANGLE, 2 x 2 x 72	14 GA
	37	2	CP-TA01		TIE ANGLE, 2.000 x 2.000 x 72.000	10 GA



** ASSEMBLE FRAMES, SPLICE PLATE, AND CORNER PLATES ON THE GROUND. LIFT INTO POSITION AND BOLT TO CEILING AND WALL PANELS.



FIRE CURTAIN DETAIL



GLOBAL FINISHING SOLUTIONS
12731 NORWAY ROAD
OSSEO, WI 54758 USA
800-848-8738
globalfinishing.com

IMPORTANT NOTE: This print and all information contained therein is the sole property of Global Finishing Solutions, LLC ("GFS"). It is not to be used or reproduced in any manner or submitted to other parties for use without the express written approval of GFS pursuant to a non-exclusive contract or purchase order. GFS shall not be held liable for any errors or omissions in this drawing or any other information. Reference in connection with an equipment order; however, this print is not intended or represented to be suitable for re-use by Customer or others on extensions of the order or on any other project. Any use without written permission is prohibited.

SCALE	1 / 20
DRAWN BY	JO
DATE	3/1/2022
REVIEW BY	
REVIEW DATE	

SHIP TO
PLATYPUS MARINE, INC.
518 MARINE DRIVE

DEL INFO
1-UBG-140806-2L
UNIVERSAL BAY
FINISHING CONSULTANTS
132ND STREET SW / SUITE 201

GREEN  DIAMOND
SAND PRODUCTS
 ABRASIVE PRODUCTS

(1636, 2050, 3060)

MATERIAL SAFETY
DATA SHEET

SECTION I - PRODUCT IDENTIFICATION		HMIS
Manufacturer's Name:	Green Diamond Sand Products	Health - O
Telephone:	(541) 874-3111	Flammability - O
Address:	PO Box D, Riddle, OR 97469	Reactivity - O
Date Prepared:	August 1, 2013	Protective Gear - K

SECTION II - HAZARDOUS INGREDIENTS/IDENTITY INFORMATION			
Hazardous Components (Specific Chemical ID - Common Names)	CAS No.	ACGIH TLV	OSHA PEL
SiO ₂ (Silicates)	112926-00-8	10 mg/m ³	10 mg/m ³
MgO (Magnesium Oxide)	1309-48-4	10 mg/m ³	10 mg/m ³
Fe ₂ O ₃ (Iron Oxide)	1309-37-1	10 mg/m ³ *	10 mg/m ³
Al ₂ O ₃ (Aluminum Oxide)	1344-28-1	10 mg/m ³	10 mg/m ³
CaO (Calcium Oxide)	1305-78-8	2 mg/m ³	5 mg/m ³
Ni (Nickel)	7440-02-0	1 mg/m ³	1 mg/m ³
Cr ₂ O ₃ (Chromium Oxide)	1308-38-9	10 mg/m ³ *	15 mg/m ³ *

*Regulated as for nuisance particulate (dust).

TYPICAL ANALYSIS:		
SiO ₂	50.2%	<i>All SiO₂ reported in Green Diamond materials is in the form of silicates and contains no crystalline silica. Crystalline silica is the only form of silica suspected of being carcinogenic.</i>
MgO	31.4%	
Fe ₂ O ₃	15.9%	
Al ₂ O ₃	1.6%	
CaO	0.7%	
Ni + NiO	<.1%	
Cr ₂ O ₃	.1%	
Trace Elements & Compounds (total)	1.5%	
TOTAL	99.8%	

SECTION 313 SUPPLIER NOTIFICATION		
This product contains the following toxic chemicals subject to the reporting requirements of section 313 of the Emergency Planning and Community Right-To-Know Act of 1986 (40 CFR 372):		
<u>CAS #</u>	<u>Chemical Name</u>	<u>Percent by Weight</u>
7440-02-0	Nickel	<.1%
This information should be included in all MSDSs that are copied and distributed for this material.		

SECTION III - PHYSICAL/CHEMICAL CHARACTERISTICS

Boiling Point:	NA
Vapor Pressure (mm Hg.):	NA
Vapor Density (AIR = 1):	NA
Specific Gravity (H2O = 1):	3.0
Melting Point:	2,650 Deg. F
Evaporation Rate:	NA
Solubility in Water:	Not soluble in water
Appearance and Odor:	Green, Gray granular, no odor

SECTION IV - FIRE AND EXPLOSION HAZARD DATA

Flash Point:	NA
Flammable Limits:	NA
Extinguishing Media:	NA
Special Fire Fighting Procedures:	None
Unusual Fire & Explosion Hazards:	None

SECTION V - REACTIVITY DATA

Stability:	Stable
Conditions to Avoid:	None
Incompatibility (materials to avoid):	None
Hazardous Decomposition or By-Products:	None
Hazardous Polymerization:	Will not occur
Conditions to Avoid:	None

SECTION VI - HEALTH HAZARD DATA

Route(s) of Entry:	Inhalation?	Yes
	Skin?	No
	Ingestion?	No
Health Hazards (Acute & Chronic):		No specific health hazards; should avoid specified limits for compounds listed in Section II.
Carcinogenicity:	NTP?	No
	IARC Monographs?	No
	OSHA Regulated?	Yes, control for compounds in Section II and for nuisance dust.
Sign & Symptoms of Exposure:		Typical of over exposure to nuisance dust.
Medical Conditions Generally Aggravated by Exposure:		Respiratory conditions.
Emergency & First Aid Procedures:		As relevant for over exposure to nuisance dust.

SECTION VII - PRECAUTIONS FOR SAFE HANDLING & USE

Steps to be Taken in Case Material

is Released or Spilled:

Clean up with broom or vacuum.

Waste Disposal Method:

Follow federal, state, and local regulations for disposal as in inert solid waste.

Precautions to be Taken in Handling & Storing:

No specific precautions.

Other Precautions:

None

SECTION VIII - CONTROL MEASURES

Respiratory Protection (Specify Type):

NIOSH/OSHA/MSHA approved particulate filter respirator.

Ventilation:

Yes

Local Exhaust:

Yes

Mechanical (General):

Use to meet TLV requirement if dust is generated.

Special:

None

Other:

None

Protective Gloves:

Yes, if handling.

Eye Protection:

Yes, safety glasses.

Other Protective Clothing or Equipment:

Appropriate apparel.

Work/Hygienic Practices:

Use material for the purpose intended and incorporate methods of dust control that are effective in maintaining airborne dust concentrations within the TLV.

NOTICE

While the information included in this MSDS has been obtained from reliable sources, this information is furnished without any warranty (expressed or implied), representation, inducement, or license except that it is accurate to the best of Green Diamond Sand Products knowledge. This information is offered solely for your consideration, investigation, and verification. Any use of this information must be determined by the user to be in accordance with applicable federal, state, and local laws and regulations. Furthermore, the conditions or methods of handling, storage, use and disposal of the product are beyond the control and knowledge of Green Diamond Sand Products. Green Diamond Sand Products does not assume responsibility and expressly disclaim liability for any loss, damage, or expense arising out of or in any way connected with the handling, storage, use, or disposal of the product. Buyer assumes all risks in its use of the product.

Product Information			HAP Content - Look up using Product MSDSs *											
Product Name	Description or part #	Annual usage gallons <small>purchase records</small>	Product Density * <small>lb/gal from MSDS</small>	VOC content ** <small>weight % from MSDS</small>	PM content <small>weight % calculated</small>	108883 Toluene				100414 Ethyl benzene		1330207 Xylene		67561 Methanol
						wt%	wt%	wt%	wt%	wt%	wt%	wt%	wt%	
Lacquer Thinner 2	LT2	300	6.85	55.0	45.0	50.00								5.00
Denatured alcohol	QSL26	390	6.65	61.0	39.0									60.00
Multi-Purpose solvent	MS251	165	6.93	100.0	0.0	75.00								30.00
Sherwin Williams Sea Voyage black	N51E301	160	12.75	11.9	88.1			0.56					2.37	
American Safety Technologies MS-5000 DK Gray PT A (MS510R)		270	17.41	61.0	39.0									
Sherwin Williams Sea Guard 5000HS part B (N11V00350)		600	11.43	12.0	88.0								1.00	
Sherwin Williams Sea Voyage Red 5000 part B	N51R301	215	13.23	11.5	88.5			0.56					2.39	
American Safety Technologies MS-5000 part B	MS-5101	30	17.41	3.0	97.0									
Sherwin Williams PSILX XLE-80 HF B	B80V800	69	7.76	27.2	72.8			4.20					23.00	
Sherwin Williams R7K130 Reducer (Seaguard Solvent #130)		55	8.70	53.0	47.0									
Sherwin Williams Sea Guard 5000 HS red Part A	N11R350	240.00	11.63	24.0	76.0									
Sherwin Williams Sea Guard 5000 HS white Part A	N11W350	85.00	12.32	24.0	76.0								1.00	
Sherwin Williams Seaguard Ablative Anti-Fouling Black	P30BQ12	160.00	17.86	12.5	87.5			2.50					10.00	
Sherwin Williams Sea Guard 5000 HS Gray Part A	N11A00350	100.00	11.82	24.0	76.0									
Sherwin Williams Sea Guard 5000 HS Buff Part A	N11H00350	150.00	11.91	18.0	82.0									
Sea Hawk Biocop TF AF Black	1205	19.00	15.76	12.0	88.0			1.00					1.00	
Sherwin Williams PXLE80 White PT A	B80W00800	68.75	10.17	19.0	81.0			3.00					16.00	
AWLgrip 545 Converter	OD3001	91.00	8.11	50.0	50.0	25.00								
AWLgrip 545 White base	OD8001	90.00	8.11	11.0	89.0								10.00	
AWLgrip AWL-CAT #2 Spray Converter	G3010	53.00	8.34	36.0	64.0	25.00							10.00	
Sherwin Williams Polysiloxane XLE80 D. Gray 26008 Part A	B80AW0651	20.00	17.35	19.0	81.0			3.00					16.00	
American Safety MS-200 Dark Gray 36076 Part A	MS209R	60.00	9.82	9.0	91.0			1.00					2.00	
AWLgrip Hullgard Extra Base	OD6120	38.00	11.94	35.0	65.0			10.00					25.00	
Interlux interprotection 2000E Underwater Primer Gray base	Y2000E	57.00	12.70	30.0	70.0			10.00					10.00	
Interlux interprotect 2002E underwater primer white base	Y2002E	56.00	12.70	3.0	97.0								1.00	
Sherwin Williams Seaguard ablative anti-fouling Red	P30RQ10	105.00	18.13	11.0	89.1			1.00					9.50	
		3646.50			100.0									
					100.0									

Product Information									
Product Name	71432 Benzene (including wt% 0.01	95636 1,2,4-Trimethylbenzene wt%	98828 Cumene wt%	1344281 Al oxide wt%	71363 N-Butyl Alcohol wt%	78933 Methyl ethyl Ketone wt%	67630 Isopropyl Alcohol wt%	822060 Hexamethylene- HAP wt%	Cas Number
Lacquer Thinner 2									
Denatured alcohol									
Multi-Purpose solvent									
Sherwin Williams Sea Voyage black		7.93	1.06						
American Safety Technologies MS-5000 DK Gray PT A (MS510R)			1.00	60.00					
Sherwin Williams Sea Guard 5000HS part B (N11V00350)		10.00	1.00						
Sherwin Williams Sea Voyage Red 5000 part B		7.52	1.00						
American Safety Technologies MS-5000 part B		3.00							
Sherwin Williams PSILX XLE-80 HF B									
Sherwin Williams R7K130 Reducer (Seaguard Solvent #130)		3.00			50.00				
Sherwin Williams Sea Guard 5000 HS red Part A					24.00				
Sherwin Williams Sea Guard 5000 HS white Part A					23.00				
Sherwin Williams Seaguard Ablative Anti-Fouling Black									
Sherwin Williams Sea Guard 5000 HS Gray Part A					24.00				
Sherwin Williams Sea Guard 5000 HS Buff Part A					18.00				
Sea Hawk Biocop TF AF Black		10.00							
Sherwin Williams PXLE80 White PT A									
AWLgrip 545 Converter						25.00			
AWLgrip 545 White base							25.00		
AWLgrip AWL-CAT #2 Spray Converter								1.00	
Sherwin Williams Polysiloxane XLE80 D. Gray 26008 Part A									
American Safety MS-200 Dark Gray 36076 Part A		5.00	1.00						
AWLgrip Hullgard Extra Base									
Interlux interprotection 2000E Underwater Primer Gray base		10.00							
Interlux interprotect 2002E underwater primer white base	1.00								
Sherwin Williams Seaguard ablative anti-fouling Red									

Summary of HAP and VOC totals for consecutive 12-month period			
Pollutant	Consecutive 12-month actual emissions (tons)	Consecutive 12-month PTE total (tons/yr)	ORCAA PTE threshold (tons/yr)
Individual HAP			
Styrene	1.719	(tons/yr) 0.076	22.0
Methyl ethyl Ketone	0.001	0.000	22.0
Dimethyl phthalate	0.035	0.002	22.0
Cumene	0.001	0.000	22.0
HAP	0.000	0.000	22.0
HAP	0.000	0.000	22.0
HAP	0.000	0.000	22.0
HAP	0.000	0.000	22.0
N-Butyl Alcohol	0.000	0.000	22.0
Methyl ethyl Ketone	0.000	0.000	22.0
Isopropyl Alcohol	0.000	0.000	22.0
Hexamethylene-1,6-diisocyanate	0.000	0.000	22.0
Total HAPs	1.8	(tons/yr) 0.1	12.00
Total VOCs	1.5	(tons/yr) 0.07 (lbs/24 hours) 0.18 (lbs/hour) 0.01	22.00
PM₁₀ (based on TE)	1.3	(tons/yr) 0.1 (lbs/hour) 0.006	100.00
Current Date	August 15, 2023		
Assumptions			
Annual hours of Fiberglass operations:	500		
Transfer Efficiency (TE):	0.45		
60% - Transfer Efficiency (TE) of an HVLV gun			
45% - Average Transfer Efficiency			
30% - Transfer Efficiency of a conventional gun			
		Platypus Marine uses both HVL and conventional guns 50/50	
		(tons/yr) 25.00	No threshold
			No threshold

Welding emissions for 12-month rolling total ending with:

August

2023

Welding type		AWS classification		Emission factors <i>lb/1000 lb of electrode consumed</i>							Emissions <i>lbs/year</i>						
Type of welding wire	Welding process	Electrode type	Fume (PM10)	Cr	Cr (VI)	Co	Mn	Ni	Pb	PM10	Cr	Cr (VI)	Co	Mn	Ni	Pb	
SS Flux core ESB 35FA129	FCAW	E316LT	8.50	ND	ND	ND	ND	ND	ND								
SS Tig Rod CWS316L3323	GTAW																
SS Tig Rod SS Tig Rod ESE carbon steel hard wire	GTAW		5.20	0.00	ND	0.00	0.32	0.00	ND	0.343	0.000		0.000	0.021	0.000		
Aluminum tig rod 5138	GTAW	E70S															
Aluminum tig rod 5356	GTAW																
Aluminum wire 4043 1/8x36	GTAW																
Aluminum wire 4043 3/32x36	GTAW																

Actual (tons) :

Potential to emit (PTE) (tons) :

PTE is based on annual operating hours at facility:

0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
0.0007	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
2080									

